



General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • (517) 788-0650

September 12, 1980

Director Nuclear Reactor Regulation
Att Mr Dennis M Crutchfield, Chief
Operating Reactors Branch No 5
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 -
BIG ROCK POINT PLANT - TECHNICAL SPECIFICATIONS
ERRORS IDENTIFIED DURING AMENDMENT NO 33
IMPLEMENTATION REVIEW

By letter dated August 11, 1980, the Commission issued Amendment No 33 to the Big Rock Point Facility Operating License No DPR-6. During Consumers Power Company's review prior to implementation of the amendment, two errors were noted.

The two errors should be corrected as follows:

1. Page 7, Section 3.5.1(d) - Change "1 Set Automatic A-C Operated" to "1 Set Remote Manual A-C Operated."
2. Page 143, Section 11.4.3.4E - Change power supply breaker designation "52-2B34" to "52-2B45."

(Page changes attached.)

The requested wording change in 1 above is required to reflect the condition of power supply breaker 52-2B45 which is locked open to preclude inadvertent operation of MO-7068 (reference Technical Specifications Section 11.3.3.4A). The wording "remote manual" is chosen to reflect the manual action required to unlock the breaker which allows remote operation of the valve from the control room. The requested wording change in 2 above is required to correct a typographical error in our submitt. dated July 7, 1980.


oc0980-0204a-48

8009250278

P

Acc'd
9/11

It is requested that these corrections be formally made so that the Big Rock Point Technical Specifications can accurately reflect current conditions.



David P Hoffman
Nuclear Licensing Administrator

CC Director, Region III, USNRC
NRC Resident Inspector-Big Rock Point