

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

FEB 25 1975

Commonwealth Edison Company
ATTN: Mr. Byron Lee, Jr.
Vice President
P.O. Box 767
Chicago, Illinois 60690

Docket No. 50-10
Docket No. 50-237

Gentlemen:

This is in response to your letters dated January 17, 1975 and February 5, 1975, informing us of the steps you have taken to correct the items of noncompliance which we brought to your attention in our letter dated December 26, 1974. We will examine these matters during a subsequent inspection.

With respect to your response to Item A.1.b temporary changes to procedures are not the means to incorporate less safe conditions than originally intended. As stated in your facility Technical Specifications, temporary changes which do not change the intent of the original procedure may be made under controlled conditions. When conditions are made less safe, we consider the intent has been changed. This matter was discussed with Mr. Elfrink of your office on February 11, 1975.

Should you have any questions concerning this matter, we will be glad to discuss them with you.

Sincerely yours,

Gaston Fiorelli, Chief
Reactor Operations Branch

bcc w/ltrs dtd 1/17 and 2/5/75:
IE Chief, FS&EB
IE HQ (4)
Licensing (4)
Central Files
IE Files
PDR
Local PDR

Rosiman, Esq.



POOR ORIGINAL

8009250

507

LE