

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE: I L Z I S 1; LICENSE NUMBER: 00-000000-000; LICENSE TYPE: 41111; CAT: 5

REPORT SOURCE: L; DOCKET NUMBER: 0150000295; EVENT DATE: 030380; REPORT DATE: 092280

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

During monthly containment isolation (CI) valve operability test, pressurizer liquid space sample valve LAOV-SS9355A failed to close placing the CI system in a degraded mode of operation in violation of T.S. 3.9.3.A. The valve was closed with manual assistance. Health and safety of the public were not affected since the redundant CI valve LAOV-9355B was operable and closed as required.

SYSTEM CODE: SO; CAUSE CODE: E; CAUSE SUBCODE: X; COMPONENT CODE: VALVE; COMP. SUBCODE: F; VALVE SUBCODE: D

EVENT YEAR: 80; SEQUENTIAL REPORT NO.: 039; OCCURRENCE CODE: 3; REPORT TYPE: L; REVISION NO.: 0

LER/RO REPORT NUMBER: 180; ACTION TAKEN: XB; FUTURE ACTION: B; EFFECT ON PLANT: Z; SHUTDOWN METHOD: Z; HOURS: 0000; ATTACHMENT SUBMITTED: N; NRC-4 FORM SUB.: Y; PRIME COMP. SUPPLIER: N; COMPONENT MANUFACTURER: M120

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

Cause of failure unknown at this time due to inaccessibility of the valve. This valve is only required to open during startup and not during operation. Work request has been written and valve will be worked on during next refueling outage.

FACILITY STATUS: E; % POWER: 096; OTHER STATUS: NA; METHOD OF DISCOVERY: B; DISCOVERY DESCRIPTION: Operator Observation

ACTIVITY CONTENT RELEASED OF RELEASE: Z; AMOUNT OF ACTIVITY: NA; LOCATION OF RELEASE: NA

PERSONNEL EXPOSURES NUMBER: 0.0; TYPE: Z; DESCRIPTION: NA

PERSONNEL INJURIES NUMBER: 0; DESCRIPTION: NA

LOSS OF OR DAMAGE TO FACILITY TYPE: Z; DESCRIPTION: NA

PUBLICITY ISSUED: N; DESCRIPTION: NA

NAME OF PREPARER: Benson Binggeli; PHONE: 312-746-2084 x 490

8010020537