



Metropolitan Edison Company
Post Office Box 480
Middletown, Pennsylvania 17057

Writer's Direct Dial Number

September 22, 1980
TLL 477

Office of Inspection and Enforcement
Attn: Mr. Boyce H. Grier, Director
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406


Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Licensee Event Report 80-039/03L-0

Attached please find Licensee Event Report 80-039/03L-0, concerning the inoperability of the Cable Room and Transformer Room Halon Fire Suppression System on August 22, 1980.

This event constitutes a violation of Section 3.7.10.3 and is considered reportable under Section 6.9.1.9(b) of the Interim Recovery Technical Specifications.

Sincerely,


G. K. Hovey
Director, TMI-2

GKH:SDC:dad

cc: John T. Collins
Bernard J. Snyder

8010030409 S

A002
S/11