

Telephone 617 366-9011


TWX

710-390-0739

YANKEE ATOMIC ELECTRIC COMPANY

WYR 80-109

B.3.2.1



20 Turnpike Road Westborough, Massachusetts 01581

September 25, 1980

United States Nuclear Regulatory Commission
Washington, D.C. 20555

Attention: Office of Nuclear Reactor Regulation
Mr. Thomas M. Novak, Assistant Director
Operating Reactors
Division of Licensing

References: (a) License No. DPR-3 (Docket No. 50-29)
(b) USNRC Letter to YAEC dated August 15, 1980

Dear Sir:

As requested in Reference (b), a review was conducted of our technical specifications and procedures to assure that the minimum level of water over the fuel assemblies is approximately 33 feet. As a result of this review, we have concluded that our existing technical specifications and procedures are adequate to assure that a level of water approximately 33 feet, sufficient depth to prevent inadvertent exposure of a fuel assembly during transfer, is maintained. No further action is deemed necessary at this time.

We trust that you find this information satisfactory; however, should you desire additional information please contact us.

Very truly yours,

YANKEE ATOMIC ELECTRIC COMPANY

Ray E. Moody
D. E. Moody for

Manager of Operations

BLD/sec

8010060308

P