



ARKANSAS POWER & LIGHT COMPANY
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

October 1, 1980

1-090-28

Mr. K. V. Seyfrit, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Comm.
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Licensee Event Report
No. 80-032/04L-0
(File: 0520)

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 1 Environmental Technical Specification 5.6.2.b, attached is the subject report concerning the rate of release of radioactive materials in gaseous wastes which exceeded the site boundary limit of 1 MPC.

Very truly yours,

David C. Trimble
Manager, Licensing

DCT:GAC:skm

~~854~~
Attachment

cc: Mr. Victor Stello, Jr., Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Comm.
Washington, D. C. 20555

Mr. Norman M. Haller, Director
Office of Management & Program Analysis
U. S. Nuclear Regulatory Comm.
Washington, D. C. 20555

8010070540

5

MEMBER MIDDLE SOUTH UTILITIES SYSTEM