

# University of Illinois at Urbana-Champaign

## Nuclear Engineering Program

214 Nuclear Engineering Laboratory  
Urbana, Illinois 61801  
(217) 333-2295

9-9-80

Docket No. 50-151

Docket No. 50-356

Report No. 50-151/80-02; 50-356/80-02

A.B. Davis, Chief  
Fuel Facility and Mat. Saf. Branch  
U. S. Nuclear Regulator Commission  
799 Roosevelt Rd.  
Glen Ellyn, Ill. 60137


Dear Mr. Davis:

In the report of the inspection by Mr. R. A. Paul on August 19-20, 1980, a significant error was noted under Item 15 Independent Measurements.

The report states that the reactor was operating at 500 watts during the survey. The actual power during the survey was 500 kilowatts. This becomes significant in terms of the measurements at the face of the north beam port.

This should be corrected before placing the report in the NRC's Public Document Room. Otherwise, this response should be attached to our response to the noncompliance item.

Sincerely,



Gerald P. Beck, Reactor Supervisor  
Nuclear Reactor Lab.

SEP 15 1980

8010200 102