



435 Sixth Avenue  
Pittsburgh, Pa.  
15219

2DLC-3709

(412) 456-6000

September 19, 1980

United States Nuclear Regulatory Commission  
Region I  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

ATTENTION: Mr. Boyce H. Grier, Director


SUBJECT: Beaver Valley Power Station - Unit No. 2  
Docket No. 50-412  
I.E. Bulletin 80-20  
Failures of Westinghouse Type W-2 Spring Return to Neutral  
Control Switches

Gentlemen:

We have reviewed I.E. Bulletin No. 80-20, dated July 31, 1980 which discusses a malfunction of a Westinghouse Type W-2 control switch at the Zion Generating Station, Unit 1. Stone & Webster has reviewed all possible locations where Westinghouse type W-2 switches could be used and have found that none of these switches are being supplied with equipment for Beaver Valley Power Station - Unit No. 2.

The manpower expended to conduct the review and preparation for the report required by this bulletin is two hours.

DUQUESNE LIGHT COMPANY

BY   
E. J. Woolever  
Vice President

COPIES TO: Mr. V. Stello (15)

8 010200 380