

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

JOHN S. DYSON
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

FREDERICK R. CLARK



October 14, 1980
JPN-80-45

GEORGE T. BERRY
PRESIDENT & CHIEF
OPERATING OFFICER

JOHN W. BOSTON
EXECUTIVE VICE
PRESIDENT & DIRECTOR
OF POWER OPERATIONS

JOSEPH R. SCHMIEDER
EXECUTIVE VICE
PRESIDENT & CHIEF
ENGINEER

ROY W. SINCLAIR
SENIOR VICE PRESIDENT
& CHIEF FINANCIAL
OFFICER

THOMAS R. FREY
SENIOR VICE PRESIDENT
& GENERAL COUNSEL

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Thomas A. Ippolito, Chief
Operating Reactors Branch No. 2
Division of Licensing

Subject: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
TMI-2 Action Plan Items II.E.4.1,
II.K.3.13a, and II.K.3.30a

Reference: Letter, D.G. Eisenhut (NRC) to All
Operating Plant Licensees dated September 5, 1980

Dear Sir:

The following summarizes the present status of the subject
TMI-2 Action Plan items:

1. Item II.E.4.1 - Dedicated Hydrogen Penetrations

Submittal of the required system design information was
made in a letter dated September 30, 1980 from R. J. Pasternak
(Power Authority) to T.A. Ippolito (NRC).

2. Item II.K.3.13a - Separation of HPCI and RCIC System Initiation
Levels - Analysis

A. Separation of HPCI/RCIC Initiation Setpoints

The Power Authority, as a member of the BWR Owners'
Group, concurs with the General Electric report on this
topic which was submitted in a letter dated October 1,
1980 from R.H. Bucholz (GE) to D.G. Eisenhut (NRC).

1001
10/15/80

8010200 441


B. RCIC Auto Restart

General Electric, in a letter dated September 29, 1980 from R. H. Bucholz (GE) to D. F. Ross, Jr. (NRC), has requested a meeting with the NRC staff to resolve concerns associated with this topic. The Power Authority, as a member of the BWR Owners' Group, will evaluate the GE analysis pertaining to this item when this information is made available to the Owners' Group.

3. Item II.K.3.30a - Revised Small Break LOCA Methods to Show Compliance with 10CFR50, Appendix K - Schedule Outline

The Power Authority has been informed by General Electric that an extension of the October 1, 1980 submittal date has been granted by the NRC staff. The Power Authority will evaluate the schedule and outline required for this item when this information is made available to the BWR Owners' Group.

Very truly yours,


J. P. Bayne
Senior Vice President
Nuclear Generation