BIG ROCK POINT

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M I B R P 1 (2) | 0 0 - 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 - 0 1 5 5 (7) | 0 9 1 7 8 0 (8) | 1 0 1 5 8 0 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Following intermittent automatic test circuit alarms, the sensor Channel
03 | D of the Reactor Depressurizing System was removed from service to vent
04 | the reactor water level transmitter LT3183. All four RDS loops remained
05 | operable for this condition with 2/3 logic instead of 2/4. No hazard oc-
06 | curred and the equipment was restored to operable status within 4 hours
07 | per Tech Spec 11.3.1.5.3. Similar to RO-80-28. Reportability based on
08 | Tech Spec 6.9.2.b(2).
7 8 9 80

09 | SYSTEM CODE S H (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER [EVENT YEAR 8 0] — | SEQUENTIAL REPORT NO. 0 3 2 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN E (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)
33 34 35 36 37 40 41 42 43 44

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | In addition to minor conservative calibration shift occurring in the
11 | reactor water level transmitter, the setpoint for reactor low level is
12 | unduly conservative. A Technical Specification change was approved on
13 | 9/16/80 to provide greater margin in the trip setpoint, but had not been
14 | implemented by the time of occurrence of this event.
7 8 9 80

15 | FACILITY STATUS E (28) | % POWER 0 6 0 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation of Alarm
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 0 0 0 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY (43) TYPE Z (42) | DESCRIPTION NA
7 8 9 10 80

20 | PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 9 10 68 69 80

8010200564