



Portland General Electric Company
Trojan Nuclear Plant
P.O. Box 439
Rainier, Oregon 97045
(503) 536-3713



October 16, 1980
CPY-1023-80

Mr. R. H. Engelken, Director
US Nuclear Regulatory Commission, Region V
1990 North California Boulevard
Walnut Creek, California 94596

Dear Sir:

A Limiting Condition for Operation (LCO), 3.7.8.1 of the Trojan Technical Specifications, requires that a special report be provided in the event of inoperability of the fire suppression system. System operability as defined by Paragraph B of the referenced LCO will not be met during a planned maintenance overhaul of the diesel-driven fire pump. The inspection includes preventative maintenance on the diesel engine as well as the pump. In addition, the pump also will be coated with a corrosion inhibitor at this time. This letter represents the initial notification and follow-up report as required by the Technical Specifications.

The removal of the diesel-driven fire pump requires that an additional source of fire suppression water be provided as a backup to the electric motor-driven fire pump. The Rainier Rural Fire Protection District has agreed to station a pumper truck at the site while the diesel-driven pump is out of service. A drafting connection from the cooling tower basin will provide the necessary pumper water supply. The pumper will be aligned to discharge into the fire main via Hydrant No. 3 located south of the Security Building. The pumper will only be used in the event of an electric motor-driven fire pump failure. It is anticipated that the system will be in this configuration from October 20 through November 12, 1980.

Sincerely,

C. E. Yundt
C. E. Yundt
General Manager

CPY/RPK/lsm1A13:mae

c: LER Distribution
J. R. Deardorff
C. F. Marpe
File 103.x/93.24a

A002
s
1/0

8010280 347 F

80-272