

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER · DALLAS, TEXAS 75201

R. J. GARY  
EXECUTIVE VICE PRESIDENT  
AND GENERAL MANAGER

October 21, 1980  
TXX-3222

Mr. W. C. Seidle, Chief  
Reactor Construction & Engineering  
Support Branch  
U. S. Nuclear Regulatory Commission  
Office of Inspection & Enforcement  
611 Ryan Plaza Dr., Suite 1000  
Arlington, Texas 76012

Docket Nos. 50-445  
50-446

COMANCHE PEAK STEAM ELECTRIC STATION  
DIESEL GENERATOR PIPE SUPPORTS  
FILE NO: 10110


Dear Mr. Seidle:

In accordance with the requirements of 10 CFR 50.55(e), this letter provides the status of the manufacturing deficiency we reported verbally to your Mr. W. C. Crossman on September 26, 1980, relative to the component supports associated with the auxiliary piping systems for the CPSES Unit 1 and Unit 2 Diesel Generators.

Specifications for this equipment imposed the requirements of ASME III which in turn imposed Subsection NF through Subsection ND, Paragraph 3676.9. The supplier (Delaval) manufactured the supports in accordance with their standard shop procedures without acknowledging the requirements of Subsection NF. This deficiency is currently being evaluated by Engineering with the objective of formulating appropriate corrective action. We plan to file our formal report on this matter on or before January 16, 1981.

If we can provide any additional information, please advise.

Very truly yours,

  
for R. J. Gary

RJG:dk

cc: NRC Region IV - (0 + 1 copy)

Director, Inspection & Enforcement - (15 copies)  
c/o Distribution Services Branch, DDC, ADM.  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8010280 358 5