U. S. NUCLEAR REGULATORY COMMISSION NRC FORM 366 (7.77) LICENSEE EVENT REPORT (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) JO CONTROL BLOCK: 0 0 0 0 0 0 0 200 CTHNP 0 LICENSEE CODE CON'T 8 1 0 2 4 8 0 0 9 2 6 8 0 69 EVENT DATE REPCAT 0 5 0 - 0 2 3 0 1 (6) SOURCE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During surveillance testing of the diesel fire pump; it was found that the pump 0 2 discharge pressure at 2500 GPM was found to be only 94 PSIG. The pressure required 0 3 The basis for this by Technical Specifications, (Section 4.15.A.d.2) is 100 PSIG. 0 4 test is to check for equipment failures and deterioration. Since only a minor 0 5 deviation was observed, no significant consequences are expected. 0 6 0 7 0 8 9 COMP VALVE CAUSE SYSTEM CAUSE SUBCODE COMPONENT CODE SUBCODE CODE CODE B (13) Z | (15 NI GI II N E 1(14 (16) B AIBI (12) (11) 19 REVISION OCCURRENCE REPORT SEQUENTIAL NO REPORT NO. CODE TYPE EVENT YEAR LER/RO 0 0111 01 3 L 81 01 4 (17 REPORT NUMBER 30 COMPONENT PRIME COMP. NPRD-4 ATTACHMENT EFFECT ON PLANT METHOD FUTURE ACTION HOURS (22) FORM SUB. N 23 1 0 0 0 N (24) L (25 GI 2/21 01 01 Z E 18 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) The pump did not run at rated capacity because of low operating RPM of the diesel 1 0 Adjustments have been made to increase the diesel motor operating RPM motor. 111 and an additional flow test have been performed which verified compliance with 1 2 Technical Specifications. 1 3 1 4 80 - 13 METHOD OF OTHER STATUS (30) FACILITY DISCOVERY DESCRIPTION (32) % POWER B (31 Inspection 0 (29 Inservice 80 10 CONTENT ACTIVITY LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35) RELEASED OF RELEASE N/A N/A Z 33 Z (34) 6 80 44 PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER TYPE (3) Z N/A 01010 38 7 80 PERSONNEL INJURIES DESCRIPTION (41) NUMBER N/A 0 0 1 0 (40 80 LOSS OF OR DAMAGE TO FACILITY (43) DESCRIPTION N/A Z 9 (42 80 PUBLICITY 8010280523 N/A NRC USE ONLY DESCRIPTION (45) N AA 111111 0 68 69 80 PHONE: (203) 267-2556 R. P. Traggio/J. A. Chunis NAME OF PREPARER