



Portland General Electric Company



August 29, 1980

Trojan Nuclear Plant
Docket 50-344
License NPF-1

Mr. R. H. Engelken, Director
U. S. Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 N. California Blvd.
Walnut Creek, CA 94596

Dear Sir:

We have reviewed IE Bulletin 80-19, Revision 1 related to failures of mercury-wetted matrix relays in reactor protective systems of operating nuclear power plants designed by Combustion Engineering. As a result of our review, we have determined that no mercury-wetted relays of the type described are utilized in the logic matrix of the Reactor Protection System at the Trojan Nuclear Plant. Therefore, no corrective actions are necessary.

Manpower expended in conduct of the review required by IE Bulletin 80-19, Revision 1 is estimated at five equivalent man-days.

Sincerely,

C. Goodwin, Jr.
Assistant Vice President
Thermal Plant Operation and
Maintenance

CG/DRS/4sa6A25

c: Mr. Lynn Frank, Director
State of Oregon
Department of Energy

Office of Inspection and
Enforcement
Division of Reactor Operations
Inspection
U. S. Nuclear Regulatory Commission

8010300678

Q

80-236