

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | V T V Y S I | 2 | 0 0 - 0 0 0 0 0 0 - 0 0 | 3 | 4 1 1 1 1 | 4 | _____ | 5

CON'T
0 1 | REPORT SOURCE | L | 6 | 0 5 0 0 0 2 7 1 | 7 | 1 0 2 7 8 0 | 8 | 1 0 2 7 8 0 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During performance of Inservice Inspection while shut down for refueling, a linear
0 3 | indication was discovered by ultrasonic testing at weld F3B on Reactor Cleanup water
0 4 | suction line CUW-18. Verification by radiography on 10/27/80 disclosed a rejectable
0 5 | indication in the weld heat-affected zone.
0 6 |
0 7 |
0 8 |

0 9 | SYSTEM CODE | C G | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | P I P E X X | 14 | COMP SUBCODE | B | 15 | VALVE SUBCODE | Z | 16

(17) LER/RO REPORT NUMBER | 8 0 | EVENT YEAR | 8 0 | SEQUENTIAL REPORT NO. | 0 3 7 | OCCURRENCE CODE | 0 1 | REPORT TYPE | P | REVISION NO. | 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Additional examinations required by ASME Section XI are underway to determine the
1 1 | extent of this problem. Corrective action to be taken will be identified in a
1 2 | subsequent report.
1 3 |
1 4 |

1 5 | FACILITY STATUS | H | 28 | % POWER | 0 0 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Inservice Inspection | 32

1 6 | ACTIVITY CONTENT | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

1 7 | PERSONNEL EXPOSURES NUMBER | 0 0 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

1 8 | PERSONNEL INJURIES NUMBER | 0 0 0 | 40 | DESCRIPTION | NA | 41

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45

8010310478 NAME OF PREPARER Warren P. Murphy PHONE: (802) 257-7711