

CONSUMERS POWER COMPANY

Docket 50-155

Request for Change to the Technical Specifications
License DPR-6

For the reasons hereinafter set forth, it is requested that the Technical Specifications contained in the Facility Operating License DPR-6, Docket 50-155, issued to Consumers Power Company on May 1, 1964, for the Big Rock Point Plant be changed as described in Section I below:

I. Change(s)

Section 11.4.1.4A.

Delete the following wording, "Verify that the hose required for backup cooling water to the core spray recirculation heat exchanger is installed on a designated rack in the screen house."

Section 11.4.1.4B.

Delete the following wording, "Verify that the hose used for backup cooling water to the core spray recirculation heat exchanger is operable and free of obvious defects. Perform a leak check and flow check of the backup cooling water hose when connected between the screen house fire water connection and the core spray recirculation heat exchanger."

and replace with, "Verify remote manual actuation of MO-7080, MO-7081, MO-7082, and MO-7083."

Bases: (Emergency Core Cooling System - Section 11)

In the third paragraph, delete the following wording, "fire hose" and replace with, "redundant line".

II. Discussion

The above proposed Technical Specifications are requested to make the Technical Specifications accurately reflect the "as-built" condition of the plant and its surveillance requirements after the facility is modified during the 1980 refueling outage. The purpose of the facility modification is to reduce operator dose in the event of an accident which requires backup cooling water for core spray recirculation heat exchanger operation. The addition of permanent piping and remote manually actuated valving will eliminate the need for plant operators to install the current fire hose and make appropriate valve lineups to provide backup cooling water.

III. Conclusion(s)

Based on the foregoing both the Big Rock Point Plant Review Committee and

the Safety and Audit Review Board have reviewed this change and find it acceptable.

CONSUMERS POWER COMPANY

By R B DeWitt
R B DeWitt, Vice President
Nuclear Operations

Sworn and subscribed to before me this 28th day of October, 1980.

Linda K. Carstens
Linda K Carstens, Notary Public
Jackson County, Michigan
My commission expires June 10, 1981