

JRBuchanan
DRoss

DISTRIBUTION
Docket
NRC PDR
Local PDR
ORB#1 Reading
KRGoller
TJCarter
SMSheppard
ABurger
OELD
OI&E(3)
BJones(4)
BScharf(15)
JMcGough
ACRS(16)
OPA(CMiles)
TBAbernathy

Docket No. 50-29

July 15, 1976

Yankee Atomic Electric Company
ATTN: Mr. Robert H. Groce
Licensing Engineer
20 Turnpike Road
Westboro, Massachusetts 01581

Gentlemen:

The Commission has issued the enclosed Amendment No. 28 to Facility License No. DPR-3 for the Yankee Nuclear Power Station (Yankee-Rowe). The amendment consists of changes to the Technical Specifications in response to your application dated April 21, 1976.

The amendment replaces descriptive pages in Section 203 of the Final Hazards Summary Report which is incorporated in the Technical Specifications appended to License No. DPR-3. The amendment allows the installation of a pulsation dampener on the Charging Pump No. 3 discharge header.

Copies of the Safety Evaluation and the Federal Register Notice are also enclosed.

Sincerely,

Original signed by

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosures:

1. Amendment No. 28 to DPR-3
2. Safety Evaluation
3. Federal Register Notice

3
4

cc w/enclosures:
See next page

8011030781

P

OFFICE x27433	ORB#1	OELD SMY	ORB#1		
SURNAME	ABurger:tsb	S. J. SCHWENCER	ASchwencer		
DATE	7/5/76	7/14/76	7/15/76		

POOR ORIGINAL