

Docket No. 50-29

TBAbernathy
JRBuchanan
VStello

September 3, 1976

DISTRIBUTION
Docket
NRC PDR
Local PDR
ORB#1 Reading
KRGoller/TJCarter
ASchwencer
ABurger
SMSheppard
OELD
OI&E(5)
BJones(4)
BScharf(15)
JMcGough
ACRS(16)
OPA(CMiles)
DBoss

Yankee Atomic Electric Company
ATTN: Mr. Robert H. Groce
Licensing Engineer
20 Turnpike Road
Westboro, Massachusetts 01581

Gentlemen:

The Commission has issued the enclosed Amendment No. 30 to Facility License No. DPR-3 for the Yankee Nuclear Power Station (Yankee-Rowe). The amendment consists of changes to the Technical Specifications in response to your request dated March 5, 1976.

The amendment replaces descriptive pages in Section 214 "Nuclear Instrumentation and Reactor Protection System" of the Facility Hazards Summary Report which is incorporated in the Technical Specifications appended to License No. DPR-3. The amendment allows certain changes to the reactor scram bypass circuitry to improve its performance capability.

We acknowledge your commitments to implement the changes prior to the completion of the Spring 1977 outage for refueling Yankee-Rowe.

Copies of the Safety Evaluation and the Federal Register Notice are also enclosed.

Sincerely,

Original signed by

A. Schwencer, Chief
Operating Reactors Branch #1
Division of Operating Reactors

Enclosures:

1. Amendment No. 30 to DPR-3
2. Safety Evaluation
3. Federal Register Notice

cc w/enclosures:
See next page

T

OFFICE → x27433	ORB#1	OELD <i>SMS</i>	ORB#1 <i>AB</i>			
SURNAME →	ABurger:tsb	<i>S. SCHINK</i>	ASchwencer			
DATE →	8/26/76 <i>AB</i>	8/30/76	8/3/76			

80 11080 809

POOR ORIGINAL