

MAR 5 1975

Docket No. 50-29

DISTRIBUTION
 Docket File
 NRC PDR
 Local PDR
 ORB#1 Reading
 JRBuchanan
 TBAbernathy
 KRGoldner
 RAPurple
 ABurger
 SMSheppard
 FGray, OELD
 SVarga
 TJCarter
 ACRS (12)
 I&E (3)

Yankee Atomic Electric Company
 ATTN: Mr. G. Carl Andognini, Assistant
 to the Vice President
 20 Turnpike Road
 Westboro, Massachusetts 01581

Gentlemen:

In accordance with the Commission's Order for Modification of License issued to you on December 27, 1974, you are presently required, among other things, to operate Yankee-Rowe only within the limits of the proposed Technical Specifications submitted by you on December 12, 1974 (Proposed Change No. 117, Supplement 1), as modified by the further restrictions set forth in Appendix A attached to the Commission's Order.

By letter dated December 30, 1974, you submitted Supplement 2 to Proposed Change No. 117 to reflect a reanalysis based upon the actual lower Low Pressure Safety Injection (LPSI) pump flow than that assumed in your ECCS analysis dated July 31, 1974.

As you know, your December 30, 1974 submittal does not alter the operating limits specified in the Commission's Order dated December 27, 1974. Therefore, in view of your letter of January 23, 1975, which indicated your intent to comply with the December 27, 1974 Order, we intend to take no action on your December 30, 1974 submittal at this time. These changes, of course, may be proposed at the time you submit the requisite evaluation in accordance with the December 27, 1974 Order.

Sincerely,

Original signed by
 R. A. Purple

Robert A. Purple, Chief
 Operating Reactors Branch #1
 Division of Reactor Licensing

cc: Mr. Donald G. Allen, President
 Yankee Atomic Electric Company
 20 Turnpike Road
 Westboro, Massachusetts 01581

SEE PREVIOUS YELLOW FOR CONCURRENCES FROM ABurger AND OELD(FGray)

| | | | | | |
|---------|------------|---------|----------|--|--|
| OFFICE | RL:ORB#1 | OELD | RL:ORB#1 | | |
| SURNANE | ABurger:dc | FGray | RAPurple | | |
| DATE | 2/13/75 | 2/28/75 | 3/5/75 | | |

8011040 721

P POOR ORIGINAL