710-390-0739

## YANKEE ATOMIC ELECTRIC COMPANY

WYR 75-1



20 Turnpike Road Westborough, Massachusetts 01581

January 2, 1975.

United States Atomic Energy Commission Washington, D. C. 20545

Attention: Directorate of Licensing

Subject: Revised ECCS Analysis

Reference: 1) License No. DPR-3 (Docket No. 50-29)

 Proposed Jhange No. 117, "Revised ECCS Analysis", submitted to DOL/AEC on July 31, 1974.

3) Buterbaugh, T. L., Johnson, W. J., and Kopelic, S. D., "Westinghouse ECCS-Plant Sensitivity Studies", WCAP-8356, July 1974.

Dear Sir:

Pursuant to 10 CFR 50.46, a revised ECCS analysis (2), performed in accordance with Appendix K to 10 CFR 50 was submitted to the Directorate of Licensing. The following additional information is hereby forwarded to you as verbally requested by members of your staff on December 23, 1974.

Table 411-1 of Reference 2 shows the results of the four large breaks that were analyzed. It is concluded that the double-ended cold leg guillotine break with a discharge coefficient of 0.6 is the worst break. Additional large breaks were not analyzed on the following basis:

- (1) Westinghouse has reported sensitivity studies on a four loop plant (Yankee Rowe has four loops) in WCAP-8340 (Proprietary Class 2) and WCAP-8356 (Proprietary Class 3). In these studies, values of 1.0, 0.8, 0.6, and 0.4 were used for the break discharge coefficient. It was shown that the worst rupture is the double-ended cold leg guillotine break with a discharge coefficient of 0.6;
- (2) In performing Appendix K analyses for their customers, Westinghouse customarily provided analyses with discharge coefficients of 1.0, 0.6, and 0.4, confirming the results of the above sensitivity study;







United States Atomic Energy Commission January 2, 1975 Attn: Directorate of Licensing Page Two (3) Results shown in Table 411-1 show only a slight sensitivity to the value of the break discharge coefficient; (4) The flow area for a double-ended cold leg guillotine break is only 2.84 ft. compared to 8.25 ft. for current design PWRs. Thus, a much finer mesh in break sizes is involved for Yankee Rowe. Respectfully submitted, YANKEE ATOMIC ELECTRIC COMPANY D. E. Vandenburgh Vice President AEL/kg

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

(TEMPORARY FORM) CONTROL NO: 60 FILE:\_ RPT OTHER TWX LTR DATE OF DOC DATE REC'D FROM Tankee Atomic Elec. Co. Westborough, Mass. 01581 1-2-75 1-3-75 XX D. E. Vandenburgh SENT AEC PDR\_ CC OTHER ORIG TO: SENT LOCAL PDR\_ 3 sigmed 37 DRL DOCKET NO: NO CYS REC'D INPUT PROP INFO UNCLASS CLASS 50-29 40 XXX ENCLOSURES: DESCRIPTION: Ltr furnishing addl info re ECCS submittal re Proposed Change No. 117 on -7-31-74 ..... PLANT NAME: Yankee Rowe 1-4-75 FOR ACTION/INFORMATION ZIEWANN (L) REGAN(E) SCH .: ENCER IL BUTLERILL W/ Copies W/ Copies W/ Coples W Cones LEAR (L) DICKER (E) STOLZ (L) CLARK (L) W/ Copies W/ Copies W/ Copies W/ Con'es KNIGHTON (E) PARE IL VASSALLO (L) W/ Copies W/ Copies / Copies W/ Copies UEPLE (L) YOUNGBLOOD (E) KNIEL (L) W/ Copies 6 Copies W/ Copies W/ Copies INTERNAL DISTRIBUTION DENITON GRANUES GANNILL A/T IND LIC ASST TECH REVIEW BRAIT! A' OGC, ROD'S PEOSA OULTZELG STAFF SALTZMA". DIGGS (L) SCHROEDER B. HURT KASTNER GEARIN (L) MACCARY GOULBOURNE (L) BALLARD KNIGHT PLANS KREUTZER (E) SPANGLER **K**STAMBUSSO PAWLICKI MCDONALD LEE (L) SHAO CHAPMAY MAIGRET (L) TELLO ENVIRO MADORE (L) (BWR) DUBE REED (E) WULLER DEYOUTED LI (FAF) SKOVHOLT (LI POUSTON ME. COUPE SERVICE (L) DICKER CHEPPARD (L) VOSS. KNIGHTON GOLLER (L) D. THOMPSON (2) SLATER (E) YOUNGBLOCD P. COLLIES DENISE IPPOLITO KLECKER REGAN SMITH (L) TEDESCO EISENHUT REGCPR TEETS (L) PROJECT LDR LONG WILLIAMS (E) IARGA VILE & REGION 2 LAINAS WILSON (L) HARLESS BENAROYA MORES STEELE VOLIMER EXTERNAL DISTRIBUTION - LOCAL FOR THE THEREOF - NATIONAL LABS -1 - PDR SAN LATTY 1 - ASLEP E W Blin Rm 5:0) 1 - W. FELLIN, 3 TO Y Rm E 231 GT 1 - 83 Y S 201 TO 10 Fm E 201 37 1 - CC 1 TO 10 1 - BROOKHAVER

READAN SELECT RESIDEN

LIC. ASST. SHEPPARD 1-4-75

1 = G. ULPMSOTA 1 = AGUED (FLTH Rm E 1.0 GT

1 - P. D. L'UELLES,

Gi