

APPENDIX A

NOTICE OF VIOLATION

Georgia Power Company  
Hatch Unit 2

License No. NPF-5

Based on the NRC inspection July 15 - August 15, 1980, certain of your activities were apparently not conducted in full compliance with NRC requirements as indicated below. These items have been categorized as described in correspondence to you dated December 31, 1974.

As required by Technical Specification 3.3.1, a minimum of 2 operable channels per trip system for the scram discharge volume high level trip in modes 1 and 2 are to be operable. Technical Specification 3.0.4 requires that entry into an operational condition shall not be made unless Limiting Conditions for Operation of these instruments are met.

Contrary to the above, the reactor plant was taken to modes 1 and 2 with "A" and "D" scram discharge volume level switches inoperable subsequent to scrams on June 2, June 14, July 11, and July 26, 1980.

This is an infraction.