

Central Files

AUG 29 1977

Docket No. 50-29 ✓

MEMORANDUM FOR: E. J. Brunner, Chief, RO&HS Br., RI

FROM: K. V. Seyfrit, A/D, TP, ROI, IE

SUBJECT: CONCURRENCE ON REGION I POSITION ON CILRT AT
YANKEE ROWE (AITS F14566H2)

We have reviewed the memorandum of 7/13/77 from D.L. Caphton on the above referenced subject. Our opinion is that the minor deviation from the pumpback mass requirement of the Technical Specifications is, as was indicated by the Region, not sufficient cause to reject the test when apparently a valid test in other respects was completed. We agree with your conclusion.

It is our understanding that the other matters related to the completion of the test which are still unresolved (as of 7/13/77) will be clarified and reviewed by the Region prior to final acceptance of the test.

In our review of this question we noted what appeared to be a typographical error in the section reference to the technical specification in the Notice of Violation and on page 5 of IE Inspection Report 50-29/77-11. The reference cited is noted as "4.6.2.1.c" and we believe that should be "4.6.1.2.c."

If there are any further questions regarding the results of the testing, please contact us.

Original signed by
K.V. Seyfrit

K. V. Seyfrit, Assistant Director
Technical Programs, ROI, IE

cc: J. C. Higgins, RI

50-29

CONTACT: R. Shewmaker
49-27551

OFFICE	REIXIEXXXXXXIXRIBIXIEX	ROI:IE	TP:ROI:IE
SURNAME	XXXXXXXXXXXXXXXXXXXXXXXXXX RShewmaker KVSeifrit	RShewmaker	KVSeifrit
DATE	8/22/77	8/ /77	8/ /77

8011050648

9

POOR ORIGINAL