

file

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

FEB 25 1975

Yankee Atomic Electric Company
Attention: Mr. G. Carl Andognini
Assistant to Vice President
20 Turnpike Road
Westborough, Massachusetts 01581

License No. DPR-3
Insp. No. 50-29/74-16

References: (1) Your letter dated February 7, 1975
(2) Telephone conversations between Mr. H. Autio and
Mr. J. Streeter on February 18, 19 and 20, 1975
In response to our letter dated January 10, 1975


Thank you for informing us of the corrective and preventive actions you documented in response to our correspondence. These actions will be examined during a subsequent inspection of your licensed program.

With respect to Item A.3., we understand from Reference 2 that Administrative Procedure AP-0225, "Control of Drawings", has been approved by the Plant Operations Review Committee and will be approved by the Manager of Operations and implemented by the plant by March 15, 1975. We also understand that immediate steps are being taken by the plant to assure that plant drawings used by maintenance and operating personnel are updated in some manner promptly after changes occur.

With respect to Item A.4., we understand from Reference 2 that Administrative Procedure AP-0215, "Control of Measuring and Test Equipment", will be revised by March 15, 1975, to document the plant requirement for "as-found" conditions for measuring and test equipment calibrated off site.

Your cooperation with us is appreciated.

Sincerely,


Eldon J. Brunner, Chief
Reactor Operations Branch

cc: H. Autio, Plant Superintendent
Donald G. Allen, President



2011050700

Q

Bcc: IE Chief, FS&EB
IE:HQ (4)
IE:Files
Central Mail & Files
Directorate of Licensing (4)
Regulatory Standards
PDR
Local PDR
NSIC
TIC
State of Massachusetts
REG I: Reading Room
GCC