

MEETING NOTICE DISTRIBUTION

Docket File  
NRC PDR  
Local PDR  
TIC  
NSIC  
TERA  
LB #2 File  
H. Denton  
E. Case  
D. Eisenhut  
R. Purple  
T. Novak  
S. Varga  
T. Ippolito  
R. A. Clark  
R. Reid  
R. Tedesco  
J. Youngblood  
A. Schwencer  
F. Miraglia  
J. R. Miller  
G. Lainas  
D. Crutchfield  
W. Russell  
J. Olshinski  
R. Vollmer  
R. Bosnak  
F. Schauer  
R. E. Jackson  
G. Lear  
V. Noonan  
S. Pawlicki  
V. Benaroya  
Z. Rosztoczy  
W. Haass  
D. Muller  
R. Ballard  
W. Regan  
J. D. Saltzman  
D. Ross  
P. Check  
R. Satterfield  
O. Parr  
F. Rosa  
W. Butler  
W. Kreger  
R. W. Houston  
T. Murphy  
W. Gammill  
J. Kramer

L. Rubenstein  
T. Speis  
W. Johnston  
B. Grimes  
H. Collins  
F. Pagano  
S. Ramos  
J. Stolz  
S. Hanauer  
P. Collins  
D. Vassallo  
D. Ziemann  
R. Mattson  
R. Schroeder  
K. Kniel  
D. Skovholt  
C. Knighton  
M. Ernst  
R. Baer  
E. Adensam  
A. Thadani  
ACRS (16)  
Attorney, OELD  
OIE (3)  
OSD (7)  
Project Manager CStahle  
Licensing Assistant MService  
Receptionist  
J. LeDoux, I&E  
V. Moore  
I&E Headquarters  
I&E Region I  
I&E Region II  
I&E Region III  
I&E Region IV  
I&E Region V

NRC Participants:

Others:

BCC: Applicant & Service List



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

OCT 16 1980

Docket No. 50-364

MEMORANDUM FOR: A. Schwencer, Chief  
Licensing Branch No. 2, DOL

FROM: L. Kintner, Project Manager  
Licensing Branch No. 2, DOL


SUBJECT: FORTHCOMING MEETING WITH ALABAMA POWER COMPANY REGARDING  
REVIEW OF FARLEY 2 OPERATING LICENSE APPLICATION

DATE & TIME: October 22, 1980 11:30 a.m.

LOCATION: Joseph M. Farley Nuclear Plant  
Dothan, Alabama

PURPOSE: To review the auxiliary feedwater system  
(proposed agenda attached)

PARTICIPANTS: ALABAMA POWER COMPANY  
Ron George, George Hairston  
BECHTEL CORPORATION  
Harold Bell  
WESTINGHOUSE  
Glen Lang  
NRC STAFF  
T. Dunning and C. E. Rossi

  
Lester Kintner, Project Manager  
Licensing Branch No. 2  
Division of Licensing

cc: See next page

OCT 16 1980

Mr. F. L. Clayton, Jr., Senior Vice  
President  
Alabama Power Company  
Post Office Box 2641  
Birmingham, Alabama 35291

cc: Mr. W. O. Whitt  
Executive Vice President  
Alabama Power Company  
Post Office Box 2641  
Birmingham, Alabama 35291

Mr. W. Bradford  
NRC Resident Inspector  
P. O. Box 1814  
Dothan, Alabama 36302

Mr. Ruble A. Thomas  
Vice President  
Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202

Mr. George F. Trowbridge  
Shaw, Pittman, Potts and Trowbridge  
1800 M Street, N. W.  
Washington, D. C. 20036

Ira L. Myers, M. D.  
State Health Officer  
State Dept. of Public Health  
State Office Building  
Montgomery, Alabama 36104

Honorable A. A. Middleton  
Chairman  
Houston County Commission  
Dothan, Alabama 36301

U. S. Environmental Protection Agency  
ATTN: EIS Coordinator  
Region IV Office  
345 Courtland Street, N. E.  
Atlanta, Georgia 30308

PROPOSED AGENDA FOR MEETING WITH  
ALABAMA POWER COMPANY ON AUXILIARY  
FEEDWATER SYSTEM ACTUATION LOGIC

- 1) Review auxiliary feedwater system actuation logic by going through automatic initiation, operation, and reset sequence assuming each possible system switch position at the start of the sequence. Perform this review for each automatic initiation signal.
- 2) Review power supply assignments for each train of the auxiliary feedwater system.
- 3) Review switch locations for each switch in the auxiliary feedwater system.
- 4) Review control system failures which can result in inadvertent auxiliary feedwater actuation during plant heatup, cooldown, or shutdown operations.
- 5) Discuss specific concerns on attached.

CONCERNS WITH ALABAMA POWER COMPANY AUXILIARY FEEDWATER  
SYSTEM ACTUATION LOGIC

- 1) The redundant solenoid valves in the control air lines to the auxiliary feedwater pump discharge valves are presently arranged to be "energize to close or modulate" the discharge valves and "de-energize to open" the discharge valves. When the auxiliary feedwater system is in use, the loss of a single power supply will, thus, open all of the auxiliary feedwater pump discharge valves and initiate full auxiliary feedwater flow to the steam generators. The following information is needed to evaluate this design:
  - a) A conservative analysis of the primary system cooldown rate following the opening of the auxiliary feedwater pump discharge valves with the auxiliary feedwater pumps in operation during hot shutdown, system heat-up, or system cooldown. This should include both normal operation and automatic initiation of auxiliary feedwater for transients and accidents. The analysis should include primary system pressure response and indicate operator actions necessary to maintain cooldown rates within appropriate limits and to maintain required primary system pressure and temperature relations
  - b) Steam generator levels versus time for the transients in a) above
  - c) The safety related reasons (if any) for designing the system such that the solenoid valves "de-energize to open" the pump discharge valves
- 2) The motor driven pump discharge valves are apparently not automatically fully opened following a low low steam generator level signal if the valve switch is in the "mod" position even though low low steam generator level is the primary auxiliary feedwater system actuation signal for loss of feedwater accidents not involving initiation of safety injection. This appears to be a deficiency in the design.
- 3) The power source dependencies of other components in the auxiliary feedwater trains is also of concern, e.g., the normal loading stations which are used to throttle auxiliary feedwater flow.