

ENCLOSURE 2

Nebraska Public Power District
Cooper Nuclear Station
Docket No. 50-298

NOTICE OF DEVIATION

Based on the results of an NRC inspection conducted on September 8-11, 1980, it appears that certain of your activities were not conducted in full conformance with your commitment to the Commission as indicated below:

The licensee's approved operator requalification program states that "A planned lecture series shall be presented covering, as a minimum, those areas where annual examinations indicate the need for additional training in the following subjects:

"1. Theory and principles of operation.

* * *

"10. Station QA program as related to station operations."

In deviation from the above, the annual examination administered in February - April, 1980, did not address the subject of "Station QA program as related to Station operations" (298/80-13-04).