



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

TERA

October 23, 1980

Docket No. 50-344

Mr. Charles Goodwin, Jr.
Assistant Vice President
Portland General Electric Company
121 SW Salmon Street
Portland, Oregon 97204

Dear Mr. Goodwin:

Our letter to you of October 3, 1979, forwarded our requirements regarding the auxiliary feedwater system at Trojan Nuclear Plant. These requirements were identified during the course of the NRR Bulletins and Orders Task Force review of operating reactors following the accident at Three Mile Island Unit No. 2. These requirements are also identified in NUREG-0611, "Generic Evaluation of Feedwater Transients and Small Break Loss-of-Coolant Accidents in Westinghouse-Designed Operating Plants." You responded to this letter on November 26 and December 31, 1979, February 5, July 1, and July 25, 1980.

Our evaluation of your responses is contained in the enclosed Safety Evaluation Report (SER). You will note that there are two unresolved items identified in this report (GS-5 and Additional Long Term Recommendation 5), and two items for which our review has not been completed (Additional Short Term Recommendation 3 and GL-5). You are requested to respond to the unresolved items within 45 days of your receipt of this letter.

Based on discussions with your staff, we understand that you have now modified the auxiliary feedwater system to provide self-cooling for the steam-driven auxiliary feedwater pump and have also added low suction pressure protection for both pumps. Therefore, our SER is somewhat out of date in certain areas since it is based on the information provided in your written submittals. You are requested to include an update of the progress you have made with auxiliary feedwater system modifications in your response to the unresolved items discussed above.

Please contact us if you have any questions concerning this matter.

Sincerely,

Robert A. Clark, Chief
Operating Reactors Branch #3
Division of Licensing

Enclosure:
SER

cc w/encl:
See next page

8011060 143

P

POOR ORIGINAL

Mr. Charles Goodwin, Jr.
Portland General Electric Company

cc: Mr. J. W. Durham, Esquire
Vice President and Corporate Counsel
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Donald W. Godard, Supervisor
Siting and Regulation
Oregon Department of Energy
Labor and Industries Building
Room 111
Salem, Oregon 97310

Columbia County Courthouse
Law Library, Circuit Court Room
St. Helens, Oregon 97501

Michael Malmros, Resident Inspector
U. S. Nuclear Regulatory Commission
Trojan Nuclear Plant
P. O. Box 0
Rainier, Oregon 97043

Robert M. Hunt, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97051

Director, Technical Assessment Division
Office of Radiation Programs (AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460