



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 3, 1978

Docket No. 50-29

Yankee Atomic Power Company
ATTN: Mr. Robert H. Groce
Licensing Engineer
20 Turnpike Road
Westboro, Massachusetts 01581

Gentlemen:

The Commission has issued the enclosed Amendment No. 47 to Facility License No. DPR-3 for the Yankee Nuclear Power Station (Yankee-Rowe). The amendment consists of changes to the Technical Specifications in response to your application dated February 17, 1978.

The amendment revises the Technical Specifications to eliminate the requirement for the Intermediate Power Range setpoint adjustment to 25% during core physics testing and to delete the provisions of the Respiratory Protection Program.

Copies of the Safety Evaluation and the Notice of Issuance are also enclosed.

Sincerely,

A handwritten signature in cursive script that reads "Dennis L. Ziemann".

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosures:

1. Amendment No. 47 to DPR-3
2. Safety Evaluation
3. Notice of Issuance

cc w/enclosures:
See next page

8011060 667

A handwritten mark in the bottom right corner of the page, resembling a stylized letter 'P' or a similar symbol.

April 3, 1978

cc: Mr. Donald G. Allen, President
Yankee Atomic Electric Company
20 Turnpike Road
Westboro, Massachusetts 01581

Greenfield Community College
1 College Drive
Greenfield, Massachusetts 01301

*Massachusetts Department of Public
Health
ATTN: Commissioner of Public
Health
600 Washington Street
Boston, Massachusetts 02111

Chief, Energy Systems
Analyses Branch (AW-459)
Office of Radiation Programs
U.S. Environmental Protection Agency
Room 645, East Tower
401 M Street, SW.,
Washington, D.C. 20460

U.S. Environmental Protection Agency
Region I Office
ATTN: EIS COORDINATOR
JFK Federal Building
Boston, Massachusetts 02203

Chairman
Board of Selectmen
Town of Rowe
Rowe, Massachusetts 01367

*(w/cy of YAEC's filing .td. 2/17/78)