


Suppl



UNITED STATES
ATOMIC ENERGY COMMISSION
WASHINGTON 25, D. C.

MAY 25 1961

Docket No. 50-29

Change No. 7

Change No. 7

Yankee Atomic Electric Company
441 Stuart Street
Boston 16, Massachusetts

Attention: Mr. Roger J. Coe
President

Gentlemen:

This refers to your request dated May 8, 1961 for AEC authorization to make Proposed Change No. 7 in your facility pursuant to paragraph 3.A. of License No. DPR-3, as amended.

We have reviewed the proposed modification of the facility and have found that installation of the control circuitry necessary to initiate a trip of the boiler feed pumps in the event of a reactor scram above 15 MW electric as described does not present significant hazards considerations not described or implicit in the license application as amended to January 12, 1961, and there is reasonable assurance that the health and safety of the public will not be endangered by operation of the facility as proposed. A copy of our analysis of the operation of the facility with the modification described is attached hereto.

In view of the foregoing, authorization is hereby granted to Yankee Atomic Electric Company to install the control circuitry necessary to initiate a trip of the boiler feed pumps in the event of a reactor scram above 15 MW electric in accordance with Yankee's Proposed Change No. 7, dated May 8, 1961.

Distribution

- T. D. Tommer
- M. Baker
- V. A. Morris-2
- A. C. Clark
- Doc. Room
- Formal
- Suppl.
- IB-LER readings GTEdwards
- Enclosure
- Hazards Analysis

Sincerely yours,

Original signed by R.L. Kirk

Deputy

Director
Division of Licensing and Regulation

DLAR
GTEdwards/dk
5/25/61

DLAR
BCCase

DLAR
Director
OGC
w. R. Sturck
5-25-61

8011060 844

P

POOR ORIGINAL