

NUCLEAR REGULATORY COMMISSION

ORIGINAL

COMMISSION MEETING

---

---

In the Matter of: PRESENTATION BY GE, AIF, AND G. LELLOUCHE  
(EPRI) ON ANTICIPATED TRANSIENTS WITHOUT  
SCRAM (ATWS)

---

---

DATE: October 28, 1980 PAGES: 1 - 71  
AT: Washington, D. C.

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8011070 033

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

- - -

Presentation by GE, AIF, and G. Lellouche (EPRI)  
on Anticipated Transients without Scram (ATWS)

- - -

Nuclear Regulatory Commission  
Room 1130  
1717 H Street, N.W.  
Washington, D.C.

Tuesday, October 28, 1980

The Commission met at 2:05 p.m., pursuant to notice.

PRESENT:

John Ahearne, Chairman  
Joseph Hendrie, Commissioner  
Victor Gilinsky, Commissioner  
Peter Bradford, Commissioner

PRESENT FOR THE NRC STAFF:

Samuel Chilk

PRESENT FOR THE OFFICE OF GENERAL COUNSEL:

Leonard Bickwit  
Marty Malsch

- - -

DISCLAIMER

This is an unofficial transcript of a meeting of the United States Nuclear Regulatory Commission held on October 29, 1980 in the Commission's offices at 1717 H Street, N. W., Washington, D. C. The meeting was open to public attendance and observation. This transcript has not been reviewed, corrected, or edited, and it may contain inaccuracies.

The transcript is intended solely for general informational purposes. As provided by 10 CFR 9.103, it is not part of the formal or informal record of decision of the matters discussed. Expressions of opinion in this transcript do not necessarily reflect final determinations or beliefs. No pleading or other paper may be filed with the Commission in any proceeding as the result of or addressed to any statement or argument contained herein, except as the Commission may authorize.

TABLE OF CONTENTS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

PRESENTATION BY:

PAGE

AIF

D. Clark Gibbs, Vice President, Middle South Energy, Inc.; Director, Nuclear Activities (Middle South Services) Chairman, AIF Committee on Reactor Licensing and Safety (accompanied by Dr. A. R. Buhl, Vice President Technology for Energy Corporation; G. C. Sorenson, Chairman, AIF CRLS, Subcommittee on ATWS, Washington Public Power Supply System; F. Stetson, Manager, RL & Safety Projects, AIF.)

3

EPRI

G. S. Lellouche (accompanied by Dr. Ian Wall, EPRI)

35

- - -

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

P R O C E E D I N G S

1  
2 CHAIRMAN AHEARNE: The Commission meets this afternoon  
3 in one of, I gather, very long series of meetings which at some  
4 place I read goes back eleven years, addressing anticipated  
5 transients without scam.

6 In the recent, very recent past on this subject - that  
7 means within the last few months, the Commission did have a  
8 meeting with its staff to hear a briefing on the final staff  
9 proposal on the proposed rule. Prior to that, we had received  
10 several letters from the Atomic Industrial Forum and from General  
11 Electric, requesting the opportunity to participate in a meeting  
12 to present some views. I gather we also received a request from  
13 EPRI.

14 We responded to, on behalf of the Commission, the  
15 Secretary responded to AIF, to EPRI, and to General Electric  
16 saying that we did invite them to an open meeting regarding this  
17 subject. The meeting is today.

18 I gather from the agenda that I have we will be hearing  
19 first from the Atomic Industrial Forum and then second from EPRI.  
20 I will turn it over to you, Clark, and I guess you will introduce  
21 your colleagues and also, I guess, introduce yourself and mention  
22 why General Electric is not here.

23  
24  
25

## PRESENTATION BY AIF

1 D. CLARK GIBBS, VICE PRESIDENT, MIDDLE SOUTH ENERGY INC.;  
2 DIRECTOR, NUCLEAR ACTIVITIES (MIDDLE SOUTH SERVICES);  
3 CHAIRMAN, AIF COMMITTEE ON REACTOR LICENSING AND SAFETY,  
4 (ACCOMPANIED BY D. A. R. BUHL, VICE PRESIDENT, TECHNOLOGY  
5 FOR ENERGY CORPORATION; G. C. SORENSON, CHAIRMAN, AIF CRLS,  
6 SUBCOMMITTEE ON ATWS, WASHINGTON PUBLIC POWER SUPPLY SYSTEM;  
7 F. STETSON, MANAGER, RL & SAFETY PROJECTS, AIF.)

8 MR. GIBBS: Gentlemen, it is an honor and pleasure for  
9 me to be here today. My name is Clark Gibbs. I am director of  
10 Nuclear Activities for Middle South Services and vice president of  
11 Middle South Energy, Inc., the owner of the Grand Gulf Nuclear  
12 Station. I am here today as chairman of the AIF Committee on  
13 Reactor Licensing and Safety. I am also a member of the AIF Policy  
14 Committee on Nuclear Regulation and the EEI Executive Advisory  
15 Committee on Nuclear Power.

16 The statement on ATWS that I shall make before you today  
17 has the endorsement of these AIF and EEI committees as well as the  
18 members of the American Public Power Association's Nuclear Power  
19 Task Force which currently own and operate nuclear power plants on  
20 their systems.

21 I will be reading my prepared presentation to you because  
22 of the organizations which I represent here and the need for their  
23 considered review of my remarks.

24 CHAIRMAN AHEARNE: That reminds me of many items of  
25 testimony I have given before the Congress, joined by my colleagues.

MR. GIBBS: If you have any questions during these pre-  
pared remarks, do not hesitate to interrupt. I am joined here  
today by Fred Stetson of the AIF staff on my far left. On my

1 immediate left is Jerry Sorensen, who is chairman of the AIF ATWS  
2 Subcommittee, and Dr. Anthony Buhl, on my right, who is vice  
3 president of Technology for Energy Corporation, all of whom will  
4 assist in dealing with your questions. Also present are others  
5 from the industry whom I may call upon should the need arise.

6 Both the NRC and the industry are vitally interested in  
7 the safety of nuclear power, largely for the same reasons. Those  
8 of us who advocate continued and expanded use of nuclear power  
9 have grown accustomed to the attention to detail, energy, and  
10 commitment that the assurance of nuclear safety requires.

11 We well understand the potential consequences of errors  
12 in judgment on public acceptance, unit availability, and cost  
13 comparisons with alternatives. Those of us who are owners of these  
14 plants are keenly aware of the importance that our ratepayers who  
15 live in the environs of our plants, attach to nuclear safety. We  
16 have not failed to observe as well the hideous financial impact  
17 attendant with an event which compromises our ability to provide  
18 adequate cooling for the reactor core. We have every reason to be  
19 the most committed to nuclear safety of any organization partici-  
20 pating in its use.

21 It is from that perspective which we view the ATWS  
22 issue, one which has confounded over ten years of attempted  
23 resolutions. We believe that the underlying reason for the  
24 inordinate length of time and effort that has already been expended  
25 on this subject, and which has frequently been spiced with acerbic

1 dialog is that it is an unprecedented attempt to provide pro-  
2 tection for a single extremely small probability event, from among  
3 a host of others which may have a greater probability of occurrence  
4 and for which the consequences are likely to be more severe.

5 We wish to enhance as necessary the safety and operability  
6 of our plants in a fashion which is self consistent, and objectively  
7 allocates our resources toward the achievement of a well-understood  
8 safety goal based upon a firm foundation of analysis of benefits  
9 and competing societal risks. In fact, it appears to us that the  
10 treatment of this subject by the NRC staff has been clearly over-  
11 taken by the events which have occurred since the accident at  
12 Three Mile Island.

13 The specific events to which I allude are the renewed  
14 interest in the establishment of quantitative safety goals, the  
15 ongoing and planned probabilistic assessment studies and the  
16 planned degraded core rulemaking. It is from these activities  
17 that we propose that the ultimate resolution of ATWS be derived.

18 In the interest of expanding upon this proposal, we  
19 suggest that the first prerequisite for a final ATWS resolution  
20 is the definition of a safety goal for nuclear plant regulation.  
21 The optimum ATWS resolution involves the reduction of risks that  
22 are already very small. Since it is impossible to reduce risks to  
23 zero, we continue to be confronted with the question, "How safe is  
24 safe enough?"

25 Although, of necessity, the lack of a safety goal has not



1 precluded rulemaking in the past, it would be unwise to ignore  
2 safety goal guidance that should soon be available. Recent  
3 recognition that such guidance is essential suggests that it will  
4 be available in time to guide a final ATWS resolution.

5 CHAIRMAN AHEARNE: Clark, at this stage, are you speaking  
6 of a program we have under way that develops the safety goals, or  
7 are you speaking of something else?

8 MR. GIBBS: I am speaking of both that, and also I am  
9 hopeful that that process will enjoy the interaction with the  
10 industry in the evolution of the ultimate safety goals.

11 CHAIRMAN AHEARNE: Well, that process does involve inter-  
12 action with all elements of the affected public, industry, etc.  
13 I wondered whether you had something separate in mind.

14 MR. GIBBS: No, sir; I do not believe I have anything  
15 separate in mind. I will say more to that as I proceed.

16 I should point out at this juncture that the AIF Committee  
17 on Reactor Licensing and Safety has recently come forward with a  
18 proposed safety goal before the ACRS which has received support  
19 within the industry.

20 A second prerequisite for a final ATWS resolution is  
21 further work on probabilistic risk assessment analysis. The last  
22 comprehensive PRA - which is the term I will use to refer to  
23 probabilistic risk assessment - which has been performed and widely  
24 circulated, and which treats ATWS among all the other events that  
25 can lead to degraded core cooling conditions was WASH-1400. That

1 study suggested that the risk from ATWS events in LWR's was small.  
2 Other NRC studies such as the four volumes of NUREG 0460 have  
3 treated ATWS in greater detail than WASH-1400 but have done so in  
4 isolation or have compared a revised ATWS risk with unmodified  
5 WASH-1400 values for competing risks.

6 This is clearly inappropriate and particularly so in  
7 view of the significant work underway and planned to expand the  
8 base of our knowledge in the area of PRA. Within the industry a  
9 growing number of PRA evaluations are scheduled for completion  
10 in the near future that will provide insights on ATWS.

11 The third prerequisite for final ATWS resolution is the  
12 integration of ATWS into the planned degraded core rulemaking.  
13 This rulemaking will determine whether and to what extent degraded  
14 core or core melt accidents must be considered in safety analyses.  
15 The end result of this process may be a rule that will amend  
16 10 CFR 50 to require changes in plant design or procedures that  
17 will improve the capability of light water reactors to prevent,  
18 respond to, or accomodate the effects of accidents resulting in a  
19 degraded reactor core.

20 As noted above, the industry does not believe that final  
21 ATWS resolution can be achieved independent of the degraded core  
22 rulemaking. A systematic safety evaluation of a nuclear power  
23 plant should consider all the sequences and suggested modifications  
24 in perspective. In this manner we can direct our attention and  
25 resources to the dominant sequences that impact safety as well as

1 to events that could result in other severe consequences.

2 COMMISSIONER GILINSKY: Did you really mean it when you  
3 said to interrupt you if we have questions?

4 MR. GIBBS: Yes, sir.

5 COMMISSIONER GILINSKY: What I am wondering is, what  
6 singles ATWS out here? It seems to me the things brought forward  
7 would apply to any number of other safety issues. It seems the  
8 suggestion that we ought not to move forward on these until we  
9 straighten out our philosophical framework, the safety goal, and  
10 a whole bunch of other things.

11 Is there something about ATWS that singles it out?

12 MR. GIBBS: No, sir. That is exactly the point. The  
13 risk associated with ATWS is one of degraded core. What we are  
14 suggesting here is that it be treated as such, along with the  
15 other scenarios which can lead to degraded core.

16 Because the same issues and facts are crucial to each,  
17 that is each of the potential degraded core scenarios, ATWS is  
18 simply a sub part of the degraded core matter; we recognize that  
19 the risk of ATWS, to the extent that there is any significant risk,  
20 is one of degraded core.

21 We recognize that ATWC is one relatively low-probability  
22 event among many that could conceivably lead to a degraded reactor  
23 core. Accordingly, there seems to be no sound reason for seeking  
24 final ATWS solutions for plants in isolation from other degraded  
25 core events.

1           We would prefer to avoid continued dialog on ATWS  
2 independently, and therefore propose the matter be disposed of now  
3 in a fashion which is supported by the record and which results in  
4 a substantial reduction of the ATWS risk. The stage has been set  
5 to treat the residual ATWS risk in the degraded core rulemaking  
6 in a fashion which will be acceptable to the industry and in  
7 particular to the owners of these plants.

8           There remains the question of what can and should be done  
9 now. The staff has recently proposed an ATWS rule and regulatory  
10 guide contained in SECY-80-409. You have also been served with a  
11 petition for rulemaking by the ATWS Utility Group representing  
12 20 domestic electric utility companies. The two proposed rules  
13 are quite similar insofar as specific short term hardware require-  
14 ments are concerned. Beyond that, they diverge. In the longer  
15 term, the staff proposes to specify criteria rather than mitigating  
16 hardware.

17           We believe this is a significant positive step and that  
18 a final rule which may evolve as a product of the degraded core  
19 rulemaking should rightfully address itself to criteria rather  
20 than hardware.

21           However, the proposed criteria are premature and as a  
22 result deficient. In our judgment, the staff proposals do not  
23 provide closure of the ATWS issue. The proposed regulatory guide  
24 will afford the staff unrestricted opportunities for imposing  
25 further regulatory requirements which will inevitably result in

1 ATWS becoming a design basis event for structures, systems, and  
2 components with implication far beyond that of which any of us  
3 today are capable of imagining. The appearance of a new design  
4 basis event virtually guarantees substantial impacts on the re-  
5 sources of both the NRC and industry for many years in the future.

6 The proposed integral plant and separate effects testing  
7 identified in the Regulatory Guide are briefly outlined as to  
8 purpose only. There is no way of intelligently evaluating what  
9 is expected of us from these purpose statements and certainly not  
10 in the time allowed for in the schedule which I will address  
11 later.

12 Further, the appearance of these tests is additional  
13 evidence that the staff is moving in the direction of treating  
14 ATWS as a design basis event after the fashion of the design basis  
15 loss of coolant accident, a practice which led to some of the  
16 unfavorable findings of those charged with the task of evaluating  
17 NRC's performance following the Three Mile Island accident.

18 The staff proposals are particularly deficient in the  
19 associated value-impact analyses, proposed schedule for imple-  
20 mentation, and attention to detail where contradictions clearly  
21 exist in the record.

22 COMMISSIONER GILINSKY: Can I go back to the greater  
23 core rulemaking? There, it seems to me, the question is how  
24 much further should we go beyond the historic regulatory program  
25 in considering situations in which a core is in fact degraded

1 and we might in fact want to take further steps to mitigate  
2 consequences, deal with hydrogen evolution, or whatever.

3 MR. GIBBS: Or to what extent preventive measures should  
4 be also incorporated or augmented to prevent degrading the core in  
5 the first place.

6 COMMISSIONER GILINSKY: I was going to get to that.  
7 It seems to me we have always tried to keep degraded cores from  
8 occurring in the first place. The element that the rulemaking  
9 would add - if we decide to make changes in our program - is a  
10 step beyond that envelope within which we have worked.

11 MR. GIBBS: Yes, sir.

12 COMMISSIONER GILINSKY: So, I guess I do not follow your  
13 logic in saying that we ought not to be trying to prevent cores  
14 from getting damaged, or take steps to prevent it, until we have  
15 been through that rulemaking. It seems to me that deals with  
16 questions that go beyond the ones we are talking about here in  
17 ATWS.

18 MR. GIBBS: No, sir, I don't believe so. As I conclude  
19 this statement, you will see that I am suggesting that we go ahead  
20 with certain measures which can offer preventive features with  
21 respect to degraded core matter. Our concerns are multi-faceted.  
22 Many of our concerns are that the fixes which may evolve as a  
23 result of the application of these criteria may result in fact in  
24 the reactor plant becoming less safe than it currently is; or in  
25 safety being degraded. We feel that these matters are sufficiently

1 complex that they warrant further study.

2 Now, to the extent that there does exist risk associated  
3 with ATWS, that risk is all degraded core. Even after fixes are  
4 incorporated in these plans, there still will remain some residual  
5 risk which, we are suggesting, be bolted into the hopper of  
6 degraded core.

7 COMMISSIONER GILINSKY: When you say the risks come  
8 from the core being damaged, or degraded core, all risks connected  
9 with reactors come from the core being damaged and degraded, the  
10 integrity of the core not being maintained.

11 I guess I just don't follow your argument here. Am I  
12 missing something?

13 MR. GIBBS: That is a true statement, all risks ulti-  
14 mately arise in degraded cores, ultimately.

15 COMMISSIONER GILINSKY: But you seem to be saying that  
16 we ought not to do anything until we have been through this  
17 rulemaking.

18 MR. GIBBS: I am not saying that we ought not to do  
19 anything.

20 COMMISSIONER GILINSKY: The implication that I drew  
21 from this, that we ought not really to go forward not only in  
22 ATWS but on other fronts as well because the argument seems to  
23 apply there, too. I don't mean to derail you here from your  
24 presentation, but what I am grasping for is, what is is about  
25 ATWS that leads you to think that it ought to be handled differently

1 than other parts of our concerns?

2 MR. GIBBS: I think Dr. Buhl should perhaps expand a  
3 little bit on this because apparently I am not communicating  
4 completely with you.

5 But ATWS has traditionally always been included, for  
6 example, in the WASH-1400 analyses as one of the events which can  
7 lead to a degraded core, which in turn can lead to risk to the  
8 public, both individual and population dose risk.

9 COMMISSIONER GILINSKY: Right.

10 MR. GIBBS: It is one of those events.

11 COMMISSIONER GILINSKY: Why don't you go on? I think  
12 it will sort itself out, maybe I am just missing something.

13 MR. GIBBS: Dr. Buhl?

14 DR. BUHL: Just to add a comment, I think ATWS is one  
15 of many sequences which, if you look at the dominant sequences  
16 in WASH-1400 for PWR, BWR. What we are saying is, there are  
17 certain things that one should do, and Dr. Gibbs will be proposing  
18 some of those in a few moments.

19 But our concern on the other hand is that if one looks  
20 at one accident sequence such as ATWS in the abstract, which is  
21 very easy to do, one might go too far, so to speak; that is, one  
22 might make a correction or at least a modification which he  
23 perceives to be a correction to reduce the ATWS risk and at the  
24 same time substantially increase the risk from these other  
25 accident sequences. So, I think the argument is that insofar as



1 public risk is concerned, once you take a wholistic look and be  
2 very careful about dealing with ATWS or any other specific  
3 accident sequence, for that matter, in the abstract.

4 COMMISSIONER GILINSKY: Well, it is pretty hard to argue  
5 with the proposition that we ought to look at these things and  
6 be sure when we fix one thing we do not make some other things  
7 worse. But we were just discussing the action plan this morning,  
8 and there are any number of fixes that we are putting in place  
9 to deal with one or another sequence that we are concerned about.

10 It would seem to me that if there is a real problem here,  
11 we ought to be dealing with it. Of course, at the same time  
12 stepping back a bit, to make sure that we are not fouling up the  
13 rest of the system.

14 But you have tied your argument somehow to this degraded  
15 core rulemaking and I just don't see any particular connection.

16 MR. GIBBS: Sir, the connection is, I believe, that  
17 regardless what one does with his plant to deal with ATWS, there  
18 will remain some residual risk.

19 Some of these things he does can offer competition from  
20 other event sequences which can also lead to degraded core  
21 situations. The subject is very sophisticated and very detailed,  
22 and there is a great deal of system interrelationship involved  
23 which all deserve more attention than they have received. All of  
24 them, ultimately, lead to, when taking the worst path along the  
25 "event trees" degraded core conditions.

1 We believe that once the modifications have been made  
2 that we are suggesting here today in these plans, that it would be  
3 appropriate to deal with that residual in the degraded core  
4 rulemaking.

5 COMMISSIONER GILINSKY: Maybe it will become clearer as  
6 you go on.

7 MR. GIBBS: Beginning with value-impact, the Nuclear  
8 Regulatory Commission has adopted a policy, "That value-impact  
9 analysis will be conducted for any proposed regulatory actions  
10 that might impose a significant burden on the public (where the  
11 term public is defined in its broadest sense)." Consistent  
12 with this policy, the NRC staff has attempted to develop the  
13 required value-impact analysis for ATWS.

14 The staff's effort to date, however, has not been  
15 adequate. The major defects include first, failure to realisti-  
16 cally consider the consumer impacts associated with major backfits  
17 and extended outages that will increase the cost of electric  
18 power.

19 The staff reports in SECY-80-409 that it is their  
20 judgment that extended downtime required to retrofit will likely  
21 be minimal. In view of the apparent need to provide additional  
22 relief valve capacity to meet the acceptance criteria of the  
23 proposed rule in Babcock & Wilcox and Combustion designed plants,  
24 this statement is profoundly in error.

25 A recent study performed at Duke Power Company indi-

1 cates that a minimum of 31 days of additional down time would be  
2 required to make the pressurizer modification on Oconee necessary  
3 to provide the additional relief protection mandated by the  
4 acceptance criteria, assuming absolutely no problems - a most  
5 unlikely assumption.

6           The study further estimates that this unavailability would  
7 be likely to grow to 65 days if expected problems manifest them-  
8 selves, such as difficulty in removing the pressurizer manway, or  
9 repair of indications on the nozzle welds. Approximately 360 man-  
10 rem of occupational exposure would be involved on each unit. Using  
11 \$2,000 per occupational man-rem and \$200,000 per day per unit  
12 cost of replacement power, which for Duke is nearly all coal, they  
13 estimate a \$25 million impact on their three Oconee units exclusive  
14 of engineering and equipment costs.

15           It is important to point out that Oconee operation has  
16 been relatively free of fuel failures and their resultant exposures  
17 will be considerably below the average when plants which have  
18 experienced operation with failed fuel are taken into account.

19           In addition, the Oconee containment is relatively  
20 uncongested, minimizing the interference problem which will be  
21 experienced by others. Many other utilities will be required to  
22 use oil as a replacement fuel. It is therefore judged that the  
23 Duke estimates probably represent a lower bound on the cost of  
24 this single modification to the CE and B&W designed reactors.

25           Because of the sensitivity of this analysis to cost of

1 replacement power and outage time, the ultimate relative impact  
2 to some utilities may be a factor of five or more greater than  
3 that suggested by the Duke study.

4 Another consideration is that the full implementation of  
5 the NRC-proposed resolution may also reduce system availability  
6 and reliability by making nuclear plants more complex and  
7 therefore more subject to malfunction when events such as inad-  
8 vertent initiation of the automatic stand-by liquid control  
9 system are taken into account.

10 CHAIRMAN AHEARNE: was it that aspect you were referring  
11 to earlier when you mentioned it could reduce safety?

12 MR. GIBBS: No, sir. This event could contribute, but  
13 it is unlikely because there are other events. For example, it  
14 is being proposed that an automatic feed-water runback be  
15 incorporated on boiling water reactors. Inadvertent initiation of  
16 that feature challenges the RHR system. If that challenge  
17 occurs once per plant in its lifetime, the risk associated with  
18 failure of that RHR system, has been reported to me, is about  
19 equal to the decrease in risk that one achieves by full imple-  
20 mentation of the ATWS fixes.

21 A second deficiency in the value-impact analysis is  
22 the failure to consider the increased risks from accidents other  
23 than ATWS that would be imposed by certain of the staff's alterna-  
24 tives.

25 Third, the value-impact information contained in

1 SECY-80-409 is nearly impossible to follow or understand. Dis-  
2 cussions of value-impact estimates are contained in Enclosures B,  
3 F, and H of the document. These discussions are disjointed and  
4 confusing, referring to one or more different volumes of NUREG 0460  
5 with various designations for the proposed fixes and contain un-  
6 founded and excessive dollar values for man-rem exposure. Further,  
7 the details of the modifications assumed as the basis for the  
8 impact estimates are not stated.

9 Fourth, the failure to recognize that few ATWS events  
10 have the potential of leading to severe ATWS consequences, that  
11 a limited set of severe ATWS events would result in major core  
12 degradation, and that not all major core degradations exceed  
13 10 CFR 100 guidelines further results in the values being sig-  
14 nificantly overestimated and is not appropriate for value-impact  
15 analysis.

16 Turning now to the schedule proposed in SECY-80-409,  
17 it is safe to assert that it is unachievable and unjustified in  
18 view of the number of issues that remain open. We are being  
19 asked to submit evaluation models and plans for confirmatory  
20 testing by March 1, 1981, and to propose necessary modifications  
21 to meet the criteria by July 1, 1981.

22 It is clear that such a schedule allows no time to do  
23 anything other than fall back to the prescribed hardware "fixes"  
24 so much in evidence in NUREG-0460 Volume 4. If criteria similar  
25 to those presented in the proposed rule are ultimately determined

1 to be necessary, substantially more time will be required to test  
2 alternative solutions, perform the detailed engineering, and perform  
3 the necessary reliability analyses to give us confidence that we  
4 are not "fixing" our plants in a fashion that will degrade rather than  
5 than enhance safety. Again, we need more experience with PRA  
6 methodology and implementation acquired on base studies before we  
7 begin to apply its results to making modifications to our plants.

8 The schedule further requires that boiling water reactor  
9 modifications required to meet the acceptance criteria be complete  
10 by July 1, 1982. On the basis of a proposal I have received from  
11 the affected vendor in this case, I know this to be unachievable.

12 We expect the same to apply to the PWRs. Finally, the  
13 significant pressure boundary work that may be required on the  
14 affected PWRs is to be complete by January 1, 1984. Should  
15 pressure boundary backfitting in fact be required, there is a  
16 time for doing that, and it is during the ten-year in-service  
17 inspection. Reserving any such modifications for that inspection  
18 availability will substantially reduce the impact to the ratepayer  
19 from nuclear plant down time.

20 Our problems with the achievability of the schedule are  
21 not limited to the plants which now have or expect operating  
22 licenses by January 1, 1984. For example, using the proposed  
23 schedule, the applicant for a nuclear unit expecting to receive  
24 an operating license in January, 1984, should have submitted  
25 proposals for complying with the recently announced criteria in

1 January, 1979.

2 We see no reason for including detailed implementation  
3 schedules in rules and suggest that such a practice not be  
4 continued here. The staff certainly has at their disposal  
5 alternatives to the establishment of such schedules short of  
6 including them in the rules.

7 Another major deficiency concerns the question of the  
8 staff's lack of attention to technical detail. A major portion  
9 of industry perceives the staff's "engineering judgment" in this  
10 area to be deficient. For example, the staff assumes that all  
11 ATWS events that could lead to a core melt will exceed 10 CFR 100  
12 limits. These assumptions are overly conservative.

13 They ignore the fact that exceeding stress level C  
14 requirements or exceeding an arbitrary temperature limit in a  
15 boiling water reactor torus does not necessarily lead to core  
16 melt, and core melt does not necessarily lead to violation of  
17 containment integrity or to exceeding the 10 CFR 100 limits.

18 They have not taken into account any operator action  
19 which, for such an event, would be a certainty. They overestimate  
20 the number of significant events because (A) below a certain  
21 power level, the consequences of an ATWS are not significant;  
22 (B) many anticipated transients when combined with a failure to  
23 scram do not lead to bounding consequences; (C) the consequences  
24 are a function of time in cycle; (D) not all ATWS events will  
25 necessarily cause a complete failure of the reactor shutdown

1 system; (E) an ATWS event need not necessarily cause a failure of  
2 the reactor control system; and (F) as the experience level rises  
3 with added years of operation, the number of significant events  
4 falls for certain categories of initiating events as a result of  
5 the learning curve.

6 The staff has not treated in appropriate detail evidence  
7 that some of the measures that have been recommended to decrease  
8 the ATWS risk may, in fact, increase competing risks, thus  
9 lowering overall safety. The example that I cited is one.

10 CHAIRMAN AHEARNE: Evidence, I assume, carries with  
11 it some detailed analysis or actual case histories, as opposed to  
12 the hypothesis.

13 MR. GIBBS: Well, many of these analyses have been  
14 performed, and many of them have been submitted to the staff.

15 CHAIRMAN AHEARNE: That is what you meant by it.

16 MR. GIBBS: Yes. There is also an increasing data  
17 base of this evidence by virtue of studies that are currently  
18 under way in this area.

19 Approximately 20 utilities representing about 60 plants  
20 have proposed a solution recently in the form of a petition for  
21 rulemaking on ATWS. Part 1 of the petition proposes modifications  
22 that are straight-forward and well understood by the industry and  
23 the NRC staff. Thus, these modifications will not require  
24 great expenditures of resources for technical analysis, and they  
25 can be implemented quickly. Because a substantial portion of the



1 industry is already willing to make these modifications if they  
2 will resolve the ATWS issue for existing plants, there is not likely  
3 to be much regulatory effort required to impose them. Most important  
4 of all, the proposed modifications clearly decrease the risk of  
5 ATWS while minimizing other, competing risks.

6 COMMISSIONER GILINSKY: Since you put the industry's  
7 willingness to make these modifications in terms of NRC's willing-  
8 ness to call it quits, does that mean that you do not really think  
9 even these are needed?

10 MR. GIBBS: I think that certainly there are elements  
11 within the industry who do not think these are needed or useful.  
12 I think the vast majority of the industry would be willing to go  
13 along with modifications such as those that I am about to propose  
14 if this dialog is brought to a close.

15 COMMISSIONER GILINSKY: It does not sound like something  
16 you want to do on your own.

17 MR. GIBBS: I do not view the prospect with a great deal  
18 of enthusiasm, no, sir.

19 In addition, the petition proposes that if the Commission  
20 elects to propose ATWS modifications beyond those in Part 1 of the  
21 petition, then all concerned will find themselves in a morass of  
22 unanswered questions demanding immediate answers and excessive  
23 NRC and industry manpower requirements.

24 Chief among these questions will be whether the  
25 additional potential modifications, if implemented, would leave the

1 public more safe or less safe. The petitioners indicate that  
2 nothing short of an ATWS rulemaking involving adjudicatory pro-  
3 cedures could provide the answer. The petitioners urge that such  
4 a rulemaking be held if ATWS modifications beyond those in Part 1  
5 of the petition are, in fact, to be considered now.

6 We feel that such action coming at this time on this  
7 event would be unwise and counterproductive. Doing so would be  
8 an attempt to provide the ultimate resolution of ATWS in isolation  
9 from all other degraded core scenarios. One of the first lessons  
10 learned from Three Mile Island was that NRC and the industry  
11 had concentrated too much on low probability events. We should  
12 not forget this lesson in our efforts to improve the safety of our  
13 plants.

14 In conclusion, the organizations that I represent here  
15 today hereby recommend the following:

16 1. That the staff proposed acceptance criteria for  
17 analysis of ATWS mitigation capability although well intended, are  
18 premature and should not be adopted at this time.

19 2. That the Commission accept the utilities' proposal  
20 contained in Part 1 of the ATWS Utility Group petition. Doing so  
21 will reduce the risk associated with ATWS by at least 50 percent.

22 3. That a decision on whether additional risk  
23 reduction is appropriate await the establishment of a safety goal  
24 and the insights to be gained in the near future from the several  
25 on-going probabilistic risk assessment evaluations.

1           4. That as a result of the above, the unresolved safety  
2 issue on ATWS be closed now, and any residual risk be treated in  
3 the degraded core rulemaking.

4           CHAIRMAN AHEARNE: Thank you, Clark. Do any of your  
5 colleagues wish to add remarks?

6           Now, do you also represent General Electric?

7           MR. CHILK: It is my understanding that General Electric  
8 joined with AIF.

9           MR. GIBBS: General Electric is a member of AIS, sir.  
10 They had representatives on our committees, including my Steering  
11 Group on Reactor Licensing and Safety. They called me last week,  
12 as I recall, and indicated their intent not to participate, that  
13 they felt they were getting adequately represented by this paper.

14          CHAIRMAN AHEARNE: All right, thank you.

15          COMMISSIONER HENDRIE: Would you contrast the hardware  
16 changes that are proposed in the industry petition with the  
17 staff's what I call two-way, or basic short-term modifications?

18          MR. GIBBS: Yes, sir, if you will bear with me a moment.

19          Appendix D of SECY-80-409 contains a discussion of  
20 alternatives. The ATWS Utility Group proposal begins at page 6  
21 of the petition for rulemaking.

22          In the case of the boiling water reactors, to begin  
23 with them, alternative 2(a) contained in SECY-80-409 contains  
24 an ATWS rod injection system which is also present in the petition.  
25 It contains a scram discharge volume modification. There are

1 minor differences between the staff proposal and the industry  
2 proposal; but they are both treated.

3 It contains a recirculation pump trip which is also a  
4 utility petition.

5 There are two items which it also contains that are  
6 missing from the utility petition. One is logic changes to lower  
7 the low water level set point for initiation of containment  
8 isolation. That appears to me to be a minor matter.

9 COMMISSIONER HENDRIE: Low water set point where?

10 MR. GIBBS: On the reactor level. The reactor level  
11 trip set point for initiating containment isolation. The staff is  
12 proposing that that level be lowered in order to reduce MSIB  
13 closure ATWS type events. Now, the petition is silent on that.  
14 My understanding of that is that that is a relatively minor  
15 affair. However, it should be nonetheless looked at through a  
16 PRA-type analysis.

17 The only significant distinction between the staff  
18 proposal and the petition is, the petition does not contain any  
19 requirement for feedwater logic, feedwater runback. Now, that  
20 is the distinction.

21 COMMISSIONER HENDRIE: Between BWRs?

22 MR. GIBBS: For BWRs, yes, sir.

23 Now, in the case of the PWRs, first the Babcock & Wilcox  
24 and Combustion design plant. The staff proposal contains an  
25 AMSAC(?) which is present in the petition -- excuse me, the AMSAC

1 which is defined in the petition is limited to an automatic  
2 initiation of auxiliary feedwater independent of the reactor  
3 protective system, whereas the staff proposal is more general.

4 The staff proposes an alternate rod injection system,  
5 as it is called, a supplementary protective system in the staff  
6 proposal, which is also present in the petition.

7 The staff also proposes analysis. The petition is  
8 silent on that.

9 With respect to the Westinghouse plants, the staff  
10 proposal includes a back-up scram system which is missing from  
11 the petition. The staff also includes an AMSAC, the petition only  
12 refers to automatic feedwater, auxiliary feedwater initiation.

13 So, those are distinctions insofar as the short-term  
14 requirements are concerned.

15 It is my belief that with the single exception of the  
16 feedwater runback on the boilers those distinctions are minor.

17 CHAIRMAN AHEARNE: Any questions?

18 COMMISSIONER HENDRIE: I guess not a question, more  
19 a comment. The reason this has gone on for so many years is  
20 that we rage back and forth over the argument as to what the  
21 probability of a serious ATWS in that might be, and whether that  
22 probability lies low enough so that one might be willing to  
23 regard it as an acceptable part of the inevitable residual risk,  
24 or whether it is high enough to require some specific design  
25 features, operating practices or what have you, to deal with it,

1 either by way of prevention or by way of mitigation, or both.

2 We have hammered back and forth across that argument  
3 since 1969. It continues to be at the root of the disagreements  
4 over whether specific ATWS measures are required or not. I  
5 comment that I suspect the reason for having an enunciated  
6 quantitative safety goal seems such an attractive proposition  
7 to the other side of the table before a final ATWS solution  
8 comes is just that it looks as though ATWS probabilities as  
9 evaluated by the assorted parties lie in the general neighborhood of  
10 where a quantitative safety goal might come out - probably with  
11 the uncertainty or the spread on those estimates running to either  
12 side of a reasonable safety goal.

13 So, depending on which side you are calculating from  
14 and so on, why, you either believe that whether or not you have  
15 an enunciated safety goal or not, you ought to do something about  
16 it. If you come at it from the other way, why, your belief  
17 might very well be that a reasonable safety goal, compared with  
18 ATWS probabilities, would show that nothing specific is required.

19 Since there has been a long history and a lot of people  
20 over various times have tried their hands on this, I doubt that  
21 these disagreements are apt to go away.

22 Well, let me stop there.

23 MR. GIBBS: Commissioner Hendrie, I wonder if I can  
24 make a comment.

25 CHAIRMAN AHEARNE: Sure.

1 MR. GIBBS: I don't believe, first, that one of the  
2 features of the safety goal which we expect to see emerge is  
3 individual risk criteria. My committee has suggested to the ACRS  
4 that the value that you can assign to that criteria should be  
5 tendered a minus five, and that is per year for the maximally  
6 exposed individual.

7 We do not believe that the individual risk from ATWS  
8 to the maximum exposed individual be anywhere near ten to the minus  
9 five. We believe it will be significantly less than that.

10 COMMISSIONER GILINSKY: Ten to the minus five what?

11 MR. GIBBS: Ten to the minus five per year for the  
12 maximally exposed individual.

13 COMMISSIONER HENDRIE: Ten to the minus five per  
14 reactor year chance of what serious radiation exposure, immediate,  
15 long term?

16 MR. GIBBS: Immediate. We fold the long term in with  
17 another part of the safety goal recommendation, which is the  
18 population dose criteria which is, I don't believe, at issue on  
19 this particular event, although it may well become an issue.

20 We don't believe that we are close to that criteria. In  
21 fact, we don't believe that, regardless of what criteria emerges,  
22 that when it is phrased in that context, i.e., the risk to the  
23 public, that the contribution from ATWS will be even close. We  
24 believe that other degraded core events in areas will dominate.

25 And the bottom line is, we don't know. We have to find

1 that out. We do believe that the modifications that we are pro-  
2 posing here caused the risk to be sufficiently reduced in a WASH-  
3 1400 context that it is essentially in the background.

4 COMMISSIONER GILINSKY: How well do you think we know  
5 these risk probabilities?

6 MR. GIBBS: I don't think we know them well enough. I  
7 think that we have a decent understanding of them. But I don't  
8 know them well enough. I think that we will know them much,  
9 much better two or three years from now than we know them today.

10 COMMISSIONER GILINSKY: Well, that argues both ways,  
11 it seems to me. You may decide since you don't have a real firm  
12 grip on the numbers, you may just decide to follow a kind of  
13 common-sense approach and protect against certain contingencies  
14 whether the number is exactly right or not, simply because these  
15 are important possibilities.

16 MR. GIBBS: Yes, sir, I agree, that is an accurate  
17 statement.

18 The reason for my confidence, however, in response to  
19 Commissioner Hendrie's statement, is that the staff's estimates -  
20 of any group that I would expect to make conservative estimates  
21 with respect to these risks, I would expect them to come from  
22 the staff. The staff estimates that the risk from ATWS is  
23 something like eight times ten to minus five, as I recall. That  
24 is the number that they used to go into their value-impact  
25 analysis.



1           What I am proposing here will reduce that risk by a factor  
2 of at least two on the most affected plants, and that will be  
3 confined only to the plants of two vendors. Then, in addition to  
4 that, I pointed out there are a number of options available to  
5 the operator for further reducing that risk. There are a number  
6 of actions that are obvious, that he can take.

7           Then, on top of that, one has to concern himself not  
8 with what is the probability of this severe ATWS event having  
9 occurred, but what is the impact to that maximally exposed  
10 individual on the site boundary, and that is the parameter which  
11 appears to us to be of greatest interest. We believe that is  
12 substantially less, that there will be a very small number which  
13 will be multiplied by whatever the residual risk of a severe ATWS  
14 is, to calculate what the risk to that maximally exposed individual  
15 will be.

16           COMMISSIONER GILINSKY: What is your reaction to the  
17 Brown's Ferry the chairman mentioned earlier, it has not  
18 come up so far.

19           MR. GIBBS: Yes, sir, I think that is an event which  
20 deserves some mention here. First, there was no anticipated  
21 transient. Second, less than half of the control rods were  
22 affected. Third, those control rods which were affected went  
23 in part way; and fourth, operator action was successful in  
24 getting them in the remainder of the way.

25           There were a host of other options that the operator

1 had at his disposal, that he could have used to further mitigate  
2 the consequences of that thing, that he was not obligated to use.  
3 He went to his first line of defense, which was the shut-down  
4 system, and ultimately was successful in getting the rods in.

5 Now, that event is part of the learning process. By  
6 going through that process we have eliminated one more source  
7 of common mode failure. I think we should fix those things. But  
8 I don't think that we should chastize ourselves or flagellate  
9 ourselves as a result of having experienced that incident. I  
10 think that it was a learning process, and it was far removed from  
11 the classical ATWS which is all rods stuck out at a hundred  
12 percent power following an anticipated transient, and no ability  
13 to get them in.

14 COMMISSIONER GILINSKY: But still, that is another one  
15 of those things that cuts both ways. Sure, we want to learn from  
16 it and it is inevitable that we will find things we have not  
17 expected and that is the way, in fact, that you improve the  
18 system.

19 But it is also true, so far as I can tell, this is a  
20 common mode failure that was not foreseen and was sort of  
21 surprising. In this area and other areas we would come across  
22 things like that which suggest that maybe we ought to be a little  
23 more cautious. That is really what is involved here.

24 MR. GIBBS: Commissioner Gilinsky, that is precisely  
25 what I am proposing, that we be more cautious because on the

1 other side of the fence, if we are careless with respect to what  
2 we do to these plants, to address these very low risk accidents,  
3 we can wind up with a plant on which the safety has been diminished  
4 by virtue of those actions.

5 COMMISSIONER GILINSKY: Well, we certainly don't want  
6 that.

7 MR. GIBBS: No, sir. I certainly don't want one as  
8 a representative of an owner.

9 COMMISSIONER GILINSKY: Let me ask you something else,  
10 you mentioned the recirculating pump trip as something you would  
11 propose - I guess it is required now and needs to be completed.

12 MR. GIBBS: Yes.

13 COMMISSIONER GILINSKY: I don't know when the date is.

14 MR. GIBBS: By the end of the year, sir.

15 COMMISSIONER GILINSKY: By the end of the year. Why  
16 was this so long in coming, is this something we have known about  
17 for a long time and yet, I gather, it has only been recently that  
18 clients have effected these changes.

19 MR. GIBBS: Sir, I don't know that I can give you a  
20 great deal of history on that. Although, if I consider what  
21 my reaction might have been when first confronted with the idea,  
22 it would have occurred to me that, gee, is it really a good idea  
23 to turn off your cooling flow immediately following a transient,  
24 which is effectively what you are doing with the recirculating  
25 pump trip. That may have been the cause of it.

1 Jerry or Fred, can you offer anything further on that?

2 COMMISSIONER GILINSKY: My impression is, you don't have  
3 much time to work with in the event of an ATWS if the pumps are  
4 not turned off.

5 MR. GIBBS: That appears to be the case, yes, sir.

6 MR. SORENSON: I think there has been some good information  
7 provided in that regard by Commonwealth Edison in some of their  
8 presentations previously to the ACRS regarding ATWS. I don't  
9 recall the details, but I think that might be something worth  
10 bringing back out and providing the Commission.

11 CHAIRMAN AHEARNE: I guess our time is almost up in this  
12 section. I just want to ask you a question in the statement in  
13 here, since I gather you associate yourself with the remarks.

14 MR. GIBBS: Yes.

15 CHAIRMAN AHEARNE: On page 2, at the bottom, let me  
16 drop out a word which is a "may" which is a qualifier. This is  
17 now talking about ATWS. "From among a host of others which" -  
18 I am going to drop out the "may" - "which have a greater proba-  
19 bility of occurrence and for which the consequences are likely to  
20 be more severe." Is the "may" there essential?

21 DR. BUHL: I think the "may" is there because if you  
22 look in Appendix 5 of WASH-1400 for the PWRs and the BWRs, you  
23 can find those other sequences and simply see the numbers. In  
24 fact, I have done that. When you look at those numbers there  
25 for the PWR, they are comparable for a dozen sequences, or so;

1 and for the BRW the heat removal sequence is also comparable. In  
2 my view, they are comparable. So, that is what we are saying.

3 CHAIRMAN AHEARNE: So, there are other sequences which  
4 have a comparable probability.

5 DR. BUHL: Yes, sir. The numbers are in those tables.

6 CHAIRMAN AHEARNE: Clark, do you have anything else you  
7 want to add?

8 MR. GIBBS: No, sir.

9 CHAIRMAN AHEARNE: Thank you.

10 MR. GIBBS: Thank you.

11 CHAIRMAN AHEARNE: The next presentation is from  
12 EPRI. Dr. Lellouche, the forum is yours, sir.

13 MR. LELLOUCHE: Thank you, sir.

14

15

16

17

18

19

20

21

22

23

24

25

## PRESENTATION BY EPRI

G. S. LELLOUCHE (ACCOMPANIED BY DR. IAN WALL, EPRI.)

MR. LELLOUCHE: Good afternoon, gentlemen. We are pleased to accept the Commission's invitation to contribute to these important deliberations.

Before starting I would like to make clear that this presentation is based on portions of the research done by the Institute, by their personnel, and their contractors in the area of probabilistics. As such, it does not represent a formal EPRI position. The formal EPRI position on ATWS is contained in the comments to Volume 4 of NUREG 0460 sent to Mr. Tadani(?) some time ago. In light of the fact that EPRI did not receive a copy of the current SECY document until last week, and then only from a secondary source, if the Commission wishes a further formal response to the staff's review of our position we shall be pleased to supply such when we are requested to.

I would like to start by referring to a rather old letter, 21 August, 1978, to Dr. Kerr from Carl Bennett, who is the ACRS ATWS Subcommittee statistical consultant. He stated that there were no statistical problems with the methods used by EPRI to treat the historical data. He suggested a modification in the procedure to combine plant data and we agreed to use the suggested method. He stated that the disagreement between the staff numbers and EPRI's came from the differing input data.

The input data arise from the following considerations -

1 and you gentlemen will forgive me, this is going to be a  
2 technical presentation.

3 CHAIRMAN AHEARNE: We will manage, I think, to hold  
4 through it.

5 MR. LELLOUCHE: It is always more difficult when you  
6 can't talk in generalities.

7 The input data arise from the following considerations:  
8 How many reactor years of experience are there? How many tests  
9 of the electrical system are there during a year? Is the kahl  
10 event pertinent to a calculation of ATWS probabilistics? How  
11 many transients per year are significant from an ATWS viewpoint?  
12 Is the effect of bypass capacity pertinent to the number of  
13 transients impacting on ATWS? Is the initial power level of the  
14 reactor pertinent?

15 A second question relates to determining a scram failure  
16 probability by using fault tree systems modeling - the so-called  
17 synthesis method.

18 A third question relates to competing risk and whether  
19 the suggested fixes actually reduce total risk.

20 The EPRI analysis of the historical data is found to  
21 be consistent with the fault tree analyses. The effects of rod  
22 and drive failures is found to be only a very small fraction of  
23 the probabilities found using the fault tree analyses, and this  
24 conclusion is consistent with the results obtained by Messrs.  
25 Vesely and Easterling using statistical models that are not based

1 on fault trees. The uncertainties in the historical results at  
2 the 5th and 95th percentile levels are also found to be consistent  
3 with the fault tree results at those percentiles. The effect of  
4 the square root bounding method for rod and drive is also shown  
5 not to meaningfully impact on a fault tree analysis above the  
6 50th percentile.

7 Our analysis of the effect of adding valves as a PWR  
8 fix has been previously addressed with the ASRS, and was shown  
9 to increase the total risk by increasing the small loca probability.  
10 We shall in great detail re-examine this work and address other  
11 reactors besides those in WASH-1400.

12 May I have the first figure, please?

13 This viewgraph shows the reactor years of experience.  
14 The NRR staff has stated in NUREG-0460 that there were 659 years.  
15 As of six months ago, EPRI stated there are 900 years. There are  
16 now 950 years of experience. The staff has not changed their  
17 mind as yet.

18 The testing rate. The NRR staff says there are 12  
19 tests per year.

20 CHAIRMAN AHEARNE: Per plant?

21 MR. LELLOUCHE: Oh, yes, per plant; certainly. In all  
22 this, except where otherwise stated, I believe I will be only  
23 talking about per plant information, except where it is obvious.

24 The EPRI position on this is that there are approximately  
25 a hundred tests per year. Let me go into that. What I am talking



1 about here are tests of the electrical system. I am not talking  
2 about tests of rod and scram drive per se, but only the electrical  
3 system.

4 What staff has been doing over the years, in fact from  
5 WASH 1270 on, is listing an analysis of the tests of the electrical  
6 system. They have stated a number of times in the documents that  
7 they believe the rod and drive to be much more reliable than the  
8 electrical system.

9 The mechanical engineering staff of the regulatory branch  
10 has stated that they believe the rod and drives to be much more  
11 efficient than the staff believe.

12 From this point of view we have proposed to bound the  
13 testing rate and its impact by looking at the electrical system  
14 since the staff believes that is the worst portion.

15 CHAIRMAN AHEARNE: Now, I assume that what you are  
16 saying is that you and the staff, when you sit down and debate  
17 it, disagree on the definition of a test. Clearly, you do not  
18 differ on the definition of reactor year. So, I gather the  
19 difference in the first is merely the date at which you choose.

20 MR. LELLOUCHE: One might argue that they have not  
21 changed their mind yet.

22 CHAIRMAN AHEARNE: Or that they have enough data  
23 past 1978. I assume the years and plants are not in debate.

24 MR. LELLOUCHE: Probably not.

25 EPRI has in the past stated that the number of BWR

1 tests per year is about 200. For PWRs we use 12 per year and  
2 state it to be an absolute lower estimate because we felt it  
3 difficult to account for the split testing procedures used at  
4 PWRs. We state today that the number of PWRs is also about 200  
5 and we can, if you wish, discuss the mathematics which lead us  
6 to believe that the split testing is in fact equivalent to a full  
7 single test.

8 CHAIRMAN AHEARNE: Would you say about 200 per year?

9 MR. LELLOUCHE: We will see exactly how those numbers  
10 arise.

11 For each transient of significance there will be a number  
12 of trip levels reached. May I have the next slide, please?

13 They generally will be neutron flux level, pressure  
14 vessel pressure, BWR water level for BWR. There will also be  
15 trip signals associated with specific transient, turbine trip,  
16 MSIV closure, loss of condenser vacuum, feedwater pump trip, loss  
17 of offsite power.

18 Westinghouse, in its publication has presented this  
19 table for the particular trips that are reached for these four  
20 transients which are very important from an ATWS point of view.  
21 In all cases you will notice there are three.

22 Some will say, aha, you don't get a turbine trip because  
23 there is no turbine trip for certain types of anticipated  
24 transients. But in both these cases you see that you have two  
25 others as well, and in our analysis we shall only use two as the

1 number of trips that are achieved. May I have the next slide,  
2 please?

3           It appears we have lost the slide. For BWRs the trip  
4 levels that are reached for loss of condenser vacuum or a stop-  
5 valve flux and vessel pressure, or MSIV closure, flux, vessel  
6 pressure and stop valves, and the same for turbine trip or  
7 generator trip, for pressure-regulative failure only two are  
8 reached, flux and vessel pressure; for loss of feedwater flow  
9 some three are reached, low water level, isolation valves - I am  
10 sorry - for flux and vessel pressure.

11           There are in all cases except a very, very few, and  
12 those very few have extremely small frequencies of occurrence,  
13 a minimum of two trip levels that are reached.

14           There will be other trips as well associated with steam  
15 generators. Each of those trip levels has associated with it a  
16 number of independent electrical channels, usually four. These  
17 channels are tested once every four weeks, yielding for two trip  
18 levels at four channels each -- well, I have it for three trip  
19 levels at four channels each, 144 tests per year. So, that would  
20 be approximately 80 tests, 90 tests a year for two trip levels.

21           Some transients reach a full 200 tests of the relevant  
22 channels per year because they hit four trip levels. Some less,  
23 approximately 100. In PWRs all channels enter a four-fold redundant  
24 low voltage relay, each of which is tested every four weeks,  
25 yielding 48 tests per year.

1           Now, in this particular list for Westinghouse we see  
2 that there are four channels for each of these, except for the low  
3 reactor coolant flow which are three per loop, which means many  
4 more than four. They are tested each 28 days, averaging approxi-  
5 mately six a week. Then the testing continues from the bistable  
6 to the actuator. There are six pairs of channels, each are  
7 tested every 28 days. Two breakers each are tested over 28 days.  
8 May I have the next slide, please?

9           The same thing is true for BWRs, only for BWRs we do  
10 not split the testing. For BWRs the test is a complete one,  
11 going from the sensor to the valve lifters, and they are done  
12 approximately five a week. Those question marks should be four,  
13 done approximately five a week.

14           Next slide, please, for B&W, I hope - we have them  
15 all backwards. For B&W the same thing is true, only here it goes  
16 from bistable into logic and the logic has trip relays, and  
17 then you have the trip breakers themselves. There are eight  
18 breakers and they go in a one out of two followed by two out of  
19 four. These are tested 40 times a month, for the logic 24 times  
20 a month for the logic trip relays; eight times a month for the  
21 breakers, and approximately four to six times a week for the  
22 channels.

23           Finally, for B&W the same thing is true here. We  
24 appear to have lost something, but continue on. What is the next  
25 one?

1           COMMISSIONER GILINSKY: What is it that you are calcu-  
2     lating here?

3           MR. LELLOUCHE: I am trying to demonstrate the number of  
4     tests of the portions of the system that are actually done each  
5     month. The purpose of this - these are all electrical, remember.  
6     The purpose of this is to demonstrate that in fact the electrical  
7     portion of the system from beginning to end, whether it is done  
8     split into two or three parts, or for BWRs as a single entity,  
9     are tested a number of times per month perhaps five, ten, 50,  
10    depending on which portions you are talking about - not once. Not  
11    once.

12           Each channel is tested once a month. There are many  
13    channels. Each breaker is tested once a month. There are for  
14    CE eight breakers. Trip relays are tested. Everything is tested  
15    many more times than once a month. When you add them together  
16    in a mathematically consistent way using statistical methods,  
17    statistical calculus methods, you find that in fact you have  
18    something like a hundred to two-hundred tests a year of the  
19    system, depending upon how many trip level sensors - whether you  
20    hit just a high pressure, or whether you hit a high flux as  
21    well, how many of those you hit. Per transient type you get any-  
22    where from a hundred equivalent full tests of the electrical  
23    system to two-hundred equivalent full tests of the electrical  
24    system per year, not twelve.

25           COMMISSIONER GILINSKY: What were you saying, equivalent

1 full tests?

2 MR. LELLOUCHE: Equivalent in the sense that for PWRs  
3 most, or at least some plants do not test them from beginning to  
4 end in a single unit, but they split testing from the beginning  
5 to the middle, and the next week the middle to the end. These are  
6 done for presumably good and sufficient maintenance reasons, but  
7 mathematically one can show that they combine when the frequen-  
8 cies are a failure or small - as they are here in fact - that  
9 this mathematical analysis show that they combine and it is  
10 fully equivalent, mathematically, to a full test.

11 So, I use the word "equivalent", so as not to be  
12 caught in a mathematical misstatement. They are mathematically  
13 equivalent to a full test of the electrical system, and there are  
14 a minimum of approximately 100 a year, not twelve.

15 That is all I am trying to do by demonstrating all  
16 of these multi-channel tests which go on.

17 The staff presumes in fact - I presume they presume -  
18 that all of these mean one test, one test of the total system,  
19 all channels of all sensors, all breakers, all actuators, every-  
20 thing. That, to them I presume, means a test. But from the  
21 point of view of what the reactor sees during a transient, that  
22 is not true. It is not true engineering-wise; it is not true  
23 mathematically; it is not true physically, it is simply in-  
24 correct to make such a statement.

25 Now, if we go on with this, 900 reactor years, a

1 hundred tests a year, approximately 90,000 electrical tests of  
2 the system. May I have the next slide, please? The one that  
3 says, "Summary of Testing Rates" at the top. Please, remove the  
4 others that you have already shown. I am sorry, gentleman.

5 Now, this shows the testing rate of the various portions  
6 of the system. BWR is depending upon transients 100 to 200 times  
7 a year. Again, these are only electrical tests, tests of the  
8 electrical portions. PWRs, sensors to bistable 100 to 200 times  
9 a year; bistable to actuator, depending upon reactor; breakers  
10 themselves, depending upon reactor. May I have the next slide,  
11 please?

12 Now, we have approximately 90,000 tests. As I said,  
13 100 tests per year, 900 reactor years, 90,000 electrical tests.  
14 If we apply the statistical methods used by the staff in fact,  
15 these are the staff's statistical methods, pi square, and neglect  
16 kahl, we get the top line.

17 With a median estimation of failure of the electrical  
18 portion of the system of approximately four times tenth of a  
19 minus six per demand. If we include kahl, we get approximately  
20 two and-a-half times larger.

21 Now, if we do move on from here, which is purely  
22 historical data, the actual number of reactor years, the actual  
23 testing procedures used in real plants, and go on to Fault tree  
24 analysis, these fault trees come from WASH-1400. We did some  
25 updating of the data and definitions, WASH-1400 assumes three

1 rods have to fail in a BWR; it is really five rods minimum in a  
2 close connection. They assume any three rods for PWR, there is a  
3 minimum of 30 rods, things of that nature. If you correct those,  
4 there are some physics, then for fault tree analysis you find the  
5 second set set of lines which again show that the median  
6 estimation is in line with or without kahl estimation. More  
7 so than it is with kahl, but I would not really care whether you  
8 multiply them by two, it does not make a significant difference.

9 Mr. Lewis of the Lewis Report has suggested that using  
10 square root averaging procedure is incorrect. He suggested  
11 that you should use the upper bound on multiple rod failure; and  
12 the upper bound is one percent - and he accepted this as not being  
13 unreasonable, one percent of the single rod failure. That is to  
14 say, if you have a hundred single rods, every time you have a  
15 hundred single rods failure, you have one total rod systems failure.  
16 We have not had a hundred single rods fail.

17 If we use that upper bound effect of the rods and  
18 drives, we get the pair of lines. Now, you will notice that  
19 it does impact significantly at the low end, at the five percent  
20 level. But it does not impact meaningfully above the 50-percent  
21 level, which indicates that the argument that the square root  
22 bounding technique is going to make significant changes. It  
23 certainly does not hold up under numerical analysis.

24 NRC calculated rod and drive effects, Messrs. Vesely and  
25 Easterling did them two different ways, not fault tree method,



1 but they were using standard statistical failure models. They  
2 calculate failure rates significantly lower, in fact, at 99-per-  
3 cent statistical confidence level.

4           These types of comparisons lead us to believe that we  
5 are calculating, treating the data correctly. Our fault trees  
6 are correct, that is to say, consistent with data analysis;  
7 effects of things like upper bound techniques or square root  
8 models don't alter these conclusions, in fact. May I see what  
9 the next slide looks like?

10           COMMISSIONER GILINSKY: What is your summary of that?

11           MR. LELLOUCHE: My summary of that is that the failure  
12 of the system, the electrical portion of the system in a total  
13 failure mode, that is all rods failing out, would be in the  
14 neighborhood of three to five times ten to the minus six per  
15 demand; not what the staff originally calculated which was  
16 approximately --

17           COMMISSIONER GILINSKY: That comes more or less from  
18 the middle column.

19           MR. LELLOUCHE: That is the middle column, yes.

20           COMMISSIONER GILINSKY: Why do you take the middle  
21 column?

22           MR. LELLOUCHE: In a normal distribution the middle  
23 column would be the mean value. In "skewed" distributions to  
24 talk about the mean does not necessarily have meaning - if you  
25 forgive my pun. You do not know where it lies on distribution.

1 The mean, in fact, in this case would be something like a factor  
2 of two higher than the median. These distributions tend to be  
3 log normal not exactly, they have an early peak and a long tail;  
4 and it is hard to make a choice as to what kind of a confidence  
5 level to use. Why should be pick 95 over 99, why not five nines?  
6 What is wrong with the two-percent level?

7 The answer to that is, there is nothing wrong with any  
8 of them, it is just what you want to interpret. By choosing a  
9 median estimate we are erring on the side of equal error. That  
10 is to say, it is equally likely that we could be above or below.

11 If we choose a high estimate, the odds are very good  
12 that we are well below it. That might be considered conservative,  
13 but it could be considered too conservative. Where does one stop  
14 with conservatism? So, one might say the 99 percent, another  
15 might say the five nines level. It simply errs equally on either  
16 side. That is the best I can do. In a normal distribution it  
17 is the mean value.

18 Now, this is insufficient to determine ATWS. For ATWS  
19 we also need to know what the frequency of transients is going to  
20 be, and we take our list of one of the important transients from  
21 the staff.

22 The staff says that for B&W we have loss of offsite  
23 power; total loss of feedwater, and transients leading to loss of  
24 feedwater.

25 For combustion we have better discrimination.

1 COMMISSIONER GILINSKY: Let me return to that point. We  
2 are dealing with very small samples, failure samples.

3 MR. LELLOUCHE: Yes, correct.

4 COMMISSIONER GILINSKY: Therefore, your estimate is  
5 intrinsically an uncertain one.

6 MR. LELLOUCHE: Certainly, in terms of the failures  
7 themselves because we had so few. But not in terms of the tests,  
8 where we had 90,000.

9 COMMISSIONER GILINSKY: So, it seems to me in these  
10 circumstances, I guess, I want to think more about the 50 percent.  
11 It is sort of like reaching into an iron and taking out 10,000  
12 balls and finding one red one.

13 MR. LELLOUCHE: That's correct.

14 COMMISSIONER GILINSKY: What do you conclude from that?

15 MR. LELLOUCHE: That the odds are something like one  
16 in 10,000?

17 COMMISSIONER GILINSKY: Maybe.

18 MR. LELLOUCHE: It depends on how many balls there are  
19 in the first place.

20 MR. LELLOUCHE: For combustion we have somewhat more  
21 detailed information for two different types of cores. The results  
22 for Westinghouse of consequence calculations, that is to say  
23 the transient that the plant undergoes shows that none of these  
24 transients, no transients exceed 3,100 psi at, I think, 95 per-  
25 centile moderated temperature coefficient. But the ones that

1 yield the worst result - that would be something like 2,800, I  
2 believe - are loss of load and total loss of feedwater.

3 For General Electric, any transient leading to excessive  
4 cool temperature, is a transient of significance. May I have  
5 the next slide, please?

6 We collected from the utilities that would report them  
7 to us information on all their scrams, the origin of their scrams,  
8 the status of the reactor before and after the scrams, and we  
9 categorizrd these and published it as an EPRI document. I believe  
10 the staff makes use of it.

11 We took the staff's definition of what is a transient  
12 of significance, ATWS, and we broke them out from the EPRI  
13 analysis of real plant data. We found that there were these  
14 many transients for PWRs and these for BWRs. May I have the next  
15 slide, please?

16 If we quantify them, using the data that is in NP-801  
17 which lists the actual frequencies, and we quantify them for the  
18 particular plants of necessity, LOOP is loss of outside power,  
19 loss of feedwater, loss of load; CEA is an uncontrolled rod  
20 withdrawal, etc., if we quantify them we find these numbers as  
21 being the numbers of events per year that occur.

22 CHAIRMAN AHEARNE: Now, you mentioned this was for the  
23 plants that would give you the data. Is that a large set of  
24 plants?

25 MR. LELLOUCHE: At that time it was approximately 50 per-

1 cent of the plants and 50 percent of the reactor years. We have a  
2 new analysis, we have done a second collection because that one  
3 stopped in 1976. We have done a new collection. We now have 60  
4 percent of the plant years and approximately 55 percent of the number  
5 of plants.

6 CHAIRMAN AHEARNE: Is this data based on that later  
7 collection?

8 MR. LELLOUCHE: The later collection has not been  
9 completely analyzed yet. We are still hoping to get some more  
10 data.

11 I can say this: These numbers do not change by more  
12 than three to five percent as far as my understanding of the  
13 numbers at the present time.

14 The staff, however, quotes different numbers. They  
15 also say that we have excluded a whole bunch of transients from  
16 our list. May I have the next one, please?

17 These are the transients that they say we have excluded.  
18 Of all of these, the vendors say the "nones" mean there is no  
19 effect, there is no significance. There is one error here on the  
20 BWR, the first one, on "stuck valves" the no should be a yes. I  
21 am not even sure you have it on your graph. It should be yes -  
22 yes - no - no of PWR.

23 They do not have much significance. The "maybe" there  
24 means those feedwater instabilities have to do with single loops.  
25 The scrams are mostly RX scrams.

1 CHAIRMAN AHEARNE: In your middle column there the  
2 frequency is at 25 percent?

3 MR. LELLOUCHE: Above 25 percent, I beg your pardon.  
4 I do not have data on stuck valves above 25 percent power.

5 The "maybes" refer to the fact that most of the feed-  
6 water flow instabilities, a number of them are caused by operators,  
7 about half; about half are mechanical, and almost all of them do  
8 not require a scram at the time it occurs, but a scram is an RX  
9 scram. Whether it would add in later on and cause trouble, I  
10 could not say. That is the largest ~~form~~ *error*.

11 Now, if we go further, we now compare - may I have the  
12 next slide, please? We can take a look at what the power  
13 distributions are. The number of transients carrying below  
14 25 percent power is approximately half, the total number of  
15 transients occurring for PWRs and approximately 70 percent for  
16 BWRs. The number of transients of importance to ATWS are also  
17 approximately half from between above 25 power and below 25 per-  
18 cent power. The importance of this will come up in just a moment.  
19 May I have the next slide, please?

20 If we plot up our numbers, the EPRI numbers, of the  
21 actual anticipated transients which are of significance and  
22 compare them with NUREG-0460, our estimate, we see that actual  
23 operating experience lies significantly below the staff's  
24 estimate - very significantly below the staff's estimate.

25 Now, the staff says that they do not believe that 25

1 percent power is a cutoff. May I have the next slide, please?

2 This is a CE machine, these are <sup>retrend</sup> calculations done as  
3 a function of moderator temperature coefficient at power level  
4 with and without aux speed for two types of transients, loss of  
5 feedwater and MSIV closure.

6 Now, you will notice that for below 50 percent power,  
7 or certainly below 25 percent power, independently of the  
8 moderator temperature coefficient you don't exceed 2,500 psi,  
9 and that is true whether you have access to a condenser or not.  
10 That is to say, it is true for a loss of feedwater with condenser  
11 available and it is true for an MSIV closure without condenser  
12 and without aux <sup>speed</sup> speed. The result is that calculations like  
13 this show that the staff's presumption that 25 percent power  
14 is an inappropriate cutoff simply is incorrect. May I have the  
15 next slide, please?

16 The next slide shows a B&W machine, this is for a  
17 loss of feedwater transient, and one sees here that the  
18 probability is not exceeding - this is unfortunately the negative  
19 of what I wanted to say.

20 CHAIRMAN AHEARNE: We have the one.

21 MR. LELLOUCHE: You have the good one? All right,  
22 you have the inverse of the slide. The probability of exceeding  
23 3,200 reaches essentially zero below 75 percent power; 25 percent  
24 power is the cutoff. It is really quite an acceptable number  
25 for PWRs.

1           Now, for BWRs 25 percent power has to be combined with  
2 access to the condenser. You have a 25-percent or greater condenser  
3 bypass capacity, transients below 25 percent power or below the  
4 condenser capacity will not impact. Such calculations have been  
5 done, and I believe presented to the staff from Yankee, and they  
6 show simply that you don't get into any kind of trouble if your  
7 initial power level is less than your bypass capacity. Even when  
8 the bypass is not available, and you are going into the torus, if  
9 you are below 25 percent power you have approximately half an  
10 hour before you reach about 180 degrees, which is still 20 degrees  
11 below any staff limit. That is without turning on the torus,  
12 a heat-exchanger cooler. You have nearly an hour if you turn that  
13 up.

14           So, I would suggest that 25 percent power is a reasonable  
15 cutoff for all ATWS transients on PWRs and for all ATWS transients  
16 that have access to the condenser for BWRs. May I have the next  
17 slide, please?

18           The result of this is the frequency of transients and  
19 the ATWS frequency. We will look at the bottom of the table.  
20 The frequency of transients that are applicable to PWRs, if we  
21 deal with all PWRs as a unit, not separating them out by plant,  
22 is .6 per year. For BWRs approximately three and-a-half, and if  
23 we sum them up with a six to four split it is approximately 1.7  
24 per year. These yield ATWS frequencies between two and two times  
25 ten to the minus five for Bs and three times ten to the minus six



1 Ps. May I have the next slide, please?

2 The staff, however, has used various numbers. In  
3 0460 Vol 1-3 they have two times ten to the minus four; in Vol 4  
4 they used eight times ten to the minus five; and for some PWRs,  
5 Westinghouse ten to the minus six, but they still used two times  
6 ten to the minus four for BWRs, and I would suggest that the  
7 real data yield numbers approximately in order of magnitude less.

8 Any safety-oriented plant modification contains within  
9 it the probability of accomplishing the goal desired, and the  
10 potential for creating new and altered pathways for accidents.  
11 Thus, the usefulness of any modification lies in a trade-off  
12 between the decreased risk inherent in the modification and the  
13 increased risk due to the new accident pathways created by the  
14 modification.

15 Examples of this trade-off are well known. Some of them  
16 are the interfacing LOCA (Event V of WASH 1400) where locking open  
17 an MOV to eliminate a single failure point for use of the LPSI  
18 increased the probability of the LOCA through the two check  
19 valves by a factor of ten.

20 Another example is requiring the auxfeed to actuate  
21 as a post TMI requirement for certain events has increased the  
22 number of pressurizer emptying transients which appear to the  
23 operator as a LOCA and increase the likelihood of operator  
24 misaction.

25 Closure of the blocking valves on the PORV and main-

1 tenance of the HPI has increased the number of safety valve  
2 actuations and in fact, it led to the safety valve actuation at  
3 Crystal River.

4 Each of these are competing risk situations where  
5 unexpected results and increased risk are obtained from a supposed-  
6 ly safety-based modification intended to reduce it.

7 In the case of ATWS the staff has suggested that  
8 increasing the number of valves on combustion and B&W plants  
9 will reduce ATWS risk. The following analysis shows that this  
10 modification induces a competing risk situation and the increased  
11 competing risk is greater than the ATWS risk reduction. The  
12 competing risk here is a failure of a valve to reseal after it has  
13 opened, that is to say, TMI 2 and Crystal River.

14 In the following analysis we will consider WASH-1400  
15 for a category characterization of the event sequence, but it  
16 will be made reasonable that for B&W and C.E. there should be no  
17 real difference. We shall also consider the Crystal River  
18 probabilistic risk assessment document and show that indeed for  
19 Crystal River; this is also specific.

20 Now, ATWS risk. An ATWS event sequence - can I have  
21 the next slide?

22 COMMISSIONER GILINSKY: May I ask you, are those  
23 numbers comparable?

24 MR. LELLOUCHE: These numbers are all for comparable  
25 confidence levels; they are all median numbers. The staff numbers

1 are median numbers and so are ours.

2 The next slide, please. An ATWS event sequence leading  
3 to potential damage depends on the time into the fuel cycle. Early  
4 in the cycle, insufficient fission products have built up so that  
5 a large amount of boron is in solution. Up to some time, T-1 say,  
6 in this figure, even if all the valves open during an ATWS, the  
7 moderator coefficient will be insufficiently negative to terminate  
8 the transient before an excessive pressure level is reached.  
9 In this time period the ATWS transient of importance is TK. That  
10 is to say a transient followed by a simple failure of the scram  
11 system. O-t stands for the frequency of the scram system.

12 In the second part of the fuel cycle the moderator  
13 coefficient is sufficiently negative so that if all the valves  
14 open, no excessive pressure will be reached. But if one valve  
15 fails to open - symbolized by P here - then an excessive  
16 pressure will be reached. Further on, two valves will have to  
17 fail to open. Further on, beyond that, three valves would have  
18 to fail to open. Beyond the point T-2 the moderator coefficient  
19 is so negative, even if all the valves fail to open no excessive  
20 pressure will be reached.

21 We estimate T-1 to be approximately 40 percent of the  
22 weight into the transient.

23 The only competing risk we deal with here is failure  
24 of a valve to reseal.

25 COMMISSIONER HENDRIE: How far out do you have to get

1 on these plants to get T-2?

2 MR. LELLOUCHE: Eighty to 90 percent for some; it  
3 depends on the particular transient. If you have a 3,300 psi  
4 transient, not too much time; if you have a 5,000 psi transient  
5 you may never get there. But I will not be making use of T-2.

6 The only competing risk I want to deal with is failure of  
7 a valve to reseal. This event is denoted universally by Q.  
8 Clearly, for Q to occur the valve must have opened. The number of  
9 stuck open PWR valves has been determined by searching the LERS  
10 to be 9. May I have the next slide, please?

11 Using a 300 PWR reactor-year experience base, this  
12 leads to a transient frequency of stuck open valves of 03 per year.  
13 There are two types of sequences where failure to reseal is  
14 significant. The first is the ATWS event itself where the  
15 sequence - TKQ - leads to a small LOCA and any additional serious  
16 failure of HP.I leads to core melt. In WASH-1400 the additional  
17 failures will come up in a moment.

18 We have here besides these TKQs, such as failure of  
19 the HP.I or failure of ECC injection, we also have the same type  
20 of event, that is to say a stuck open valve leads to release of  
21 liquid on the T\*Q event. These are equally likely during the  
22 entire fuel cycle and don't have anything to do with moderator  
23 coefficient. Now, may I have the next slide, please?

24 These are the list of events that have occurred, we  
25 notice one of them is a blocking valve. In <sup>unit</sup>Fort Calhoun we had a

1 common mode failure of 2 PORVs, one was a safety valve and and  
2 a PORV valve. These two events have actually occurred. May I  
3 have the next slide, please?

4 The types of secondary failures that have to occur  
5 are given their symbolism from WASH-1400. They are failure of  
6 containment spray injection; failure of ECC, the other three.  
7 Now, in the range of time zero to T-1 into the fuel cycle, TK  
8 is much greater than TKQX. In the second range, TKP is less,  
9 much less than TKQX, and TK onward, TKQX is the total range.

10 The types of transients which in fact lead to the  
11 lifting of valves are common to all PWRs and they are standard  
12 ATWS types when the scram system does occur, in fact. Their  
13 cold pressurization is one at which PORVs often open at a lower  
14 pressure level, but they have the likelihood of not closing again.

15 Now, if we go to WASH 1400 we can determine what these  
16 transient frequencies are in the sense that WASH 1400 deals  
17 with a small, small measure. They say that S-2 is like a stuck-  
18 open valve, and S-2-G which would be a small break followed by  
19 ECC failure at a certain frequency, and they listed the frequencies  
20 as they are listed on this graph.

21 When we take the S-2 frequency out, we determine what  
22 the actual failure rate of the secondary systems are, and from  
23 these we can now determine by summing them what the actual T\*QX  
24 frequency is; and it is approximately five times ten to the minus  
25 four.

1           Now, staff has said that their frequency is two times  
2 ten to the minus four, or eight times ten to the minus five, and if  
3 you take that 40 percent of the time - well, 40 percent of the  
4 time is the eight times ten to the minus five. If you calculate  
5 that as one point six times ten to the minus four and account  
6 for it, a valve lifting stuck open is approximately ten times  
7 larger than ATWS already.

8           Now, some reactors do not have the same type of failure  
9 modes as others. That is to say, Surry does not contain fan coolers  
10 for plants with fan coolers as well as sprays the C event would  
11 not be important. Similarly, plant variations imply that F&H  
12 are couples and that you should not differentiate, necessarily,  
13 between them. May I have the next slide, please?

14           We can recalculate T\*QX for non-Surry types of plants  
15 to be approximately five times ten to the minus four, and ATWS  
16 is still approximately a factor of ten smaller than these stuck-  
17 open valve events.

18           Now, we have only looked at the melt probabilities.  
19 From a risk viewpoint this is insufficient, we have to look at  
20 the release probability as well, and the releast fractions. If  
21 I may have the next slide, please, we can see that all size  
22 scram failure and competing risk events are classified in  
23 the release categories 3, 5 and 7. The release magnitudes for  
24 3 are much greater than for 5 and 7, and here we have compared  
25 them in terms of equivalent iodine which is a convenience only.

1 NUREG 0460 states that there is some possibility for an ATWS to be  
2 in PWR-3 but does not quantify this statement. It concludes the  
3 most likely failure mode is PWR-7. We quantify the probability of  
4 it being in PWR-5, in this case, by looking at TK-beta which is  
5 a category 5 event, and we include the TK-epsilon, which is a  
6 category 7 event, and we do not have to deal with any other  
7 categories as far as we know.

8 The competing risks are in two types, a delta risk and  
9 an alpha risk, the alpha risk being a steam explosion and delta  
10 being another form of core melt. If you take the ratio of these  
11 two - may I have the next slide, please - we determine what the  
12 actual competing risk is, and the competing risk is 5,000 times  
13 larger than the ATWS rate.

14 Now, that is true for Surry. If we neglect C&F modes  
15 of failure it is also equally true for non-Surry types of plants,  
16 and that is 500 times. If we go over to Crystal River - may I  
17 have the next slide. You do not have a copy of this, I made it  
18 up on the way in.

19 If we use the Crystal River report, T\*Q us considered  
20 as a B-4 -- type event. The B-4 sequences are listed here,  
21 their melt probabilities, given a B-4 event occurs are listed  
22 here. Their sum is much greater than for Surry, the total T\*QX  
23 is twice as large in Surry and the ratio of non-ATWS risk to ATWS  
24 risk for Crystal River is a factor of 10,000.

25 Now I don't care how many valves are put on, any

1 additional valves will increase the risk. There is no conceivable  
2 way that additional valves can reduce the risk. These numbers are  
3 so large that even if only one percent of them went to increased  
4 risk, you would still have excessive increases in risk over ATWS.

5 I would like to very briefly now go through the comments  
6 made by the staff concerning the formal EPRI review of Volume 4.  
7 This makes reference to SECY-80-409, Enclosure F.

8 On page F2 the staff comments: EPRI should not use  
9 "much criticized square root bounding method," and that it  
10 improperly treated the Naval data.

11 We would respond to that by saying the EPRI analysis  
12 was in accordance with WASH 1400 to which it was being compared.  
13 To alter one analysis would have required redoing WASH 1400.  
14 Since only comparisons were being made no dichotomy exist.. Much  
15 more important, however, is the fact that the EPRI analyses of  
16 the historical data and the synthesis results utilizing the square  
17 root bounding method are numerically in accord with each other  
18 above the 50th percentile.

19 Further, the exclusion of the square root method does  
20 not alter this result. This result does not, however, depend  
21 on the use of Naval data. It does depend on estimating the testing  
22 rate in accordance, however, with actual plant practice and not  
23 with the staff's assumption.

24 Finally, the Vesely and Easterling NRC analyses predict  
25 still smaller system failure rates than the EPRI analyses did.



1           On page F3 the staff comment: The EPRI list of  
2 transients is incomplete.

3           Our response would be, if we add these extra transients  
4 in they make no significant difference in the numerics. In fact,  
5 however, the vendors dispute the additions of most of these  
6 transients. They do not agree that most of them would lead to  
7 trouble even if the scram system failed. In fact, some of these  
8 extra transients are already analyzed in vendor submittals and  
9 have been shown not to lead to trouble.

10           Second, the staff says that exclusion of events below  
11 25 percent power may be inappropriate.

12           Response: Extensive evidence now exists that with  
13 the one possible exception of uncontrolled rod withdrawal which  
14 has a frequency of one per hundred years, the worst PWR transients  
15 which have access to the condenser do not lead to excess  
16 pressures when they start from below 50 percent power; and that  
17 this is true with or without aux feed. Both B&W and CE machines  
18 have been analyzed and the B&W analysis showed that this is  
19 true below 85 percent initial power; and the CE certainly below  
20 50 percent initial power.

21           Comment by the staff: Only five years of EPRI  
22 collected transient frequency experience data is meaningful.

23           We would respond: The staff has been saying this for  
24 the last two years. They should at least go to seven years. But  
25 the fact is that the PWRs, we have ten plants with nine or more

1 years data and four with 13 or more years data. There is little  
2 rationale for excluding any data except for mathematically justi-  
3 fiable reasons, and no mathematically justifiable reasons have  
4 been made by the staff.

5           The staff comments: The EPRI analysis of testing  
6 rates is wrong.

7           We would respond: Channel tests are perfectly  
8 appropriate since they give upper bounds on multi-channel outages.  
9 Further, although the data indicates occasions where all channels  
10 of a given sensor type have failed, there is to our knowledge  
11 no occurrence of simultaneous failure of all channels of two  
12 or more sensor types, and almost all channels trip two or more  
13 types of sensors.

14           This is where the Fessenheim analysis which the staff  
15 uses as backup to their numbers falls apart. Although the data  
16 used to derive input for Fessenheim shows no simultaneous failures  
17 of all channels of two sensor types, the final result is based  
18 on a common mode failure factor of beta equal to .1. If this  
19 very true, there would with very high probability have been  
20 at least one and probably two simultaneous total failures of  
21 all channels of two diverse sensor systems.

22           Since such has not occurred it is more likely that  
23 beta equal .01 more correctly describes the simultaneous failure  
24 of two diverse sensor systems. This would produce results fully  
25 in line with the EPRI calculations of historical data and the

1 EPRI fault tree and other analyses.

2 More to the point, however, is the fact that the  
3 Fessenheim analysis has two arbitrary constants and their calcu-  
4 lations may be made to any numbers desired. Further, the paper  
5 by Apostolakis which is also used by the staff as confirmation of  
6 their results has been completely discredited by commentators,  
7 including Mr. Easterling; and Mr. Apostolakis has agreed with  
8 the fact that his paper is incorrect. There is in fact no  
9 defensible calculation which backs up the staff results.

10 Page F7. The staff comments: Only stuck-open safety  
11 valves should be included in calculating increased risk due to staff  
12 imposed fixes.

13 COMMISSIONER GILINSKY: Mr. Apostolakis has agreed  
14 that his paper is incorrect, presumably he has done so in writing?

15 MR. LELLOUCHE: Yes.

16 COMMISSIONER GILINSKY: Where?

17 MR. LELLOUCHE: In his response to the letter which  
18 Mr. Easterling sent in as a letter to the editor.

19 CHAIRMAN AHEARNE: Has it been published in Nuclear  
20 Safety yet?

21 MR. LELLOUCHE: I don't know whether it has as yet been  
22 published in Nuclear Safety. I received it in the mail, and since  
23 I received it, they must have received it from Nuclear Safety.  
24 I am sure Nuclear Safety has it; and Mr. Apostolakis agrees that  
25 his calculation is wrong. If it in fact had been correctly done

1 according to his lights, if he had done the numerics correctly,  
2 he would have gotten an order of magnitude higher than the staff's  
3 numbers. The staff's numbers would now be in the neighborhood of  
4 ten to the minus. His numbers, multiplied by the frequency of  
5 transient would be in the neighborhood of two times ten to the  
6 minus three per year. His analysis is incorrect.

7 It is incorrect for a number of reasons. If you wish  
8 I can go into them, but I don't know if you wish.

9 COMMISSIONER BRADFORD: It would be easier if you just  
10 sent us a copy of the letter.

11 MR. LELLOUCHE: I have to find it. I will get you a  
12 copy of the letter.

13 COMMISSIONER BRADFORD: Fine.

14 MR. LELLOUCHE: Now, on page F7 the staff says: Only  
15 safety valves should be included in determining increased risk  
16 from competing risks.

17 In response we would say: The staff thus throws  
18 out all LERs as being involved. They have rectified nine out of  
19 nine events. But on what basis? We agree that any additional  
20 valves would have higher set points, we stated so in just those  
21 words in our comments on Volume 4 of NUREG-0460. But firstly,  
22 most of the stuck-valve events were caused by human maintenance  
23 errors which had nothing to do with set points; and second, the  
24 new requirements concerning closing backup valves introduce  
25 additional failure modes, leading to safety valve actuation. We

1 also stated this in our comments to Volume 4. It would seem that  
2 rectifying nine out of nine events would be slightly unconservative  
3 when the staff still refuses to agree on the rectification of the  
4 single kahl event because that would be unconservative.

5 On page F8: Operators have time to mitigate small LOCAS.  
6 The staff says that because of that none of these small LOCA  
7 events should lead to any problems.

8 We would respond that the staff might allow such  
9 consideration for ATWS. Browns Ferry clearly shows that the  
10 operator would respond rapidly to a failed scram. To assume that  
11 such operators would sit on their hands for ten minutes is clearly  
12 unrealistic.

13 On page F9 the staff says: The EPRI analysis is  
14 wrong because of errors and deficiencies.

15 We would respond, we put together the comments to  
16 Volume 4 in three or four days. There are indeed some typos and  
17 one numerical error. But the implication of the results still  
18 stands. The staff did not bother to correct the errors and  
19 requantify. Had they done so, they would have found that for non-  
20 Surry plants the valve risk is 500 times larger than ATWS risk.  
21 They did just not bother to do that.

22 Now, that is all I have to say, but we also present in  
23 our comments to Volume 4 an analysis of the value impact statement  
24 made by staff, and Dr. Wall would like to comment on that, if he  
25 may.

1 CHAIRMAN AHEARNE: Dr. Wall?

2 DR. WALL: I am sorry I do not have a whole statement  
3 since we only received the SECY document last week and I was out  
4 of the country.

5 We are very pleased indeed that we found our comment was  
6 acceptable, namely that recommending to use incremental rather  
7 than total values and impacts, the value impact statement.

8 However, it is rather unclear in the final SECY document,  
9 Enclosure B, where the latest table and value impacts states  
10 incremental and total numbers. I think Mr. Gibbs referred to that  
11 in his presentation.

12 We also found some inconsistencies in NUREG 0460 and  
13 recommended that NRC publish all calculation details. To our  
14 knowledge, such details are still not available, and indeed  
15 within this briefing table, Table 1, Enclosure B, is at least  
16 partially inconsistent with Table 3 where they are trying to  
17 correct the values at page F11.

18 These frequent updates without full support is what  
19 renders it so difficult for other parties to track NRC's  
20 calculations. I think it would be very easy for the staff to  
21 help in that respect.

22 The NRC staff claims that EPRI misinterpreted their  
23 impact, Alternatives 2(a) and 3(a). EPRI as an R&D organization  
24 has no input to offer on impact estimates. So, we merely try  
25 to use NRC numbers. NUREG-0460 is somewhat confusing on the

1 subject, so we rather carefully noted that the impact numbers  
2 were approximate in our comments.

3 In any event, the thrusts of our comments were on the  
4 estimation of value, not impact, and any misinterpretation only  
5 reflects on the relative impact of Alternative 2(a) and 3(a).

6 The staff's response is incorrect and in that respect  
7 seems overly encompassing and unjustified.

8 The NRC staff did not address Enclosure F, the other  
9 EPRI comments on their value analysis. These comments point out  
10 several deficiencies, some of which Dr. Gibbs referred to; for  
11 example, this variation in consequence magnitude for potential  
12 core melting accidents should be considered. When one does that,  
13 the rate of logical risk reduction claimed for PWR ATWS fixes  
14 are overstated by at least a factor of ten.

15 Realistic as opposed to conservative parameters should  
16 be used or, alternatively one wishes to be more informative, quote  
17 the realistic values and put a range which includes conservative  
18 values which may be more palatable to the staff.

19 The effect of proposed fixes on overall plant risk should  
20 be assessed as a whole and not just in isolation; and Dr. Gibbs  
21 addressed that very succinctly.

22 In summary, the NRC staff has not substantively  
23 addressed in Enclosure F EPRI's comments on the impact analysis.  
24 Insufficient reasons are given to change our contention that the  
25 values on ATWS fixes are greatly overstated. We believe that

1 on-going policy risk assessments for specific plants will show  
2 that with a few "outliers" ATWS is not a dominant contributor to  
3 public risk. Thus, it will be more cost effective to address  
4 other --

5 CHAIRMAN AHEARNE: When you say a few outliers, do you  
6 mean plants?

7 DR. WALL: I mean maybe a few plants, a few events  
8 which have significantly probability that we currently see in  
9 Surry. That is something which I think will come out within the  
10 next twelve months.

11 Furthermore, if the recommendations of the ACR Sub-  
12 committee on Safety Goals are accepted by your Commission, the  
13 more stringent NRC proposals do not appear to be justified. Again,  
14 Mr. Gibbs addressed that very fully.

15 Accordingly, we would recommend that the NRC limit its  
16 requirements in the short term to the above outlined and focus  
17 on what is important, and defer its more stringent proposals  
18 for 12 to 18 months until many on-going public risk assessments  
19 are completed and the safety goal has had a more widespread review.  
20 Thank you very much.

21 CHAIRMAN AHEARNE: When you say focus on efforts on  
22 the outlying plants --

23 DR. WALL: Outlying events on selected plants.

24 COMMISSIONER HENDRIE: It seems to me that the essence  
25 of the difference on the ATWS frequencies, there is about a factor



1 of ten difference in the assumption of the tripping rate, and I  
2 am not quite sure what the overall average in transient rate  
3 would be on the staff side, but I suspect about five, and yours  
4 is a little under two, a factor of about two and-a-half.

5 DR. WALL: Except for Westinghouse.

6 COMMISSIONER HENDRIE: I am just trying to pick some  
7 characteristic of the overall set. Those differences then  
8 propagate through and result in a factor of ten difference in  
9 the estimates of ATWS occurrence rates.

10 MR. LELLOUCHE: Ten to twenty. In my analysis of  
11 comparative risk I used the staff's numbers for ATWS frequencies,  
12 I did not use any other numbers. I compared only the staff number  
13 risk. If we had used other numbers, historical numbers, that  
14 risk ratio would have been much larger.

15 COMMISSIONER HENDRIE: I guess the other comment I  
16 would like to make - not knowing quite where it fits in the  
17 discussion, actually - is that the most prominent recent contri-  
18 bution to ATWS experience for the scrap discharge volume at  
19 Brown's Ferry didn't have very much to do with the electrical  
20 portion of the system.

21 CHAIRMAN AHEARNE: That was a comment.

22 COMMISSIONER HENDRIE: I am not sure what to infer from  
23 that, you understand.

24 MR. LELLOUCHE: Neither was a failure to scram in the  
25 ATWS sense in that the residual power level was in the neighborhood

1 of a very few percent. Had it occurred from 100 percent power,  
2 it would have still been in the neighborhood of approximately  
3 ten percent, which could have been handled by the condenser. It  
4 was not an ATWS, it was not even an approximate ATWS.

5 COMMISSIONER HENDRIE: I recognize that. I regard it  
6 not as having particular significance as a piece of data with  
7 regard to ATWS frequency, but rather a piece of interesting data  
8 with regard to scram system reliability or unreliability.

9 MR. LELLOUCHE: I agree with you.

10 COMMISSIONER HENDRIE: I did feel compelled to comment  
11 since your testing rate is one which is based on the testing of  
12 the electrical portion of the system.

13 COMMISSIONER BRADFORD: When you say it was not an ATWS  
14 or even an approximate ATWS, are you assuming that there could  
15 not have been more water held up in the system which would thereby  
16 have defeated the scram to a greater extent?

17 MR. LELLOUCHE: That would have been a different event.  
18 I am not suggesting that. I am saying that the event which  
19 occurred was not an ATWS, number one. If the event which occurred  
20 had occurred at 100 percent power, it would have still not been  
21 an ATWS because the residual power level would have been approxi-  
22 mately ten percent, and the bypass to the condenser would have  
23 handled it. An ATWS by definition, I presume, is one in which we  
24 have a pressure spot of some nature of significance, one in which  
25 in a BWR the torus starts to overheat significantly. An ATWS in

1 which nothing happens is a benign ATWS. The words are very  
2 difficult.

3 The events could have occurred slightly differently,  
4 obviously, in which it would have been worse or better; there is  
5 no argument to that, you are correct. The event which did occur,  
6 in fact, was not an ATWS in any classical sense of the meaning  
7 of the word.

8 CHAIRMAN AHEARNE: Thank you very much, gentlemen.  
9 We have certainly, as Mr. Hendrie said, had an informative  
10 afternoon session, and I am sure we will have further dialog  
11 with our staff.

12 MR. LELLOUCHE: Thank you, sir.

13 CHAIRMAN AHEARNE: We stand adjourned.

14 (Whereupon, at 4:20 p.m. the meeting of the Commission  
15 adjourned, to reconvene subject to the call of the Chair.)  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the  
COMMISSION MEETING

in the matter of: Presentation by GE, AIF, and G. Iellouche (EPRI) on  
anticipated Transients without SCRAM (ATWS)

Date of Proceeding: October 28, 1980

Docket Number: \_\_\_\_\_

Place of Proceeding: October 28, 1980

were held as herein appears, and that this is the original transcript  
thereof for the file of the Commission.

M. E. Hansen

Official Reporter (Typed)

*M. E. Hansen*

Official Reporter (Signature)

ATWS:

A REVIEW

BY

G. S. LELLOUCHE

October 28, 1980

VIEW GRAPHS

REACTOR YEARS OF EXPERIENCE

NRR STAFF                    659 (1978)

EPRI                            900 (1980)

TESTING RATE

NRR STAFF                    12/YEAR

EPRI                            100/YEAR

## APPENDIX 1

### THE REACTOR PROTECTION SYSTEM: TESTING AND FUNCTION

NUREG 0460 assumes that 12 tests of the electrical system are performed per year. The EPRI studies indicate that this is in error by at least a factor of 8.

The reactor protection system consists of sensors, logic, bistables, actuators, and breakers. In BWR's the signal proceeds from the sensor through redundant lines to a pair of actuating valves. The PWR systems are more varied at the breaker end consisting of logic systems requiring one out of two (1/2), two out of four (2/4), or a still more complex 8 breaker system (in four pairs of two with a 1/2 followed by a 2/4) to actuate rod motion.

In analyzing actual plant procedures it is necessary to determine the number of trip levels in the plant, their redundancies, and their testing rates. In order to apply this information to predicting scram unavailability it is necessary to determine which trip levels are reached in any transient of significance.

Consider the four plant types individually. The trip level, redundancies, and testing frequencies are as follows:

#### BWR's

<u>Scram Signals</u>	<u>No. of Channels</u>	<u>Test Frequency</u>
APRM Highflux	4	Weekly
High Main Steamline Radiation	4	Weekly
High Pressure in Vessel	4	30 days
High drywell pressure	4	30 days
MSIV	4	30 days
Turbine Control Valve	4	30 days
Turbine Stop Valve	4	30 days
Others		

---

AVERAGES ABOUT 5/week

Westinghouse (Senser to Bistable)

<u>Scram Signals</u>	<u>No. of Channels</u>	<u>Test Frequency</u>
High Flux	4	Each 28 days
Overtemperature	4	Each 28 days
Overpower $\Delta T$	4	Each 28 days
Low reactor Coolant flow	3/loop	Each 28 days
Low Pressurizer Pressure	4	Each 28 days
High Pressurizer Pressure	4	Each 20 days
High Pressurizer Level	3	Each 28 days

Average ~

6/week

Bistable to Actuator

6 (2/4)

Each 28 days

Breakers

2 (1/2)

Each 28 days



B & W (Sensor to Bistable)

<u>Scram Signals</u>	<u>No. of Channels</u>	<u>Test Frequency</u>
Power range high flux	4	Each 30 days
Pressure Temperature	4	Each 30 days
Reactor Coolant Temperature	4*	Each 30 days
High reactor pressure	4	Each 30 days
Low reactor pressure	4	Each 30 days
Others		Average 6/week
<u>Bistable to Breaker</u>	4 (2/4)	Each 30 days

C.E. (Sensor to Bistable)

<u>Scram Signals</u>	<u>No. of Channels</u>	<u>Test Frequency</u>
High flux	4	Each 30 days
R.C. Flow	4	Each 30 days
Low pressurizer pressure	4	Each 30 days
High pressurizer Pressure	4	Each 30 days
Steam Generator Level	4	Each 30 days
Steam Generator Pressure	4	Each 30 days
Others		

---

Averages ~ 6/week

Logic	40	
Logic trip relays	24 (includes breakers in pairs)	each 30 days
Trip Breakers (in pairs, any 1/2 any 2/4)	8	each 30 days

With very few exceptions (and from EPRI NP801 these have very low frequencies). ATWS transients reach at least two diverse trip levels. The following indication of trip levels come from vendor documents.

BWR TRIP LEVELS

<u>Transient</u>	<u>Trip Levels Reached</u>
Loss of Condensor Vacuum	Stop Valves, Flux, Vessel Pressure
MSIV closure (all loops)	Flux, Vessel Pressure, Stop Valves
Turbine Trip	Same
Generator Trip	Same
Pressure Regulator Failure	Flux, Vessel Pressure
Loss of Feedwater Flow	Low Water Level, Isolation Valves Flux, Vessel Pressure

TRIP LEVELS REACHED DURING W ATWS TRANSIENTS

<u>Transient</u>	<u>RPS Trip Due To</u>
Loss of Load	Turbine trip High Pressurizer Pressure Over temperature $\Delta T$
Loss of Feedwater	Turbine Trip Over temperature $\Delta T$ High Pressurizer Pressure
Loss of Offsite Power	Undervoltage Underfrequency Over temperature $\Delta T$ Over power $\Delta T$ Others
Rod Withdrawal	High Flux Over temperature $\Delta T$ Over power $\Delta T$ Pressurizer high level

POOR ORIGINAL

SUMMARY OF TESTING RATES  
FOR EACH REACTOR

BWR's

Depending on Transient 100-200/year

PWR's

Sensors to Bistable

Depending on transient 100-200/year

Bistable to Actuator

W 78/year

B & W 48/year

C. E. 430/year

Breakers

W 24/year

B & W 48/year

C. E. (Direct test) 95/year

C. E. (with Logic Trip Relays) 288/year

## SCRAM UNAVAILABILITY / DEMAND

### STATISTICAL CONFIDENCE

LEVEL

5%

50%

95%

### HISTORICAL DATA

WITHOUT KAHL	$2.8 \times 10^{-7}$	$3.8 \times 10^{-6}$	$1.7 \times 10^{-5}$
WITH KAHL	$2 \times 10^{-6}$	$9 \times 10^{-6}$	$2.4 \times 10^{-5}$

### FAULT TREE SYNTHESIS

BWR	$5.1 \times 10^{-7}$	$2.3 \times 10^{-6}$	$2 \times 10^{-5}$
PWR	$1.7 \times 10^{-6}$	$4.2 \times 10^{-6}$	$1.1 \times 10^{-5}$

### UPPER BOUND EFFECT OF RODS = $10^{-6}$

BWR	$\ll 10^{-6}$	$\ll 3 \times 10^{-6}$	$\sim 2.1 \times 10^{-5}$
PWR	$\ll 3 \times 10^{-6}$	$\ll 5 \times 10^{-6}$	$\sim 1.2 \times 10^{-5}$

### NRC CALCULATION OF ROD & EFFECT

EASTERLING, VESELY	BWR	$10^{-7}$	AT 99% S-C
EASTERLING	PWR	$2 \times 10^{-6}$	AT 99% S-C

## Limiting Transients for ATWS\*

- I. Babcock & Wilcox
  - A. Loss of offsite power (LOOP)
  - B. Total loss of feedwater (LOF)
  - C. Transients leading to LOF (LOL)
- II. Combustion Engineering
  - A. 2560 Mwt Core
    - 1. Uncontrolled rod withdrawal (CEA)
    - 2. Partial loss of feedwater (PLOF)
    - 3. Loss of load (LOL)
    - 4. Total loss of feedwater (LOF)
  - B. 3800 Mwt Core
    - 1. Uncontrolled rod withdrawal
    - 2. Partial loss of primary coolant flow (PPCF)
    - 3. Loss of load
    - 4. Total loss of feedwater
- III. Westinghouse (No transient yields results of significance but the most limiting transients are the following)
  - A. Loss of load
  - B. Total loss of feedwater
- IV. General Electric
  - Any transient leading to excessive pool temperatures (GE)

\* These transients have been specified by NRC in WASH 1270 and the Status Reports as being those which lead to excessive pressures.

Correspondence Between Significant ATWS  
Transients and Plant Transient Data

ATWS Transient

Plant Transient

PWR

PPCF

CEA

PLOF

LOF

LOL

LOOP

BWR

- |      |  |
|------|--|
| # 1* | Loss of RCS (1 Loop)                         |
| # 2  | Uncontrolled Rod Withdrawal                  |
| #15  | Loss or Reduction in Feedwater Flow (1 Loop) |
| #16  | Total Loss of Feedwater Flow (All Loops)     |
| #18  | Closure of All MSIV                          |
| #24  | Loss of Condensate Pumps (All Loops)         |
| #25  | Loss of Condenser Vacuum (LCV)               |
| #33  | Turbine Trip (TT)                            |
| #34  | Generator Trip (GT)                          |
| #35  | Loss of Station Power                        |
|      |  |
| # 1  | Load Rejection                               |
| # 3  | Turbine Trip                                 |
| # 5  | MSIV (All Loops)                             |
| # 8  | Loss of Condenser Vacuum                     |
| # 9  | Pressure Regulator Fails Open                |
| #10  | Pressure Regulator Fails Closed              |
| #20  | Feedwater, Increasing Flow at Power          |
| #24  | Feedwater, Low Flow                          |
| #31  | Loss of Offsite Power                        |
| #32  | Loss of Auxiliary Power                      |

\* This number refers to the detailed transient frequencies presented in EPRI NP 801

Reactor Median Transient Initiation  
Frequencies Relevant for ATWS

Events/Year

I. Babcock & Wilcox

1) LOOP	0.27
2) LOF	0.07
3) LOL	<u>1.11</u>

Sum =1.45

II. Combustion Engineering

a) 2560 Mwt Core

1) CEA	0.02
2) PLOF	0.45
3) LOL	1.11
4) LOF	<u>0.07</u>

Sum =1.65

b) 3800 Mwt Core

1) CEA	0.02
2) PPCF	0.13
3) LOL	1.11
4) LOF	<u>0.07</u>

Sum =1.23

III. Westinghouse (none of significance, but those most limiting are)

1) LOL	1.11
2) LOF	<u>0.07</u>

Sum =1.18

IV. General Electric

Sum =3.52




NEW STAFF TRANSIENTS

PWR

	<u>FREQUENCIES</u>		<u>SIGNIFICANCE</u>
	<u>TOTAL</u>	<u>25% POWER</u>	
STUCK VALVES	0.03	?	NONE
SAFETY INJECTION	0.04	0.01	NONE
FEEDWATER FLOW INSTABILITY	1.16	1.02	MAYBE
LOSS OF CIRCULATING WATER	0.07	0.08	YES
LOSS OF POWER TO NECESS. SYS.	0.21	0.05	NONE
LOW SECONDARY PRESSURE	0.06	0.04	NONE

BWR

STUCK VALVES (NO AUTO, SCRAM)	0.2	0.13
BYPASS VALVE FAILS OPEN	0.04	0.0
MSIV (1 LOOP)	0.08	0.07
LOSS OF FEEDWATER HEATING	0.02	0.0



COMPARING STAFF ESTIMATES OF AT FREQUENCIES WITH PLANT OPERATING EXPERIENCE

NUREG 0460 Estimate for BWR

NUREG 0460 for PWR

BWR Operating Experience

B&W

S1C

M&B

NO. OF ATWS TRANSMITS/REACTOR YEAR

YEARS SINCE COMMERCIAL


# C.E. 2611 MW Plant

LOFW/ATWS  
MSIV/ATWS

$\frac{LOFW}{w/aux\ feed}$   
 $\frac{MSIV}{o.w.o./aux\ feed}$

$\Delta$  MSIV  
w.o. aux feed

Initial  
Power  
Level  
100%




+ 50%  
+ 50%  
+ 50%

1.2  
4  
- M.T.C. x 10<sup>4</sup>

Peak Pressure (PSIA)

POOR ORIGINAL



Probability of Exceeding Pressure Limit  
For a B & W Loss of Feedwater

Limit = 3200 psi

Limit = 3750 psi

Power (% of Rated)

Probability, %

TABLE IX

Effect of Plant Generation on Transient Event Rates

Plant Type	Year of Operation		
	<u>1</u>	<u>2</u>	<u>3</u>
PWR's Greater than 6 years old	19.7	19.7	12.6
Less than 6 years old	16.9	10.3	7.8
BWR's Greater than 6 years old	20.3	5.5	5
Less than 6 years old	23.4	7	5

TABLE X

LWR Applicable At Frequencies

PWR	0.64 (0.24 w/100% bypass)
BWR	3.52 (1.22 w/> 30% bypass)
LWR	1.68 (0.60 w/appropriate bypass)

TABLE XI

Annual Frequency of ATWS (Pr(ATWS))

PWR	$3.2 \times 10^{-6}$ ( $1.2 \times 10^{-6}$ w/bypass)
BWR	$1.8 \times 10^{-5}$ ( $6.1 \times 10^{-6}$ w/bypass)
LWR	$8.4 \times 10^{-6}$ ( $3 \times 10^{-5}$ w/bypass)

MEDIAN ATWS FREQUENCIES

NRR STAFF	<u>W</u>	<u>CE</u>	<u>B&amp;W</u>	<u>GE</u>
0460 VOL 1-3	$2 \times 10^{-4}$	$2 \times 10^{-4}$	$2 \times 10^{-4}$	$2 \times 10^{-4}$
0460 VOL 4	$10^{-6}$ - $8 \times 10^{-5}$	$3 \times 10^{-5}$	$8 \times 10^{-5}$	$2 \times 10^{-4}$
EPRI	$\ll 10^{-6}$	$6-9 \times 10^{-6}$	$8 \times 10^{-6}$	$1.8 \times 10^{-5}$

Figure 6  
ATWS Event Sequences During  
the Fuel Cycle





Figure 7





APPENDIX

List of (Stuck Open) Pressurizer Valves

1. Palisades, 1971, PORV
2. Oconee 1, 1973, Block Valve
3. Oconee 3, 1975, PORV
4. Davis Besse, 1977, PORV
5. TMI-2, 1978, PORV
6. Cook 3, 1978, PORV
7. Ft. Calhoun, 1979, 2 PORV
8. TMI-2, 1979, PORV
9. Crystal River, 1980, <sup>POR</sup>~~Safety~~ Valve

- C - Failure of Containment Spray Injection System
- D - Failure of Emergency Core Cooling Injection
- F - Failure of Containment Spray Circulation System
- G - Failure of Containment Heat Removal System
- H - Failure of Emergency Core Cooling Recirculation System

$0 - t_1: TK \gg TKQX$   
 $t_1 - t_2: TKP < t_0 \ll TKQX$   
 $t_2$  onward: TKQX is the total risk

Westinghouse	B&W	Combustion
● Loss of external Load	● Loss of External Load	● Loss of External Load
● Turbine Trip	● Turbine Trip	● Turbine Trip
● Loss of Normal Feedwater	● Loss of Normal Feedwater	● Loss of A.C. Power
● Loss of all A.C. Power	● Cold Pressurization	● Cold Pressurization
● Cold Pressurization		

$$\begin{aligned}
 S_2D &= 9 \times 10^{-6} / \text{Reactor Year} \\
 S_2F &= 1 \times 10^{-7} / \text{Reactor Year} \\
 S_2G &= 9 \times 10^{-8} / \text{Reactor Year} \\
 S_2H &= 6 \times 10^{-6} / \text{Reactor Year} \\
 S_2C &= 2 \times 10^{-6} / \text{Reactor Year}
 \end{aligned}$$

$$\begin{aligned}
 D &= 9 \times 10^{-3} / \text{demand} \\
 F &= 1 \times 10^{-4} / \text{demand} \\
 G &= 9 \times 10^{-5} / \text{demand} \\
 H &= 6 \times 10^{-3} / \text{demand} \\
 C &= 2 \times 10^{-3} / \text{demand}
 \end{aligned}$$

hence that

$$(T \cdot Q) (D + F + G + H + C) \equiv T \cdot QX = 5 \times 10^{-4}$$

TK vs. TKQX + T\*QX

Since  $K \ll 1$ , we can neglect (for now) TKQX. NUREG 0460<sup>+</sup> estimates

$$TK = 1.6 \times 10^{-4} / \text{Reactor Year}$$

Since  $T*QX = 5 \times 10^{-4} / \text{Reactor Year}$ , valve failures to reset already dominate ATWS risk hence any additional valves can only increase the risk.

C - Surry does not contain fan coolers; for plants with fans as well as sprays C is negligible.

D - Plant changes should not significantly affect this parameter.

F - Plant variations imply that F and H are coupled hence that F should not be called out separately; since  $H \gg F$  this does not impact.

G,H - Plant variations do not indicate that these should change significantly.

With these considerations we recalculate T\*QX for non-Surry type of plants to be

$$X = 1.1 \times 10^{-2} / \text{demand}$$

and

$$T*QX = \frac{1.6}{5} \times 10^{-4} / \text{reactor year}$$

hence for non-Surry plants ATWS is still only  $\frac{1}{2}$  of T\*QX hence additional valves will increase risk. If we use  $t_1 = 0.4$  the Q failure core melt probability dominates ATWS by a factor of 10.

Release as Equivalent Iodine-131

$$\frac{\text{PWR-3}}{\text{PWR-5}} = 20$$

$$\frac{\text{PWR-3}}{\text{PWR-7}} = 20,000$$

$$\text{TK} = 1.6 \times 10^{-4} / \text{year}$$

The containment failure modes for ATWS by Category are then

$$\text{Category 7} \quad \text{TK-}\epsilon = 1.6 \times 10^{-4}$$

$$\text{Category 5} \quad \text{TK-}\beta = 6.4 \times 10^{-7}$$

The total ATWS risk is

$$(\text{TK-}\epsilon) C_7 + (\text{TK-}\beta) C_5$$

$$(\text{T} \cdot \text{Q}(\text{D}+\text{H})^{-\alpha} + \text{T} \cdot \text{Q}(\text{F}+\text{C}+\text{G})^{-\delta} + \text{TKQ}^{-\alpha}) C_3$$

and the risk ratio is

$$\frac{\text{Competing Risk}}{\text{ATWS Risk}} = \frac{\{\text{T} \cdot \text{Q}[(\text{D}+\text{H})^{-\alpha} + (\text{F}+\text{C}+\text{G})^{-\delta}] + \text{TKQ}^{-\alpha}\} C_3}{[\text{TK}(\epsilon C_7 + \beta C_5)] t_1}$$

Quantifying this relation

$$\frac{\text{Completing Risk}}{\text{ATWS Risk}} = \frac{6.6 \times 10^5 C_3}{6.4 \times 10^{-5} (.004 C_5 + C_7)}$$

$$\approx 5000$$

neglecting C and F for non surry types of plants

$$= \frac{7.2 \times 10^5 C_3}{6.4 \times 10^{-5} [.004 C_5 + C_7]}$$

$$= 522$$

# CRYSTAL RIVER

1. T\*Q is a B<sub>4</sub> (small-small) LOCA

2.

B <sub>4</sub> Seq #	MELT Prob given B <sub>4</sub>	TYPE
2	$1.3 \times 10^{-2}$	ECC Recirc. Fails (H)
6	$1.2 \times 10^{-3}$	Bldg Spray and ECC Recirc (F+H)
9	$7.2 \times 10^{-3}$	ECC Injection Fails (D)
20	$2.6 \times 10^{-3}$	Bldg Spray & Recirc Fails (C+H)
23	$1.0 \times 10^{-2}$	Bldg Spray and ECC fails (C+D)

$$\Sigma = 3.4 \times 10^{-2}$$

$$T^*Q \times X = 1.02 \times 10^{-3}$$

## Risk

$$\frac{\text{Now ATWS}}{\text{ATWS}} = \frac{(S_2 + S_{23})(\alpha C_1 + \delta C_2) + (S_6 + S_9 + S_{20} + S_{23})\epsilon C_6 + S_9 \epsilon C_7}{TK t_1 (\beta C_5 + \delta C_7)}$$

$$= 10000$$

POOR ORIGINAL

PRESENTATION  
TO  
U.S. NUCLEAR REGULATORY COMMISSION  
ON  
ANTICIPATED TRANSIENTS WITHOUT SCRAM

OCTOBER 28, 1980  
DR. D. CLARK GIBBS

MY NAME IS CLARK GIBBS. I AM DIRECTOR OF NUCLEAR ACTIVITIES FOR MIDDLE SOUTH SERVICES AND VICE PRESIDENT OF MIDDLE SOUTH ENERGY, INC., THE OWNER OF THE GRAND GULF NUCLEAR STATION. I AM HERE TODAY AS CHAIRMAN OF THE AIF COMMITTEE ON REACTOR LICENSING AND SAFETY. I AM ALSO A MEMBER OF THE AIF POLICY COMMITTEE ON NUCLEAR REGULATION AND THE EEI EXECUTIVE ADVISORY COMMITTEE ON NUCLEAR POWER. THE STATEMENT ON ATWS THAT I SHALL MAKE BEFORE YOU TODAY HAS THE ENDORSEMENT OF THESE AIF AND EEI COMMITTEES AS WELL AS THE MEMBERS OF THE APPA NUCLEAR POWER TASK FORCE WHICH CURRENTLY OWN AND OPERATE NUCLEAR POWER PLANTS ON THEIR SYSTEMS.

I WILL BE READING MY PREPARED PRESENTATION TO YOU BECAUSE OF THE ORGANIZATIONS WHICH I REPRESENT HERE AND THE NEED FOR THEIR CONSIDERED REVIEW OF MY REMARKS. SHOULD YOU HAVE QUESTIONS DURING THESE PREPARED REMARKS, DO NOT HESITATE TO INTERRUPT ME. I AM JOINED HERE TODAY BY FRED STETSON OF THE AIF STAFF, JERRY SORENSEN, CHAIRMAN OF THE AIF ATWS SUBCOMMITTEE, AND DR. ANTHONY BUHL, VICE PRESIDENT OF TECHNOLOGY FOR ENERGY CORPORATION, WHO WILL ASSIST AS NECESSARY IN DEALING WITH YOUR QUESTIONS. ALSO PRESENT ARE OTHERS FROM THE INDUSTRY WHOM I MAY CALL UPON SHOULD THE NEED ARISE.

BOTH THE NRC AND THE INDUSTRY ARE VITALLY INTERESTED IN THE SAFETY OF NUCLEAR POWER, LARGELY FOR THE SAME REASONS. THOSE OF US WHO ADVOCATE CONTINUED AND EXPANDED USE OF NUCLEAR



POWER HAVE GROWN ACCUSTOMED TO THE ATTENTION TO DETAIL, ENERGY, AND COMMITMENT THAT THE ASSURANCE OF NUCLEAR SAFETY REQUIRES. WE WELL UNDERSTAND THE POTENTIAL CONSEQUENCES OF ERRORS IN JUDGEMENT ON PUBLIC ACCEPTANCE, UNIT AVAILABILITY, AND COST COMPARISONS WITH ALTERNATIVES. THOSE OF US WHO ARE OWNERS OF THESE PLANTS ARE KEENLY AWARE OF THE IMPORTANCE THAT OUR RATEPAYERS WHO LIVE IN THE ENVIRONS OF OUR PLANTS ATTACH TO NUCLEAR SAFETY. WE HAVE NOT FAILED TO OBSERVE AS WELL THE HIDEOUS FINANCIAL IMPACT ATTENDANT WITH AN EVENT WHICH COMPROMISES OUR ABILITY TO PROVIDE ADEQUATE COOLING FOR THE REACTOR CORE. WE HAVE EVERY REASON TO BE THE MOST COMMITTED TO NUCLEAR SAFETY OF ANY ORGANIZATION PARTICIPATING IN ITS USE.

IT IS FROM THAT PERSPECTIVE WHICH WE VIEW THE ATWS ISSUE, ONE WHICH HAS CONFOUNDED OVER 10 YEARS OF ATTEMPTED RESOLUTIONS. WE BELIEVE THAT THE UNDERLYING REASON FOR THE INORDINATE LENGTH OF TIME AND EFFORT THAT HAS ALREADY BEEN EXPENDED ON THIS SUBJECT AND WHICH HAS BEEN FREQUENTLY SPICED WITH ACERBIC DIALOG IS THAT IT IS AN UNPRECEDENTED ATTEMPT TO PROVIDE PROTECTION FOR A SINGLE EXTREMELY SMALL PROBABILITY EVENT, FROM AMONG A HOST OF OTHERS WHICH MAY HAVE A GREATER PROBABILITY OF OCCURRENCE AND FOR WHICH THE CONSEQUENCES ARE LIKELY TO BE MORE SEVERE. WE WISH TO ENHANCE AS NECESSARY THE SAFETY AND OPERABILITY OF OUR PLANTS IN A FASHION WHICH IS SELF CONSISTENT, AND OBJECTIVELY ALLOCATES OUR RESOURCES TOWARD THE

ACHIEVEMENT OF A WELL UNDERSTOOD SAFETY GOAL BASED UPON A FIRM FOUNDATION OF ANALYSIS OF BENEFITS AND COMPETING SOCIETAL RISKS. IN FACT, IT APPEARS TO US THAT THE TREATMENT OF THIS SUBJECT BY THE NRC STAFF HAS BEEN CLEARLY OVERTAKEN BY THE EVENTS WHICH HAVE OCCURRED SINCE THE ACCIDENT AT TMI. THE SPECIFIC EVENTS TO WHICH I ALLUDE ARE THE RENEWED INTEREST IN THE ESTABLISHMENT OF QUANTITATIVE SAFETY GOALS, THE ONGOING AND PLANNED PROBABILISTIC ASSESSMENT STUDIES AND THE PLANNED DEGRADED CORE RULEMAKING. IT IS FROM THESE ACTIVITIES THAT WE PROPOSE THAT THE ULTIMATE RESOLUTION OF ATWS BE DERIVED.

IN THE INTEREST OF EXPANDING UPON THIS PROPOSAL WE SUGGEST THAT THE FIRST PREREQUISITE FOR A FINAL ATWS RESOLUTION IS THE DEFINITION OF A SAFETY GOAL FOR NUCLEAR POWER PLANT REGULATION. THE OPTIMUM ATWS RESOLUTION INVOLVES THE REDUCTION OF RISKS THAT ARE ALREADY VERY SMALL. SINCE IT IS IMPOSSIBLE TO REDUCE RISKS TO ZERO, WE CONTINUE TO BE CONFRONTED WITH THE QUESTION, "HOW SAFE IS SAFE ENOUGH?" ALTHOUGH, OF NECESSITY, THE LACK OF A SAFETY GOAL HAS NOT PRECLUDED RULEMAKING IN THE PAST, IT WOULD BE UNWISE TO IGNORE SAFETY GOAL GUIDANCE THAT SHOULD SOON BE AVAILABLE. RECENT RECOGNITION THAT SUCH GUIDANCE IS ESSENTIAL SUGGESTS THAT IT WILL BE AVAILABLE IN TIME TO GUIDE A FINAL ATWS RESOLUTION. I SHOULD POINT OUT AT THIS JUNCTURE THAT THE AIF COMMITTEE ON REACTOR LICENSING AND

SAFETY HAS RECENTLY COME FORWARD WITH A PROPOSED SAFETY GOAL BEFORE THE ACRS WHICH HAS RECEIVED SUPPORT WITHIN THE INDUSTRY.

A SECOND PREREQUISITE FOR A FINAL ATWS RESOLUTION IS FURTHER WORK ON PROBABILISTIC RISK ASSESSMENT ANALYSIS. THE LAST COMPREHENSIVE PRA WHICH HAS BEEN PERFORMED AND WIDELY CIRCULATED AND WHICH TREATS ATWS AMONG ALL THE OTHER EVENTS THAT CAN LEAD TO DEGRADED CORE COOLING CONDITIONS WAS WASH-1400. THAT STUDY SUGGESTED THAT THE RISK FROM ATWS EVENTS IN LWR'S WAS SMALL. OTHER NRC STUDIES SUCH AS THE FOUR VOLUMES OF NUREG 0460 HAVE TREATED ATWS IN GREATER DETAIL THAN WASH-1400 BUT HAVE DONE SO IN ISOLATION OR HAVE COMPARED A REVISED ATWS RISK WITH UNMODIFIED WASH-1400 VALUES FOR COMPETING RISKS. THIS IS CLEARLY INAPPROPRIATE AND PARTICULARLY SO IN VIEW OF THE SIGNIFICANT WORK UNDERWAY AND PLANNED TO EXPAND THE BASE OF OUR KNOWLEDGE IN THE AREA OF PRA. WITHIN THE INDUSTRY A GROWING NUMBER OF PRA EVALUATIONS ARE SCHEDULED FOR COMPLETION IN THE NEAR FUTURE THAT WILL PROVIDE INSIGHTS ON ATWS.

THE THIRD PREREQUISITE FOR FINAL ATWS RESOLUTION IS THE INTEGRATION OF ATWS INTO THE PLANNED DEGRADED CORE RULEMAKING. THIS RULEMAKING WILL DETERMINE WHETHER AND TO WHAT EXTENT DEGRADED CORE OR CORE MELT ACCIDENTS MUST BE CONSIDERED IN SAFETY ANALYSES. THE END RESULT OF THIS PROCESS MAY BE A RULE THAT WILL AMEND 10 CFR 50 TO REQUIRE CHANGES IN PLANT DESIGN OR

PROCEDURES THAT WILL IMPROVE THE CAPABILITY OF LIGHT WATER REACTORS TO PREVENT, RESPOND TO, OR ACCOMMODATE THE EFFECTS OF ACCIDENTS RESULTING IN A DEGRADED REACTOR CORE.

AS NOTED ABOVE, THE INDUSTRY DOES NOT BELIEVE THAT FINAL ATWS RESOLUTION CAN BE ACHIEVED INDEPENDENT OF THE DEGRADED CORE RULEMAKING. A SYSTEMATIC SAFETY EVALUATION OF A NUCLEAR POWER PLANT SHOULD CONSIDER ALL THE SEQUENCES AND SUGGESTED MODIFICATIONS IN PERSPECTIVE. IN THIS MANNER WE CAN DIRECT OUR ATTENTION AND RESOURCES TO THE DOMINANT SEQUENCES THAT IMPACT SAFETY AS WELL AS TO EVENTS THAT COULD RESULT IN OTHER SEVERE CONSEQUENCES. BECAUSE THE SAME ISSUES AND FACTS ARE CRUCIAL TO EACH, ATWS IS SIMPLY A SUB PART OF THE DEGRADED CORE MATTER; WE RECOGNIZE THAT THE RISK OF ATWS, TO THE EXTENT THAT THERE IS ANY SIGNIFICANT RISK, IS ONE OF DEGRADED CORE. WE RECOGNIZE THAT ATWS IS ONE RELATIVELY LOW-PROBABILITY EVENT AMONG MANY THAT COULD CONCEIVABLY LEAD TO A DEGRADED CORE. ACCORDINGLY, THERE SEEMS TO BE NO SOUND REASON FOR SEEKING FINAL ATWS SOLUTIONS FOR PLANTS IN ISOLATION FROM OTHER DEGRADED CORE EVENTS.

WE WOULD PREFER TO AVOID CONTINUED DIALOG ON ATWS INDEPENDENTLY, AND THEREFORE PROPOSE THAT THE MATTER BE DISPOSED OF NOW IN A FASHION WHICH IS SUPPORTED BY THE RECORD AND RESULTS IN SUBSTANTIAL REDUCTION OF ATWS RISK. THE STAGE HAS BEEN SET TO TREAT THE RESIDUAL ATWS RISK IN THE DEGRADED

CORE COOLING RULEMAKING IN A FASHION WHICH WILL BE ACCEPTABLE TO THE INDUSTRY AND IN PARTICULAR, TO THE OWNERS OF THESE PLANTS.

THERE REMAINS THE QUESTION OF WHAT CAN AND SHOULD BE DONE NOW. THE STAFF HAS RECENTLY PROPOSED AN ATWS RULE AND REGULATORY GUIDE CONTAINED IN SECY-80-409. YOU HAVE ALSO BEEN SERVED WITH A PETITION FOR RULEMAKING BY THE ATWS UTILITY GROUP REPRESENTING 20 DOMESTIC ELECTRIC UTILITY COMPANIES. THE TWO PROPOSED RULES ARE QUITE SIMILAR INSOFAR AS SPECIFIC SHORT TERM HARDWARE REQUIREMENTS ARE CONCERNED. BEYOND THAT, THEY DIVERGE. IN THE LONGER TERM, THE STAFF PROPOSES TO SPECIFY CRITERIA RATHER THAN MITIGATING HARDWARE. WE BELIEVE THIS IS A SIGNIFICANT POSITIVE STEP AND THAT A FINAL RULE WHICH MAY EVOLVE AS A PRODUCT OF THE DEGRADED CORE RULEMAKING SHOULD RIGHTFULLY ADDRESS ITSELF TO CRITERIA RATHER THAN HARDWARE.

HOWEVER, THE PROPOSED CRITERIA ARE PREMATURE AND AS A RESULT, DEFICIENT. IN OUR JUDGEMENT, THE STAFF PROPOSALS DO NOT PROVIDE CLOSURE OF THE ATWS ISSUE. THE PROPOSED REGULATORY GUIDE WILL AFFORD TO THE STAFF UNRESTRICTED OPPORTUNITIES FOR IMPOSING FURTHER REGULATORY REQUIREMENTS WHICH WILL INEVITABLY RESULT IN ATWS BECOMING A DESIGN BASIS EVENT FOR STRUCTURES, SYSTEMS AND COMPONENTS WITH IMPLICATIONS FAR BEYOND THAT OF WHICH ANY OF US TODAY ARE CAPABLE OF IMAGINING. THE APPEARANCE OF A NEW DESIGN BASIS EVENT VIRTUALLY GUARANTEES SUBSTANTIAL

IMPACTS ON THE RESOURCES OF BOTH THE NRC AND INDUSTRY FOR MANY YEARS IN THE FUTURE.

THE PROPOSED INTEGRAL PLANT AND SEPARATE EFFECTS TESTING IDENTIFIED IN THE REGULATORY GUIDE ARE BRIEFLY OUTLINED AS TO PURPOSE ONLY. THERE IS NO WAY OF INTELLIGENTLY EVALUATING WHAT IS EXPECTED OF US FROM THESE PURPOSE STATEMENTS AND CERTAINLY NOT IN THE TIME ALLOWED FOR IN THE SCHEDULE WHICH I WILL ADDRESS LATER. FURTHER, THE APPEARANCE OF THESE TESTS IS ADDITIONAL EVIDENCE THAT THE STAFF IS MOVING IN THE DIRECTION OF TREATING ATWS AS A DESIGN BASIS EVENT AFTER THE FASHION OF THE DESIGN BASIS LOSS OF COOLANT ACCIDENT, A PRACTICE WHICH LED TO SOME OF THE UNFAVORABLE FINDINGS OF THOSE CHARGED WITH THE TASK OF EVALUATING NRC'S PERFORMANCE FOLLOWING THE TMI ACCIDENT. THE STAFF PROPOSALS ARE PARTICULARLY DEFICIENT IN THE ASSOCIATED VALUE-IMPACT ANALYSES, PROPOSED SCHEDULE FOR IMPLEMENTATION, AND ATTENTION TO DETAIL WHERE CONTRADICTIONS CLEARLY EXIST ON THE RECORD.

BEGINNING WITH VALUE-IMPACT, THE NUCLEAR REGULATORY COMMISSION HAS ADOPTED A POLICY, "THAT VALUE-IMPACT ANALYSIS WILL BE CONDUCTED FOR ANY PROPOSED REGULATORY ACTIONS THAT MIGHT IMPOSE A SIGNIFICANT BURDEN ON THE PUBLIC (WHERE THE TERM PUBLIC IS DEFINED IN ITS BROADEST SENSE)." CONSISTENT WITH THIS POLICY, THE NRC STAFF HAS ATTEMPTED TO DEVELOP THE REQUIRED VALUE-IMPACT ANALYSIS FOR ATWS. THE STAFF'S EFFORT TO

DATE, HOWEVER, HAS NOT BEEN ADEQUATE. THE MAJOR DEFECTS INCLUDE FIRST, FAILURE TO REALISTICALLY CONSIDER THE CONSUMER IMPACTS ASSOCIATED WITH MAJOR BACKFITS AND EXTENDED OUTAGES THAT WILL INCREASE THE COST OF ELECTRIC POWER. THE STAFF REPORTS IN SECY-80-409 THAT IT IS THEIR JUDGEMENT THAT EXTENDED DOWNTIME REQUIRED TO RETROFIT WILL LIKELY BE MINIMAL. IN VIEW OF THE APPARENT NEED TO PROVIDE ADDITIONAL RELIEF VALVE CAPACITY TO MEET THE ACCEPTANCE CRITERIA OF THE PROPOSED RULE IN B&W AND COMBUSTION DESIGNED PLANTS, THIS STATEMENT IS PROFOUNDLY IN ERROR.

A RECENT STUDY PERFORMED AT DUKE POWER COMPANY INDICATES THAT A MINIMUM OF 31 DAYS OF ADDITIONAL DOWN TIME WOULD BE REQUIRED TO MAKE THE PRESSURIZER MODIFICATIONS ON OCONEE NECESSARY TO PROVIDE THE ADDITIONAL RELIEF PROTECTION MANDATED BY THE ACCEPTANCE CRITERIA ASSUMING ABSOLUTELY NO PROBLEMS, A MOST UNLIKELY ASSUMPTION. THE STUDY FURTHER ESTIMATES THAT THIS UNAVAILABILITY WOULD BE LIKELY TO GROW TO 65 DAYS IF EXPECTED PROBLEMS MANIFEST THEMSELVES SUCH AS DIFFICULTY IN REMOVING THE PRESSURIZER MANWAY, OR REPAIR OF INDICATIONS ON THE NOZZLE WELDS. APPROXIMATELY 360 MAN-REM OF OCCUPATIONAL EXPOSURE WOULD BE INVOLVED ON EACH UNIT. USING 2000 \$ PER OCCUPATIONAL MAN-REM AND \$200 K PER UNIT PER DAY COST OF REPLACEMENT POWER, WHICH FOR DUKE IS NEARLY ALL COAL, THEY ESTIMATE A \$25M IMPACT ON THEIR THREE OCONEE UNITS EXCLUSIVE OF

ENGINEERING AND EQUIPMENT COSTS. IT IS IMPORTANT TO POINT OUT THAT OCONEE OPERATION HAS BEEN RELATIVELY FREE OF FUEL FAILURES AND THEIR RESULTANT EXPOSURES WILL BE CONSIDERABLY BELOW THE AVERAGE WHEN PLANTS WHICH HAVE EXPERIENCED OPERATION WITH FAILED FUEL ARE TAKEN INTO ACCOUNT.

IN ADDITION, THE OCONEE CONTAINMENT IS RELATIVELY UNCONGESTED, MINIMIZING THE INTERFERENCE PROBLEM WHICH WILL BE EXPERIENCED BY OTHERS. ANY OTHER UTILITIES WILL BE REQUIRED TO USE OIL AS A REPLACEMENT FUEL. IT IS THEREFORE JUDGED THAT THE DUKE ESTIMATES PROBABLY REPRESENT A LOWER BOUND ON THE COST OF THIS SINGLE MODIFICATION TO THE CE AND B&W DESIGNED REACTORS. BECAUSE OF THE SENSITIVITY OF THIS ANALYSIS TO COST OF REPLACEMENT POWER AND OUTAGE TIME, THE ULTIMATE RELATIVE IMPACT TO SOME UTILITIES MAY BE A FACTOR OF 5 OR MORE GREATER THAN THAT SUGGESTED BY THE DUKE STUDY.

ANOTHER CONSIDERATION IS THAT THE FULL IMPLEMENTATION OF THE NRC PROPOSED RESOLUTION MAY ALSO REDUCE SYSTEM AVAILABILITY AND RELIABILITY BY MAKING NUCLEAR PLANTS MORE COMPLEX AND, THEREFORE MORE SUBJECT TO MALFUNCTION WHEN EVENTS SUCH AS INADVERTENT INITIATION OF THE AUTOMATIC SLCS ARE TAKEN INTO ACCOUNT.

A SECOND DEFICIENCY IN THE VALUE-IMPACT ANALYSIS IS THE FAILURE TO CONSIDER THE INCREASED RISKS FROM ACCIDENTS OTHER THAN ATWS THAT WOULD BE IMPOSED BY CERTAIN OF THE STAFF'S



ALTERNATIVES. THIRD, THE VALUE IMPACT INFORMATION CONTAINED IN SECY-80-409 IS NEARLY IMPOSSIBLE TO FOLLOW OR UNDERSTAND. DISCUSSIONS OF VALUE IMPACT ESTIMATES ARE CONTAINED IN ENCLOSURES B, F, AND H OF THE DOCUMENT. THESE DISCUSSIONS ARE DISJOINTED AND CONFUSING, REFERRING TO ONE OR MORE DIFFERENT VOLUMES OF NUREG 0460 WITH VARIOUS DESIGNATIONS FOR THE PROPOSED FIXES AND CONTAIN UNFOUNDED AND EXCESSIVE DOLLAR VALUES FOR MAN-REM EXPOSURE. FURTHER, THE DETAILS OF THE MODIFICATIONS ASSUMED AS THE BASIS FOR THE IMPACT ESTIMATES ARE NOT STATED.

FOURTH, THE FAILURE TO RECOGNIZE THAT FEW ATWS EVENTS HAVE THE POTENTIAL OF LEADING TO SEVERE ATWS CONSEQUENCES, THAT A LIMITED SET OF SEVERE ATWS EVENTS WOULD RESULT IN MAJOR CORE DEGRADATION, AND THAT NOT ALL MAJOR CORE DEGRADATIONS EXCEED 10 CFR 100 GUIDELINES FURTHER RESULTS IN THE VALUES BEING SIGNIFICANTLY OVERESTIMATED AND IS NOT APPROPRIATE FOR VALUE IMPACT ANALYSIS.

TURNING NOW TO THE SCHEDULE PROPOSED IN SECY-80-409, IT IS SAFE TO ASSERT THAT IT IS UNACHIEVABLE AND UNJUSTIFIED IN VIEW OF THE NUMBER OF ISSUES THAT REMAIN OPEN. WE ARE BEING ASKED TO SUBMIT EVALUATION MODELS AND PLANS FOR CONFIRMATORY TESTING BY MARCH 1, 1981, AND TO PROPOSE NECESSARY MODIFICATIONS TO MEET THE CRITERIA BY JULY 1, 1981. IT IS CLEAR THAT SUCH A SCHEDULE ALLOWS NO TIME TO DO ANYTHING OTHER

THAN FALL BACK TO THE PRESCRIBED HARDWARE "FIXES" SO MUCH IN EVIDENCE IN NUREG-0460 VOLUME 4. IF CRITERIA SIMILAR TO THOSE PRESENTED IN THE PROPOSED RULE ARE ULTIMATELY DETERMINED TO BE NECESSARY, SUBSTANTIALLY MORE TIME WILL BE REQUIRED TO TEST ALTERNATIVE SOLUTIONS, PERFORM THE DETAILED ENGINEERING, AND PERFORM THE NECESSARY RELIABILITY ANALYSES TO GIVE US CONFIDENCE THAT WE ARE NOT "FIXING" OUR PLANTS IN A FASHION THAT WILL DEGRADE RATHER THAN ENHANCE SAFETY. AGAIN, WE NEED MORE EXPERIENCE WITH PRA METHODOLOGY AND IMPLEMENTATION ACQUIRED ON BASE STUDIES BEFORE WE BEGIN TO APPLY ITS RESULTS TO MAKING MODIFICATIONS TO OUR PLANTS.

THE SCHEDULE FURTHER REQUIRES THAT BWR MODIFICATIONS REQUIRED TO MEET THE ACCEPTANCE CRITERIA BE COMPLETE BY JULY 1, 1982. ON THE BASIS OF A PROPOSAL I HAVE RECEIVED FROM THE AFFECTED VENDOR IN THIS CASE, I KNOW THIS TO BE UNACHIEVABLE. WE EXPECT THE SAME TO APPLY TO THE PWR'S. FINALLY, THE SIGNIFICANT PRESSURE BOUNDARY WORK THAT MAY BE REQUIRED ON THE AFFECTED PWR'S IS TO BE COMPLETE BY JANUARY 1, 1984. SHOULD PRESSURE BOUNDARY BACKFITTING IN FACT BE REQUIRED, THERE IS A TIME FOR DOING THAT, AND IT IS DURING THE 10 YEAR IN-SERVICE INSPECTION. RESERVING ANY SUCH MODIFICATIONS FOR THAT INSPECTION AVAILABILITY WILL SUBSTANTIALLY REDUCE THE IMPACT TO THE RATEPAYER FROM NUCLEAR PLANT DOWN TIME.

OUR PROBLEMS WITH THE ACHIEVABILITY OF THE SCHEDULE ARE NOT LIMITED TO THE PLANTS WHICH NOW HAVE OR EXPECT OPERATING LICENSES BY JANUARY 1, 1984. FOR EXAMPLE, USING THE PROPOSED SCHEDULE, THE APPLICANT FOR A NUCLEAR UNIT EXPECTING TO RECEIVE AN OPERATING LICENSE IN JANUARY, 1984, SHOULD HAVE SUBMITTED PROPOSALS FOR COMPLYING WITH THE RECENTLY ANNOUNCED CRITERIA IN JANUARY, 1979.

WE SEE NO REASON FOR INCLUDING DETAILED IMPLEMENTATION SCHEDULES IN RULES AND SUGGEST THAT SUCH A PRACTICE NOT BE CONTINUED HERE. THE STAFF CERTAINLY HAS AT THEIR DISPOSAL ALTERNATIVES TO THE ESTABLISHMENT OF SUCH SCHEDULES SHORT OF INCLUDING THEM IN THE RULES.

ANOTHER MAJOR DEFICIENCY CONCERNS THE QUESTION OF THE STAFF'S LACK OF ATTENTION TO TECHNICAL DETAIL. A MAJOR PORTION OF INDUSTRY PERCEIVES THE STAFF'S "ENGINEERING JUDGEMENT" IN THIS AREA TO BE DEFICIENT. FOR EXAMPLE, THE STAFF ASSUMES THAT ALL ATWS EVENTS THAT COULD LEAD TO A CORE MELT WILL EXCEED 10 CFR 100 LIMITS. THESE ASSUMPTIONS ARE OVERLY CONSERVATIVE. THEY IGNORE THE FACT THAT EXCEEDING STRESS LEVEL C REQUIREMENTS OR EXCEEDING AN ARBITRARY TEMPERATURE LIMIT IN A BWR TORUS, DOES NOT NECESSARILY LEAD TO CORE MELT, AND CORE MELT DOES NOT NECESSARILY LEAD TO VIOLATION OF CONTAINMENT INTEGRITY OR TO EXCEEDING THE 10 CFR 100 LIMITS. THEY HAVE NOT TAKEN INTO ACCOUNT ANY OPERATOR ACTION WHICH, FOR SUCH AN EVENT, WOULD BE

A CERTAINTY. THEY OVERESTIMATE THE NUMBER OF SIGNIFICANT EVENTS BECAUSE: (A) BELOW A CERTAIN POWER LEVEL, THE CONSEQUENCES OF AN ATWS ARE NOT SIGNIFICANT; (B) MANY ANTICIPATED TRANSIENTS WHEN COMBINED WITH A FAILURE TO SCRAM DO NOT LEAD TO BOUNDING CONSEQUENCES; (C) THE CONSEQUENCES ARE A FUNCTION OF TIME IN CYCLE; (D) NOT ALL ATWS EVENTS WILL NECESSARILY CAUSE A COMPLETE FAILURE OF THE REACTOR SHUTDOWN SYSTEM; (E) AN ATWS EVENT NEED NOT NECESSARILY CAUSE A FAILURE OF THE REACTOR CONTROL SYSTEM; AND (F) AS THE EXPERIENCE LEVEL RISES WITH ADDED YEARS OF OPERATION, THE NUMBER OF SIGNIFICANT EVENTS FALLS FOR CERTAIN CATEGORIES OF INITIATING EVENTS AS A RESULT OF THE LEARNING CURVE. THE STAFF HAS NOT TREATED IN APPROPRIATE DETAIL EVIDENCE THAT SOME OF THE MEASURES THAT HAVE BEEN RECOMMENDED TO DECREASE THE ATWS RISK MAY, IN FACT, INCREASE COMPETING RISKS, THUS, LOWERING OVERALL SAFETY.

APPROXIMATELY 20 UTILITIES REPRESENTING ABOUT 60 PLANTS HAVE PROPOSED A SOLUTION RECENTLY IN THE FORM OF A PETITION FOR RULEMAKING ON ATWS. PART 1 OF THE PETITION PROPOSES MODIFICATIONS THAT ARE STRAIGHTFORWARD AND WELL UNDERSTOOD BY THE INDUSTRY AND THE NRC STAFF. THUS, THESE MODIFICATIONS WILL NOT REQUIRE GREAT EXPENDITURES OF RESOURCES FOR TECHNICAL ANALYSIS, AND THEY CAN BE IMPLEMENTED QUICKLY. BECAUSE A SUBSTANTIAL PORTION OF THE INDUSTRY IS ALREADY WILLING TO MAKE THESE MODIFICATIONS IF THEY WILL RESOLVE THE ATWS ISSUE FOR

EXISTING PLANTS, THERE IS NOT LIKELY TO BE MUCH REGULATORY EFFORT REQUIRED TO IMPOSE THEM. MOST IMPORTANT OF ALL, THE PROPOSED MODIFICATIONS CLEARLY DECREASE THE RISK OF ATWS WHILE MINIMIZING OTHER, COMPETING RISKS.

IN ADDITION, THE PETITION PROPOSES THAT IF THE COMMISSION ELECTS TO PROPOSE ATWS MODIFICATION BEYOND THOSE IN PART 1 OF THE PETITION, THEN ALL CONCERNED WILL FIND THEMSELVES IN A MORASS OF UNANSWERED QUESTIONS DEMANDING IMMEDIATE ANSWERS AND EXCESSIVE NRC AND INDUSTRY MANPOWER REQUIREMENTS. CHIEF AMONG THESE QUESTIONS WILL BE WHETHER THE ADDITIONAL POTENTIAL MODIFICATIONS, IF IMPLEMENTED, WOULD LEAVE THE PUBLIC MORE SAFE OR LESS SAFE. THE PETITIONERS INDICATE THAT NOTHING SHORT OF AN ATWS RULEMAKING INVOLVING ADJUDICATORY PROCEDURES COULD PROVIDE THE ANSWER. THE PETITIONERS URGE THAT SUCH A RULEMAKING BE HELD IF ATWS MODIFICATIONS BEYOND THOSE IN PART 1 OF THE PETITION ARE, IN FACT, TO BE CONSIDERED NOW.

WE FEEL THAT SUCH ACTION COMING AT THIS TIME ON THIS EVENT WOULD BE UNWISE AND COUNTERPRODUCTIVE. DOING SO WOULD BE AN ATTEMPT TO PROVIDE THE ULTIMATE RESOLUTION OF ATWS IN ISOLATION FROM ALL OTHER DEGRADED CORE SCENARIOS. ONE OF THE FIRST LESSONS LEARNED FROM THREE MILE ISLAND WAS THAT NRC AND THE INDUSTRY HAD CONCENTRATED TOO MUCH ON LOW PROBABILITY EVENTS. WE SHOULD NOT FORGET THIS LESSON IN OUR EFFORTS TO IMPROVE THE SAFETY OF OUR PLANTS.

IN CONCLUSION, THE ORGANIZATIONS THAT I REPRESENT HERE TODAY HEREBY RECOMMEND THE FOLLOWING:

- FIRST: THAT THE STAFF PROPOSED ACCEPTANCE CRITERIA FOR ANALYSIS OF ATWS MITIGATION CAPABILITY ALTHOUGH WELL INTENDED, ARE PREMATURE, AND SHOULD NOT BE ADOPTED AT THIS TIME.
- SECOND: THAT THE COMMISSION ACCEPT THE UTILITIES' PROPOSAL CONTAINED IN PART I OF THE ATWS UTILITY GROUP PETITION. DOING SO WILL REDUCE THE RISK ASSOCIATED WITH ATWS BY AT LEAST 50%.
- THIRD: THAT A DECISION ON WHETHER ADDITIONAL RISK REDUCTION IS APPROPRIATE AWAIT THE ESTABLISHMENT OF A SAFETY GOAL AND THE INSIGHTS TO BE GAINED IN THE NEAR FUTURE FROM THE SEVERAL ONGOING PROBABILISTIC RISK ASSESSMENT EVALUATIONS.
- FOURTH: THAT AS A RESULT OF THE ABOVE, THE UNRESOLVED SAFETY ISSUE ON ATWS BE CLOSED NOW, AND ANY RESIDUAL RISK BE TREATED IN THE DEGRADED CORE RULEMAKING.