

YANKEE ATOMIC NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 76-9

FOR THE MONTH OF SEPTEMBER, 1976

8011070037

APPENDIX B

DOCKET NO. 50-29
 UNIT Yankee Rowe
 DATE 761006
 COMPLETED BY E. C. Tarnuzzer
 TELEPHONE (617) 366-9011 X 276

AVERAGE DAILY UNIT POWER LEVEL

MONTH September 1976

<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>	<u>DAY</u>	<u>AVERAGE DAILY MWe-net</u>
1	<u>159</u>	16	<u>155</u>
2	<u>159</u>	17	<u>158</u>
3	<u>159</u>	18	<u>158</u>
4	<u>159</u>	19	<u>157</u>
5	<u>159</u>	20	<u>157</u>
6	<u>159</u>	21	<u>156</u>
7	<u>159</u>	22	<u>156</u>
8	<u>159</u>	23	<u>155</u>
9	<u>159</u>	24	<u>155</u>
10	<u>159</u>	25	<u>122</u>
11	<u>159</u>	26	<u>140</u>
12	<u>159</u>	27	<u>156</u>
13	<u>159</u>	28	<u>156</u>
14	<u>158</u>	29	<u>156</u>
15	<u>158</u>	30	<u>156</u>
		31	<u>-</u>

DOCKET NO. 50-59
 UNIT NAME Yankee Rowe
 DATE 761006
 COMPLETED BY E. C. TARNUZZER
 TELEPHONE (617) 366-9011 X276

APPENDIX D

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH September 1976

NO.	DATE	TYPE F-FORCED S-SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR, (2)	CORRECTIVE ACTIONS/COMMENTS
-	760925	S	8.25	A & B	N.A.	Load reduction to 90 MWe for throttle valve test, xenon test, and condenser tube plugging (1).

SUMMARY: Plant ran at its restricted load limit of 90.5% for entire period except for one load reduction.

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

MONTHLY REPORT

TO:

N. R. C.

FROM:
Yankee Atomic Electric Company
Westborough, Mass.
J. L. French

DATE OF DOCUMENT

10/6/76

DATE RECEIVED

10/13/76

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

One signed copy

DESCRIPTION
LETTER TRANS THE FOLLOWING:

ENCLOSURE
MONTHLY REPORT FOR September, 1976
PLANT & COMPONENT OPERABILITY &
AVAILABILITY. THIS REPORT TO BE USED IN
PREPARING GRAY BOOK BY PLANS & OPERATIONS.

DO NOT REMOVE
ACKNOWLEDGED
(4-P)

PLANT NAME:

(1-P)

Yankee Rowe

SAFETY

FOR ACTION/INFORMATION

ENVIRO

10/13/76

RJL

MIPC
W/4 CYS FOR ACTION

INTERNAL DISTRIBUTION

REG FILE
 NRC PDR
 MCDONALD
 S. CHAIRMAN
 BRANCH CHIEF(L)
 LIC. ASST. (L)

Schwencer
Sheppard

EXTERNAL DISTRIBUTION

CONTROL NUMBER

LPR: Greenfield, MASS
 TIC
 NSIC

POOR ORIGINAL

10332