

(B) The following records shall be retained for the duration of the Facility Operating License:

1. Records of any drawing changes reflecting facility design modifications made to systems and equipment described in the Final Safety Analysis Report.
2. Records of new and irradiated fuel inventory, fuel transfers and assembly burnup histories.
3. Records of facility radiation and contamination surveys.
4. Records of radiation exposure for all individuals entering radiation control areas.
5. Records of gaseous and liquid radioactive material released to the environs.
6. Records of transient or operational cycles for those facility components identified in Table 6.10-1.
7. Records of training and qualification for current members of the plant staff.
8. Records of in-service inspections performed pursuant to these Technical Specifications.
9. Records of Quality Assurance activities required by the Quality Assurance Manual.
10. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
11. Records of meetings of the PORC and the SRC.
12. Records for Environmental Qualification which are covered under the provisions of paragraph 6.15.

5.11

RADIATION PROTECTION PROGRAM

Procedures for personnel radiation protection shall be prepared and adhered to for all plant operations. These procedures shall be formulated to maintain radiation exposures received during operation and maintenance as far below the limits specified in 10 CFR 20 as practicable. The procedures shall include planning, preparation, and training for operation and maintenance activities. They shall also include exposure allocation, radiation and contamination control techniques, and final debriefing.

BO111470 399

6.15 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-59 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.