

7. Records of training and qualification for current members of the plant staff.
8. Records of in-service inspections performed pursuant to these Technical Specifications.
9. Records of Quality Assurance activities required by the QA Manual.
10. Records of reviews performed for changes made to procedures or equipment or reviews of tests and experiments pursuant to 10 CFR 50.59.
11. Records of meetings of the Operations Committee and the Safety Committee.
12. Records for Environmental Qualification which are covered under the provisions of paragraph 6.13.

POOR ORIGINAL

8011070480

6.13 Environmental Qualification

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-49 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.

POOR ORIGINAL