

- 8011070497
5. Principal maintenance activities, including inspection, repairs and substitution or replacement of principal items of equipment pertaining to nuclear safety.
 6. Records of changes to plant procedures and records of special tests and experiments.
 7. Records of wind speed and direction.
 8. Records of individual plant staff members showing qualifications, training and retraining.
 9. Reportable Occurrences.

B. Records Retained for Plant Life

Records and logs relative to the following items shall be retained for the life of the plant:

1. Liquid and gaseous radioactive releases to the environs
2. Radiation exposures for all plant, visitor and contractor personnel
3. Off-site environmental monitoring surveys
4. Fuel accountability including new and spent fuel inventories and transfers, and fuel assembly histories
5. Radioactive shipments
6. Plant radiation and contamination surveys
7. Changes made to the plant as it is described in the Final Safety Analysis Report, reflected in updated, corrected and as-built drawings
8. Cycling beyond normal limits for those components that have been designed to operate safely for a limited number of cycles beyond such limits
9. Reactor coolant system in-service inspections
10. Minutes of meetings of the Safety Audit Committee
11. Records for Environmental Qualification which are covered under the provisions of paragraph 6.8.

6.8 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-2 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.