

POOR ORIGINAL

- M. Test results, in units of microcuries, for leak test performed pursuant to Specification 15.4.12.
- N. Record of annual physical inventory verifying accountability of sources subject to Specification 15.4.12.
- O. *Records of training and qualification for current plant NRC licensed staff and key personnel.
- P. *Records of in-service inspections performed pursuant to these technical specifications.
- Q. *Records of Quality Assurance activities required by the QA Manual.
- R. *Records of reviews performed pursuant to 10 CFR 50.59.
- S. *Records of meetings of the Manager's Supervisory Staff and the Off-Site Review Committee.
- T. *Records of Environmental Qualification which are covered under the provisions of paragraph 15.6.12.

15.6.12 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of: Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of Licenses DPR-24 and DPR-27 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.