

8011070578

7. Records of transient or operational cycling for those plant components that have been designed to operate safely for a limited number of transients or operational cycles.
8. Records of inservice inspections of the reactor coolant system.
9. Minutes of meetings of the Plant Operation Review Committee and the Nuclear Safety Audit and Review Board.
10. Records for Environmental Qualification which are covered under the provisions of paragraph 6.9.

6.9 ENVIRONMENTAL QUALIFICATION

- A. By no later than June 30, 1982 all safety-related electrical equipment in the facility shall be qualified in accordance with the provisions of Division of Operating Reactors "Guidelines for Evaluating Environmental Qualification of Class IE Electrical Equipment in Operating Reactors" (DOR Guidelines); or, NUREG-0588 "Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment", December 1979. Copies of these documents are attached to Order for Modification of License DPR-28 dated October 24, 1980.
- B. By no later than December 1, 1980, complete and auditable records must be available and maintained at a central location which describe the environmental qualification method used for all safety-related electrical equipment in sufficient detail to document the degree of compliance with the DOR Guidelines or NUREG-0588. Thereafter, such records should be updated and maintained current as equipment is replaced, further tested, or otherwise further qualified.