

THE CINCINNATI GAS & ELECTRIC COMPANY



E. A. BORGMANN  
VICE PRESIDENT

September 26, 1980  
QA-1344

U. S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Attention: Mr. Gaston Fiorelli, Chief  
Reactor Construction and Engineering  
Support Branch

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT I  
NRC INSPECTION REPORT NO. 80-20, DOCKET NO.  
50-358, CONSTRUCTION PERMIT NO. CPPR-88,  
W.O. #57300-957, JOB E-5590

Gentlemen:

This letter constitutes our formal reply to the subject inspection report. It is our opinion that nothing in the report or in this letter is of a proprietary nature.

Our response to the item of noncompliance cited in Appendix "A" of the report is as follows:

1. Corrective Action Taken and Results Achieved

Henry J. Kaiser Company Special Process Procedure Manual (SPPM) 4.5 has been revised to implement the SNT-TC-1A 1975 edition rather than the 1968 edition. This revision eliminates the discrepancies noted by the inspector.

2. Corrective Action to be Taken to Avoid Further Noncompliance

Further noncompliance will be avoided by review of SNT-TC-1A requirements when later editions or supplements are issued in order to assure continued compliance.

3. Date When Full Compliance Will Be Achieved

This item is considered to be in compliance at this time.

We trust that the above will constitute an acceptable response to the

OCT 2 1980

8011100 043


Mr. Gaston Fiorelli  
U. S. Nuclear Regulatory Commission  
Region III  
September 26, 1980  
QA-1344 - Page 2

subject inspection report.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By



E. A. BORGMANN  
SENIOR VICE PRESIDENT

JFW:pa  
cc: NRC Resident Inspector  
Attn: F. T. Daniels