

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
4. <u>Steam Line Pressure-Low</u>	
a. Safety Injection (ECCS)	$\leq 13.0\#/23.0\#\#$
b. Reactor Trip (from SI)	≤ 3.0
c. Feedwater Isolation	$\leq 75.0(1)$
d. Containment Isolation-Phase "A"	$\leq 22.0\#/33.0\#\#$
e. Auxiliary Feedwater Pumps	Not Applicable
f. Rx Plant River Water System	$\leq 77.0\#/110.0\#\#$
g. Steam Line Isolation	≤ 8.0
5. <u>Containment Pressure--High-High</u>	
a. Containment Quench Spray	≤ 77.0
b. Containment Isolation-Phase "B"	Not Applicable
c. Control Room Ventilation Isolation	$\leq 17.0\#/30.0\#\#$
6. <u>Steam Generator Water Level--High-High</u>	
a. Turbine Trip-Reactor Trip	≤ 2.5
b. Feedwater Isolation	$\leq 78.0(1)$
7. <u>Containment Presssure--Intermediate High-High</u>	
a. Steam Line Isolation	≤ 8.0
8. <u>Steamline Pressure Rate--High Negative</u>	
a. Steamline Isolation	≤ 8.0