



CONNECTICUT YANKEE ATOMIC POWER COMPANY

DISTRIBUTION  
SERVICES UNIT

BERLIN, CONNECTICUT

P. O. BOX 270 HARTFORD, CONNECTICUT 06101

1980 NOV 10 AM 9 17

TELEPHONE  
203-666-6911

November 4, 1980  
DISTRIBUTION SERVICES  
BRANCH

Docket No. 50-213  
A01116

Director of Nuclear Reactor Regulation  
Attn: Mr. Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

References: (1) W. G. Counsil letter to D. M. Crutchfield dated August 21, 1980.  
(2) D. M. Crutchfield letter to W. G. Counsil dated July 1, 1980.

Gentlemen:

Haddam Neck Plant  
Adequacy of Station Electric Distribution System Voltages

Reference (1) forwarded Connecticut Yankee Atomic Power Company's (CYAPCO) responses to Questions 2, 3, and 4 of Enclosure 1 to Reference (2), and informed the Staff that answers to Question 1 would be provided by November 26, 1980. Those answers are hereby provided as Attachment 1.

CYAPCO trusts this information will be sufficient to allow the Staff to complete their effort on this topic.

Very truly yours,

CONNECTICUT YANKEE ATOMIC POWER COMPANY

*W.G. Counsil*  
W. G. Counsil  
Senior Vice President

Attachment

8011100

422

P

THIS DOCUMENT CONTAINS  
POOR QUALITY PAGES

ATTACHMENT 1

HADDAM NECK PLANT

ADEQUACY OF STATION ELECTRIC DISTRIBUTION SYSTEM VOLTAGES

Ref. 1: NRC Letter (W. Gammill) to all Power Reactor Licensees, dated August 8, 1979

Question

Guidelines 1 and 7 (Ref. 1) require that a separate analysis be performed for all available connections to the offsite network and that the analysis be adequately documented for each condition analyzed. Ref. 2 does not fully meet these requirements. To confirm the acceptability of the voltage conditions on the station electric distribution system submit adequate voltage analysis documentation for each case and condition analyzed in Ref. 2 and additional documentation, specifically:

- a. Requirements of Guidelines 6 and 11 as well as 5 and 13 (Ref. 1) must be included in each separate case analyzed. These guidelines refer to the use of minimum and maximum expected grid voltages, maximum loads assumed for each analyzed case and a list of assumptions made for each analyzed case.
- b. Supply the calculated voltages for all low voltage AC (less than 480 volts) Class 1E buses (including all available source connections) for each analyzed case. Do these buses supply instrumentation or control circuits as required by GDC 13? If so, is all equipment capable of sustaining the analyzed voltages without blowing fuses, overheating, and without affecting the equipment's ability to perform the required function?
- c. Per Guidelines 3 and 9 (Ref. 1), compare the effect of starting and running the largest non-Class 1E load on all Class 1E buses and loads with the required voltage range for normal operation of all

Class 1E equipment (starters, contactors, motors, etc.) for each available connection of offsite power. This comparison should occur after the Class 1F buses are fully loaded.

- d. By the use of disconnect links or other means, is it possible to backfeed from the 345 KV switchyard through the main transformer (319) and the service station transformer (309) to the Class 1E buses? If this is a viable connection, an analysis is required for this source connection or identify limiting conditions of operation.

Response

The attached data sheets (Attachment 1) summarize the cases analyzed in the voltage studies for Connecticut Yankee. This data should complete the required information requested by the NRC in the July 1, 1980 memo from D. M. Crutchfield to W. G. Counsil.

- a. The data sheets include the minimum and maximum expected grid voltages, the loading conditions, mode of operation, and the assumptions made for each case in the analysis. The minimum expected grid voltages used in the analysis are the minimum acceptable grid voltages required to assure starting and running of all accident loads for the worst case bus loadings. The 106 KV level for two transformer operation is below the grid administrative limit of 106.4 KV and represents a voltage level which has a very low probability of occurrence. The probability of dropping below the 110.8 KV figure (for one transformer operation) is higher than that for the 106 KV figure, however this is offset by the low probability of having only one station service transformer available.

The maximum expected grid voltage of 117 KV is based on an early issue of the administrative limits for grid voltage at Connecticut Yankee. This level indicates the possibility of some overvoltages occurring (monitors have been installed to alarm when the voltage limits are exceeded). However, the present operating instructions specify an upper limit of 114.7 KV; a level which the study indicates would eliminate all of the overvoltage conditions identified. The 117 KV limit has been used in the study for the sake of conservatism.

The normal full load case in this study includes the operation of both charging pumps, all service water pumps, and all CAR fans. While starting these individual loads during the start sequence, the running load for the motor being started is not removed from the normal full load on the 4.16 KV buses. This provides a conservatism in the analysis by making the bus loadings appear higher than they actually are.

Note: The starting loads are not included in the "LOAD" column of the data sheets because they are modeled as constant impedances rather than constant power loads.

- b. All "Vital AC" at Connecticut Yankee is supplied by inverters. All "Semi-Vital AC" is supplied by regulating transformers. The only 120 VAC Class 1E loads not supplied by either the Vital or Semi-Vital AC are the service water filter motors. The voltages for the 120 volt bus supplying these loads are included in the data sheets.

These loads are capable of performing their required functions throughout each case studied. The voltages which fall below the normal required voltage for these loads are due to motor starts and are transient in nature with no significant effect on the performance of the motors.

- c. Cases 15 and 29 of the data sheets indicate the voltages which occur during the starting of the largest non-Class 1E load (a steam generator feed pump) while the emergency buses are fully loaded. Once this pump has started, the voltages return to those detailed in cases 13 and 27 respectively. The Class 1E loads and associated equipment are capable of continued operation during and after the voltage dip caused by starting of the SGFP. Starting of the SGFP will not cause the level-two undervoltage scheme to trip the offsite power supply in this situation because the level-two scheme is blocked once the safety injection loads have started to sequence, and remains blocked until the sequence timers are reset.

For comparison purposes, the following voltage levels should be used as minimum bus voltages for either running or starting loads. These levels are adjusted for the cable drops listed under "assumptions" on the data sheet.

<u>Nominal Voltage</u>	<u>Min. Running Voltage</u>	<u>Min. Starting Voltage</u>
4160 Volt	3620 V	3300 V
480 Volt	406 V	402 V
120 Volt	110 V	-

d. There are no interlocks preventing this connection from being used. However, the 309 transformer has a capacity of only 15 MVA; enough to supply the reactor coolant pumps. During normal plant operation, the 309 transformer does not have sufficient capacity to operate the reactor coolant pumps and a division of plant auxiliary loads at the same time. With the plant off-line, the 309 transformer has the capacity to carry the auxiliary loads. Since either the 389 or the 399 transformer (or both) serves this purpose and would not require the 309 to be used in this application, we consider this connection to be not viable. Therefore, no analysis is required for this source connection.

Attachment No. 1  
Connecticut Yankee  
Auxiliary Bus Voltage Study  
Data Sheets

CONNECTICUT YANKEE

CASE No. 1 No of STA. SERV. XFMR. IN SERV. 102 Mode of Operation SHUTDOWN

Min. EXPECTED GRID VOLTAGE 106 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION MINIMUM STATION LOAD

ASSUMPTIONS 4160-Volt Cable Drops = 20 V Running Load, 100 V Starting Load

4160-Volt Cable Drops = 10 V Running Load, 50 V Starting Load

STARTING MOTORS ARE MODELED AS CONSTANT IMPEDANCES AND THE STARTING

LOAD IS NOT INCLUDED IN THE "LOAD" COLUMN BELOW.

NOMINAL BUS VOLTAGE	LOAD MVA	P.F.	PRESENT XMR. TAP VOLTAGE FOR GRID MINIMUM	ALTERNATE XMR. TAP	
				VOLTAGE FOR GRID MAXIMUM	VOLTAGE FOR GRID MINIMUM
115 KV			4001 V	4423 V	No Change Recommended.
Bus 8	416 KV	2.0	0.70	4001 V	4423 V
Bus 9	416 KV	2.0	0.70	453 V	503 V
Bus 1-4	180 V	0.50	0.70	453 V	503 V
Bus 1-5	180 V	0.50	0.70	453 V	503 V
Bus 1-6	120 V	0.50	0.70	453 V	503 V
Bus 1-7	110 V	0.50	0.70	453 V	503 V
L.P.P.2-1	120 V	.102	0.70	112 V	128 V

CONNECTICUT YANKEE

CASE No. 2 No. of STA. SERV. XEMR. IN SERV. 2 MODE OF OPERATION STARTUP

Min EXPECTED GRID VOLTAGE 106 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NORMAL Full LOAD w/o STEAM GENERATOR FEED PUMPS (SGFP)

ASSUMPTIONS SAME AS CASE 1

SERVICE WATER PUMPS, CAR FANS, AND CHARGING PUMPS ARE RUNNING IN

ALL "NORMAL Full LOAD" CASES. ADDITION OF THESE LOADS TO THE NORMAL LOAD ON

THE 416 KV BUSES IS A CONSERVATISM IN THE STUDY.

Nominal Bus Voltage	PRESENT XEMR. TAP		ALTERNATE XEMR. TAP	
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM 115 KV				
Bus 8 416 KV	5.18	0.93	3988 V	4412 V
Bus 9 416 KV	5.18	0.93	3988 V	4412 V
Bus 1-4 480 V	1.13	0.91	450 V	499 V
Bus 1-5 480 V	1.13	0.91	450 V	499 V
Bus 1-6 480 V	1.13	0.91	450 V	499 V
Bus 1-7 480 V	1.13	0.91	450 V	499 V
L.P.P2-1 120 V	0.15	0.70	114 V	127 V

CONNECTICUT YANKEE

Case No. 3 No. of STA. SERV. XFMR. IN SERV. 2 Mode of Operation STARTUP

Min. Expected Grid Voltage 106 KV Max. Expected Grid Voltage 117 KV

Load Description Normal Full Load w/o SGEP - START SGEP

Assumptions SAME AS CASE 2

Nominal Bus Voltage	Present Xfmr. Tap		Alternate Xfmr. Tap	
	Load MVA	p.f.	Voltage for Grid Minimum	Voltage for Grid Maximum
SYSTEM				
Bus 8	416 KV	5.18	3537 V	3915 V
Bus 9	416 KV	5.18	3537 V	3915 V
Bus 1-4	480 V	1.13	396 V	441 V
Bus 1-5	480 V	1.13	396 V	441 V
Bus 1-6	480 V	1.13	396 V	441 V
Bus 1-7	480 V	1.13	396 V	441 V
LP-P2-1	120 V	0.70	100 V	111 V

CONNECTICUT YANKEE

CASE No. 4

No. OF STA. SERV. XFMR. IN SERV. 2

MIN. EXPECTED GRID VOLTAGE 106 KV MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL FULL LOAD

ASSUMPTIONS SAME AS CASE 2.

MODE OF OPERATION FULL POWER

NOMINAL BUS VOLTAGE	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP		RECOMMENDED CHANGE
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
SYSTEM					
Bus 8	4.16 KV	9.1	3943 V	4371 V	No Change
Bus 9	4.16 KV	9.1	3943 V	4371 V	
Bus 1-4	480 V	1.13	444 V	492 V	
Bus 1-5	480 V	1.13	444 V	492 V	
Bus 1-6	480 V	1.13	444 V	492 V	
Bus 1-7	480 V	1.13	444 V	492 V	
L.P. P2-1	120 V	0.70	112 V	164 V	

CONNECTICUT YANKEE

CASE NO. 5 No. of STA. SERV. XFMR. IN SERV. 2 MODE OF OPERATION PLANT TRIP

MIN. EXPECTED GRID VOLTAGE 106 KV MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL LOAD + TRANSFER OF 1 RCP PER DIVISION

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP		RECOMMENDED
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
115 KV					
Bus 8	416 KV	1.199	0.92	3911 V	4343 V
Bus 9	416 KV	1.199	0.92	3911 V	4343 V
Bus 1-4	480 V	1.13	0.91	440 V	491 V
Bus 1-5	480 V	1.13	0.91	440 V	491 V
Bus 1-6	480 V	1.13	0.91	440 V	491 V
Bus 1-7	430 V	1.13	0.91	440 V	491 V
L.P.-P2-1	120 V	0.70	1.11	111 V	124 V

CONNECTICUT YANKEE

CASE No. 6      No. OF STA. SERV. XFMR. IN SERV. 2      MODE OF OPERATION TEP w/ LOCA

MIN. EXPECTED GRID VOLTAGE 106 KV      MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NORMALE Full LOAD + PCP + START LPSTI Pump

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP	
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM				
Bus 8	416 KV	11.99	3791 V	4211 V
Bus 9	416 KV	11.99	3791 V	4211 V
Bus 1-4	480 V	1.13	427 V	476 V
Bus 1-5	480 V	1.13	427 V	476 V
Bus 1-6	480 V	1.13	427 V	476 V
Bus 1-7	480 V	1.13	427 V	476 V
LP-P2-1	120 V	0.15	108 V	120 V

RECOMMENDED

CONNECTICUT YANKEE

CASE No. 7 No. of STA. SERV. XEMR. IN SERV. 2 Mode of Operation Trip w/ LOCA

Min. EXPECTED GRID VOLTAGE 106 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL Full LOAD + RCP + Run LPSTI Pump

Assumptions SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT XEMR. TAP		ALTERNATE XEMR. TAP	
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM				
Bus 8	416 KV	12.90	0.72	3897 V
Bus 9	416 KV	12.90	0.72	3897 V
Bus 1-4	480 V	1.13	0.71	441 V
Bus 1-5	480 V	1.13	0.71	441 V
Bus 1-6	480 V	1.13	0.71	441 V
Bus 1-7	480 V	1.13	0.71	441 V
LP-P2-1	120 V	0.70	111 V	124 V

CONNECTICUT YANKEECase No. 8 No. of Sta. Serv.  $X_{EMR}$  in serv. 2 Mode of operation TRIP w/LOCAMin. Expected Grid Voltage 106 KV Max. Expected Grid Voltage 117 KVLoad Description Normal Full Load, PGP, LPSI, START HPSI PumpAssumptions Same as Case 7.

Nominal Bus Voltage	PRESENT $X_{EMR}$ TAP		ALTERNATE $X_{EMR}$ TAP		No Change Recommended
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
System					
Bus 8	4.16 KV	12.90	0.92	3746 V	4165 V
Bus 9	4.16 KV	12.90	0.92	3746 V	4165 V
Bus 1-4	480 V	1.13	0.91	421 V	471 V
Bus 1-5	480 V	1.13	0.91	421 V	471 V
Bus 1-6	480 V	1.13	0.91	421 V	471 V
Bus 1-7	480 V	1.13	0.91	421 V	471 V
L.P.P2-1	120 V	0.15	0.70	106 V	119 V

CONNECTICUT YANKEE

CASE NO. 1 No. OF STA. SERV. XEMR. IN SERV. 2 MODE OF OPERATION TRIP w/ LOCA

MIN. EXPECTED GRID VOLTAGE 106 KV MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL FUEL LOAD, P.C.P., P.S.T., H.P.S.T.

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT XEMR. TAP		ALTERNATE XEMR. TAP		RECOMMENDED CHANGE
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
SYSTEM					
Bus 8	416 KV	14.04	0.91	3879 V	4316 V
Bus 9	416 KV	14.04	0.91	3879 V	4316 V
Bus 1-4	480 V	1.13	0.91	437 V	488 V
Bus 1-5	480 V	1.13	0.91	437 V	488 V
Bus 1-6	480 V	1.13	0.91	437 V	488 V
Bus 1-7	480 V	1.13	0.91	437 V	488 V
L.P.-P2-1	120 V	0.15	0.10	110 V	124 V

CONNECTICUT YANKEE

CASE NO. 10

No. OF STA. SERV. XFMR. IN SERV. 2

MIN EXPECTED GRID VOLTAGE 106 KV MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Normal Full Load, TCP, LPSI, HPSI, Start Charging Time

ASSUMPTIONS SAME AS CASE 2

MODE OF OPERATION TRIP w/ LOCA

NOMINAL BUS VOLTAGE	PRESENT XFMR. TAP		ALTERNATE VOLTAGE FOR GRID MINIMUM	EMR. TAP VOLTAGE FOR GRID MAXIMUM
	LOAD MVA	p.f.		
SYSTEM				
Bus 8	416 KV	14.04	0.11	3782 V
Bus 9	416 KV	14.04	0.11	3782 V
Bus 1-4	430 V	1.13	0.11	426 V
Bus 1-5	480 V	1.13	0.91	426 V
Bus 1-6	480 V	1.13	0.11	426 V
Bus 1-7	480 V	1.13	0.11	426 V
L.P.P2-1	120 V	0.15	0.70	107 V
				120 V

CONNECTICUT YANKEE

CASE No. 11      No. of STA. SERV.  $X_{EMR}$ . IN SERV. 2      MODE OF OPERATION Temp w/ LOCA

Min. EXPECTED GRID VOLTAGE 106 KV      Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Vocational Fuel Load, CCP, UPSI, HPSI, CHART P

ASSUMPTIONS SAME AS CASE 2.

Nominal Bus Voltage	LOAD MVA	p.f.	PRESENT $X_{EMR}$ . TAP		ALTERNATE $X_{EMR}$ . TAP		No Change RECOMMENDED
			VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
SYSTEM							
Bus 8	416 KV	15.51	0.91	3856 V	4296 V	No Change	RECOMMENDED
Bus 9	416 KV	15.51	0.91	3856 V	4296 V		
Bus 1-4	1130 V	1.13	0.91	434 V	486 V		
Bus 1-5	1130 V	1.13	0.91	434 V	486 V		
Bus 1-6	1130 V	1.13	0.91	434 V	486 V		
Bus 1-7	1130 V	1.13	0.91	434 V	486 V		
LP-P2-1	120 V	0.15	0.70	110 V	123 V		

CONNECTICUT YANKEECASE No. 12 No. of STA. SERV. XFMR. IN SERV. 2 MOVE OF OPERATION TIE w/ LOCAMIN EXPECTED GRID VOLTAGE 106 KV MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Normal Full Load, C.P., IPSI, HPSI, Charb, Start Serv. Wt. &amp; P.

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP	
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM				
Bus 8	416 KV	15.51	0.91	382.5 V
Bus 9	416 KV	15.51	0.91	382.5 V
Bus 1-4	480 V	1.13	0.91	430 V
Bus 1-5	480 V	0.10	0.12	405 V
Bus 1-6	480 V	0.10	0.12	405 V
Bus 1-7	480 V	1.13	0.91	430 V
L.P.-P2-1	470 V	0.15	0.70	102 V
				122 V
RECOMMENDED				
				No Change

CONNECTICUT YANKEE

CASE No. 13

No. of STA. SERV. X<sub>FMR.</sub> IN SERV 2

Min. EXPECTED GRID VOLTAGE 106.4/V

Mode of OPERATION Trip w/LOCA

Max. EXPECTED GRID VOLTAGE 117 KV

LOAD Description Normal Full LOAD except HPSI, CHARGERS, SW P, (INCLUDES CAR FANS)

Assumptions SAME AS CASE 2.

Nominal Bus Voltage	PRESENT X <sub>FMR.</sub> TAP		ALTERNATE X <sub>FMR.</sub> TAP	
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM				
Bus 8	416 KV	15.75	0.90	4292 V
Bus 9	416 KV	15.75	0.90	4292 V
Bus 1-4	480 V	1.13	0.91	485 V
Bus 1-5	480 V	1.13	0.91	485 V
Bus 1-6	480 V	1.13	0.91	485 V
Bus 1-7	480 V	1.13	0.91	485 V
L.P. P2-1	120 V	0.15	0.70	110 V
			No Change	RECOMMENDED

CONNECTICUT YANKEE

CASE No. 1-1 No. of STA. SERV.  $X_{EMR}$  IN SERV. 2 Mode of Operation TRIP w/LOCA

Min. EXPECTED GRID VOLTAGE 106 kV Max. EXPECTED GRID VOLTAGE 117 kV

LOAD DESCRIPTION NOMINAL FUEL LOAD, RCP, UPSI, HPSI, CHAR BE, SW Pp, SMER, CAR FAN

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT $X_{EMR}$ . TAP		ALTERNATE $X_{EMR}$ . TAP	
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM				
Bus 8	4.16 kV	15.54	0.91	382.2 V
Bus 9	4.16 kV	15.54	0.91	382.2 V
Bus 1-4	480 V	1.13	0.91	430 V
Bus 1-5	480 V	0.93	0.91	402 V
Bus 1-6	480 V	0.93	0.91	402 V
Bus 1-7	480 V	1.13	0.91	430 V
L.P.-P2-1	100 V	0.15	0.70	101 V
RECOMMENDED				
			4259 V	No Change
			4259 V	
			481 V	
			450 V	
			450 V	
			481 V	
			114 V	

CONNECTICUT YANKEE

CASE No. 1

No. of STA. SERV. XFMR. IN SERV 2 Mode of Operation LOCA Loads Running

MIN EXPECTED GRID VOLTAGE 106 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Nominal Full Loads, Accident Loads, Start SGFP

ASSUMPTIONS SAME AS CASE 2

Nominal Bus Voltage	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP	
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM				
Bus 8	4.16 KV	11.55	0.90	3449 V
Bus 9	416 KV	11.55	0.90	3449 V
Bus 1-4	480 V	1.13	0.91	386 V
Bus 1-5	480 V	1.13	0.91	386 V
Bus 1-6	480 V	1.13	0.91	386 V
Bus 1-7	480 V	1.13	0.91	386 V
LP-P2-1	120 V	0.15	0.70	98 V
			No Change	RECOMMENDED
			3836 V	
			3836 V	
			432 V	
			432 V	
			432 V	
			432 V	
			109 V	

CONNECTICUT YANKEE

CASE No. 16      No. of STA. SERV. XFER. IN SERV. 1      Mode of Operation STARTUP

MN. EXPECTED GRID VOLTAGE 110.8 KV      Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL FULL LOAD w/o 1 SGFP

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	LOAD MVA	P.F.	PRES. XFER. TAP	ALTERNATE XFER. TAP	VOLTAGE FOR GRID MAXIMUM	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
			VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM			
SYSTEM	115 KV	14.56	0.93				
Bus 8	116 KV	5.18	0.93	4078 V	4323 V	No Change	RECOMMENDED
Bus 9	116 KV	9.38	0.92	4078 V	4323 V		
Bus 1-4	480 V	1.13	0.91	460 V	489 V		
Bus 1-5	480 V	1.13	0.91	460 V	489 V		
Bus 1-6	480 V	1.13	0.91	460 V	489 V		
Bus 1-7	480 V	1.13	0.91	460 V	489 V		
LP-P2-1	120 V	0.15	0.70	116 V	124 V		

CONNECTICUT YANKEE

CASE No. 17      No of STA. SERV.  $X_{FMR}$ . IN SERV. 1      Mode of Operation STARTUP

Min. EXPECTED GRID VOLTAGE 110.8 KV      Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL FUEL LOAD w/o SGFP - START SGFP

ASSUMPTIONS SAME AS CASE 2

Nominal Bus Voltage	Present $X_{FMR}$ . Tap		Alternate $X_{FMR}$ . Tap	
	Load MVA	p.f.	Voltage for Grid Minimum	Voltage for Grid Maximum
System	115 KV	14.56	0.93	
Bus 8	416 KV	5.18	0.93	3820 V No Change RECOMMENDED
Bus 9	416 KV	9.38	0.92	3820 V
Bus 1-4	480 V	1.13	0.91	430 V
Bus 1-5	480 V	1.13	0.91	430 V
Bus 1-6	480 V	1.13	0.91	430 V
Bus 1-7	480 V	1.13	0.91	430 V
L.P.P2-1	120 V	0.15	0.70	109 V

CONNECTICUT YANKEE

CASE No. 18

No. of STA. SERV. XFR. IN SERV. 1

MIN. EXPECTED GRID VOLTAGE 110.8 KV

MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Nominal Full Load

ASSUMPTIONS SAME AS CASE 2.

MODE OF OPERATION FU: Power

Nominal Bus Voltage	Present Xfrmr. Tap		Alternate Xfrmr. Tap	
	Load MVA	p.f.	Voltage for Grid Minimum	Voltage for Grid Maximum
System	18.20	0.92		
Bus 8	416 KV	9.10	4029 V	4278 V
Bus 9	416 KV	9.10	4029 V	4278 V
Bus 1-4	480 V	1.13	454 V	483 V
Bus 1-5	480 V	1.13	454 V	483 V
Bus 1-6	480 V	1.13	454 V	483 V
Bus 1-7	480 V	1.13	454 V	483 V
LP-P2-1	1.20 V	0.70	115 V	123 V

RECOMMENDED

CONNECTICUT YANKEE

CASE No. 19 No. of STA. SERV. XFMR. IN SERV. 1 Mode of Operation Plant Trip

MIN EXPECTED GRID VOLTAGE 110.8 KV MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Nominal Full Load, Transfer 1 RCP per Division

ASSUMPTIONS SAME AS Case 2

Nominal Bus Voltage	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP		No. CHANGE RECOMMENDED
	LOAD MVA	P.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
SYSTEM	23.98	0.92			
Bus 8	416 KV	11.99	0.92	3956 V	4211 V
Bus 9	416 KV	11.99	0.92	3956 V	4211 V
Bus 1-4	480 V	1.13	0.91	446 V	476 V
Bus 1-5	480 V	1.13	0.91	446 V	476 V
Bus 1-6	480 V	1.13	0.91	446 V	476 V
Bus 1-7	480 V	1.13	0.91	446 V	476 V
L.P. P2-1	120 V.	0.15	0.70	112 V	120 V

CONNECTICUT YANKEE

CASE No. 20      No. of STA. SERV. IN SERV. 1      MODE OF OPERATION TRIP w/L OCA

MIN EXPECTED GRID VOLTAGE 110.8 KV      MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL LINE LOAD, RCP, STREET 2 LOST

ASSUMPTIONS SAME AS CASE 2.

NOM. & BUS VOLTAGE	PRESENT YEAR. TAP		ALTERNATE YEAR. TAP	
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM	23.98	0.92		
Bus 8	416 KV	11.99	3706 V	3949 V
Bus 9	416 KV	11.99	3706 V	3949 V
Bus 1-4	1180 V	1.13	417 V	445 V
Bus 1-5	1180 V	1.13	417 V	445 V
Bus 1-6	1180 V	1.13	417 V	445 V
Bus 1-7	1180 V	1.13	417 V	445 V
LP-P2-1	120 V	0.70	105 V	112 V

CONNECTICUT YANKEE

CASE NO. 21 No. of STA. SERV.  $X_{EMR}$  IN SERV. 1 Mode of Operation TRIP w/ LOCA

MIN. EXPECTED GRID VOLTAGE 10.8 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Normal Full load, All PSS's

ASSUMPTIONS SAME AS CASE 2.

Nominal Bus Voltage	Load MVA	P.f.	PRESENT $X_{EMR}$ TAP VOLTAGE FOR GRID MINIMUM		ALTERNATE $X_{EMR}$ TAP VOLTAGE FOR GRID MAXIMUM		RECOMMENDED VOLTAGE FOR GRID	VOLTAGE FOR GRID MAXIMUM
			VOLTAGE FOR GRID MAXIMUM	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	VOLTAGE FOR GRID MINIMUM		
SYSTEM	25.80	0.12						
Bus 8	416 KV	12.90	0.92	392.5 V	418.3 V	No Change		
Bus 9	416 KV	12.90	0.92	392.5 V	418.3 V			
Bus 1-4	480 V	113	0.91	442 V	473 V			
Bus 1-5	480 V	113	0.91	442 V	473 V			
Bus 1-6	480 V	113	0.91	442 V	473 V			
Bus 1-7	480 V	113	0.91	442 V	473 V			
L.P.P2-1	120 V	0.70	111 V	120 V				

CONNECTICUT YANKEE

CASE No. 2-2      No. of STA. SERV. XFMR. IN SERV. 1      MODE OF OPERATION True w/ LOCA

MIN. EXPECTED GRID VOLTAGE 110.8 KV      Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION: Normal Full Load, LCP's, LPST's, Start HPST's

ASSUMPTIONS SAME AS CASE 2

NOMINAL BUS VOLTAGE	LOAD MVA	P.F.	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP	
			VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
115 KV	25.80	0.92				
Bus 8	416 KV	12.90	0.92	3615 V	3858 V	No Change RECOMMENDED
Bus 9	416 KV	12.90	0.92	3615 V	3858 V	
Bus 1-4	480 V	1.13	0.91	406 V	434 V	
Bus 1-5	480 V	1.13	0.91	406 V	434 V	
Bus 1-6	480 V	1.13	0.11	406 V	434 V	
Bus 1-7	480 V	1.13	0.71	406 V	434 V	
L.P.P2-1	120 V	0.15	0.70	102 V	110 V	

CONNECTICUT YANKEE

CASE No. 23

No. of STA. SERV. XEMR. IN SERV. 1

Min EXPECTED GRID VOLTAGE 110.8 KV

Mode of OPERATION TRIP w/ LOCA

Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL Full LOAD, PCP's, LPST's, HPSI's

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT XEMR. TAP		ALTERNATE XEMR. TAP	
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM 115 KV	28.09	0.91		
Bus 8 416 KV	14.04	0.91	3884 V	4146 V
Bus 9 416 KV	14.04	0.91	3884 V	4146 V
Bus 1-4 480 V	1.13	0.91	437 V	469 V
Bus 1-5 480 V	1.13	0.91	137 V	469 V
Bus 1-6 480 V	1.13	0.91	437 V	469 V
Bus 1-7 480 V	1.13	0.91	437 V	469 V
LP-P2-1 120 V	0.15	0.70	110 V	119 V

RECOMMENDED.

CONNECTICUT YANKEE

CASE No. 24      No. of STA. SERV. X<sub>FMR.</sub> IN SERV. 1      Mode of OPERATION TRIP w/LOCA

MIN. EXPECTED GRID VOLTAGE 110.8 KV      MAX. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NORMAL Full LOAD, RCP's, LPSTI's, HPSI's, START 2 NO CHAP. PH.

ASSUMPTIONS CHARGING T.P. ALREADY RUNNING ON BUS 9.

SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT X <sub>FMR.</sub> TAP		ALTERNATE X <sub>FMR.</sub> TAP		RECOMMENDED NO CHANGE
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
SYSTEM	28.09	0.91	3780 V	4036 V	
Bus 8	14.04	0.91	3780 V	4036 V	
Bus 9	14.04	0.91	3780 V	4036 V	
Bus 1-4	1.13	0.91	426 V	455 V	
Bus 1-5	1.13	0.91	426 V	455 V	
Bus 1-6	1.13	0.91	426 V	455 V	
Bus 1-7	1.13	0.91	426 V	455 V	
LPP2-1	0.15	0.70	107 V	115 V	

CONNECTICUT YANKEE

CASE No. 2.5 No of STA. SERV. XEMR. IN SERV. 1 Mode of Operation TRIP w/LOCA

Min. EXPECTED GRID VOLTAGE 110.8 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Nominal Full Load, RCL, LPST's, HPSI's, Chas. P

ASSUMPTIONS Same as Case 2.

Nominal Bus Voltage	LOAD MVA	P.f.	PRESENT XEMR. TAP		ALTERNATE XEMR. TAP	
			VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM	29.56	0.91				
Bus 8	15.57	0.91				
Bus 9	14.04	0.91	3857 V	4122 V		
Bus 1-4	1.13	0.91				
Bus 1-5	1.13	0.91				
Bus 1-6	1.13	0.91				
Bus 1-7	1.13	0.91				
LP-P2-1	120 V	0.70	110 V	118 V		

RECOMMENDED

CONNECTICUT YANKEE

CASE No. 26 No. of STA. SERV.  $X_{FMR}$  IN SERV. 1 Mode of OPERATION Trip w/o OCA

Min. EXPECTED GRID VOLTAGE 108 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Mechanical Fuel Load, RCP's, LPST's, HPSI's, Cine. P, Start SW P

ASSUMPTIONS SAME AS Case 2

Nominal Bus Voltage	PRESENT $X_{FMR}$ TAP		ALTERNATE $X_{FMR}$ TAP		<u>No Change Recommended</u>
	LOAD MVA	P.F.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
SYSTEM	29.5%	0.91	3823 V	4087 V	
Bus 8	416 KV	15.57	0.91	3823 V	4087 V
Bus 9	416 KV	14.04	0.91	3823 V	4087 V
Bus 1-4	480 V	1.13	0.11	430 V	461 V
Bus 1-5	480 V	0.90	0.92	405 V	439 V
Bus 1-6	480 V	1.13	0.91	430 V	461 V
Bus 1-7	480 V	1.13	0.91	430 V	461 V
LP-P2-1	120 V	0.15	0.70	102 V	111 V

CONNECTICUT YANKEE

CASE No. 27 No of STA. SERV. XFMR. IN SERV. 1 Mode of Operation TRIP w/ LOCA

Min EXPECTED GRID VOLTAGE 110.8 KV Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION NOMINAL FUEL LOAD, LCP's, LPST's, HPSI's,柴汽机, SWP (Includes CAR Fans)

ASSUMPTIONS SAME AS CASE 2.

NOMINAL BUS VOLTAGE	PRESENT XFMR. TAP		ALTERNATE XFMR. TAP	
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM
SYSTEM	29.79	0.91		
Bus 8	416 KV	15.75	0.90	4118 V
Bus 9	416 KV	14.04	0.91	4118 V
Bus 1-4	480 V	1.13	0.91	465 V
Bus 1-5	480 V	1.13	0.91	433 V
Bus 1-6	480 V	1.13	0.91	433 V
Bus 1-7	480 V	1.13	0.91	433 V
L.P. P2-1	130 V	0.15	0.70	110 V
				121 V

RECOMMENDED

CONNECTICUT YANKEE

CASE NO. 28

No of STA. SERV. XEMR. IN SERV. 1

Mode of Operation TRIP w/ LOCA

Min. EXPECTED GRID VOLTAGE 110.8 KV

Max. EXPECTED GRID VOLTAGE 117 KV

LOAD DESCRIPTION Nominal Fuel Load, RCP's, LPSI's, HPSI's, Char Ph, SW Ph, Street Ctr R tan

ASSUMPTIONS SAME AS CASE 2

Nominal Bus Voltage	PRESENT XEMR. TAP		ALTERNATE XEMR. TAP		RECOMMENDED
	LOAD MVA	p.f.	VOLTAGE FOR GRID MINIMUM	VOLTAGE FOR GRID MAXIMUM	
115 KV	29.79	0.91	3817 V	1081 V	No Change
Bus 8	416 KV	15.75	0.90	3817 V	4081 V
Bus 9	416 KV	14.04	0.91	430 V	461 V
Bus 1-4	480 V	1.13	0.91	402 V	431 V
Bus 1-5	480 V	0.93	0.91	430 V	461 V
Bus 1-6	480 V	1.13	0.91	430 V	461 V
Bus 1-7	480 V	1.13	0.91	430 V	461 V
LPR-P2-1	120 V	0.15	0.70	101 V	109 V

CONNECTICUT YANKEE

CASE No. 29

No. of STA. SERV.  $X_{FMR}$ . IN SERV. 1

Mode of Operation Local Loads Running

Min. EXPECTED Grid Voltage 110.8 KV

Max. EXPECTED Grid Voltage 117 KV

LOAD DESCRIPTION NOMINAL Full Load, Accident Loads, Street SGFP

ASSUMPTIONS SAME AS CASE 2.

Nominal Bus Voltage	Present $X_{EMR}$ . Tap		Alternate $X_{EMR}$ . Tap	
	Load MVA	p.f.	Voltage for Grid Minimum	Voltage for Grid Maximum
System	25.60	0.91	34.24 V	36.59 V
Bus 8	4.16 KV	11.56	0.91	34.24 V
Bus 9	4.16 KV	14.04	0.91	36.59 V
Bus 1-4	480 V	1.13	0.91	38.3 V
Bus 1-5	480 V	1.13	0.91	38.3 V
Bus 1-6	480 V	1.13	0.91	38.3 V
Bus 1-7	480 V	1.13	0.91	38.3 V
L.P.P2-1	120 V	0.15	97 V	103 V

RECOMMENDED