

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | M A Y | K R | 1 | 0 0 | - 0 | 0 0 | 0 0 | - 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T 01 | REPORT SOURCE | L | 6 | 0 5 | 0 0 | 0 0 | 0 2 | 9 | 7 | 1 | 0 | 0 | 6 | 8 | 0 | 8 | 1 | 1 | 0 | 5 | 8 | 0 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

02 | During a maintenance outage while performing a calibration of steam generator No. 2 low steam generator water trip setpoint it was found that the scram contacts operated below T.S. limits by 1.5 and 1.3 inches. One previous event was reported as LER 77-40. There were no adverse effects on the public health or safety in that the scram logic is 2 out of 4 with 2 channels within T.S. limits.

09 | SYSTEM CODE | I A | 11 | CAUSE CODE | B | 12 | CAUSE SUBCODE | C | 13 | COMPONENT CODE | I N S T R U | 14 | COMP. SUBCODE | E | 15 | VALVE SUBCODE | Z | 16

17 | LER/RO REPORT NUMBER | 8 0 | 21 | 22 | 23 | SEQUENTIAL REPORT NO. | 0 1 7 | 24 | 26 | 27 | OCCURRENCE CODE | 0 3 | 28 | 29 | REPORT TYPE | L | 30 | 31 | REVISION NO. | 0 | 32

ACTION TAKEN | E | 18 | 33 | FUTURE ACTION | Z | 19 | 34 | EFFECT ON PLANT | Z | 20 | 35 | SHUTDOWN METHOD | Z | 21 | 36 | HOURS | 0 0 0 0 | 37 | 40 | ATTACHMENT SUBMITTED | N | 23 | 41 | NPRD-4 FORM SUB. | N | 24 | 42 | PRIME COMP. SUPPLIER | N | 25 | 43 | COMPONENT MANUFACTURER | F 1 2 0 | 44 | 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 | The root cause of this event was determined to be a sensing line configuration deficiency possibly resulting in inadequate venting which could lead to instrument drift during calibration. The set point was adjusted to within T.S. limits and a design change was completed to allow proper calibration. No further actions are deemed necessary.

15 | FACILITY STATUS | G | 28 | 7 | 9 | % POWER | 0 0 0 0 | 29 | 10 | 12 | OTHER STATUS | NA | 30 | 44 | METHOD OF DISCOVERY | B | 31 | 45 | 46 | DISCOVERY DESCRIPTION | Calibration Procedure | 32 | 80

16 | ACTIVITY RELEASED | Z | 33 | 7 | 9 | CONTENT OF RELEASE | Z | 34 | 10 | 11 | AMOUNT OF ACTIVITY | NA | 35 | 44 | 45 | LOCATION OF RELEASE | NA | 36 | 80

17 | PERSONNEL EXPOSURES NUMBER | 0 0 0 0 | 37 | 7 | 9 | TYPE | Z | 38 | 11 | 12 | DESCRIPTION | NA | 39 | 13 | 80

18 | PERSONNEL INJURIES NUMBER | 0 0 0 0 | 40 | 7 | 9 | DESCRIPTION | NA | 41 | 11 | 12 | 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | 7 | 9 | DESCRIPTION | NA | 43 | 10 | 11 | 80

20 | PUBLICITY ISSUED | N | 44 | 7 | 9 | DESCRIPTION | NA | 45 | 10 | 11 | 80

8011 10 0482

NAME OF PREPARER: L. D. French PHONE: (413) 625-6140