



**Consumers
Power
Company**

REGULATED DISTRIBUTION
SERVICES UNIT

1980 NOV 10 AM 9 17

COPY

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • Area Code 517 758-0550

US NRC
DISTRIBUTION SERVICES
BRANCH

November 5, 1980

Director, Nuclear Reactor Regulation
Att Mr Dennis M Crutchfield, Chief
Operating Reactors Branch No 5
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 -
BIG ROCK POINT PLANT - TECHNICAL
SPECIFICATIONS AMENDMENT NO 33 -
CONTAINMENT SPRAY SYSTEM SURVEILLANCE

- References: 1) CPCo letter from DPHoffman to DMCrutchfield, dated July 7, 1980
2) NRC letter from WAPaulson to DPHoffman, dated August 11, 1980
3) CPCo letter from DPHoffman to DMCrutchfield, dated September 12, 1980

Reference 1 requested a Technical Specifications change to extend the surveillance interval for the containment spray system in accordance with Standard Technical Specifications guidance. Reference 2 issued Amendment No 33 which approved the requested change.

Implementation review of the change identified errors in the Amendment as described by Reference 3. Subsequently, it has been identified that the notation on the setpoints of Table 11.4.3.4 has been inadvertently omitted. This omission was identified to Mr Walter A Paulson of your staff on October 31, 1980. The correction of these notations to reflect previously approved setpoints (Amendment No 10, dated June 3, 1976) should be accomplished as follows:

Table 11.4.3.4

<u>Parameter</u>	<u>Set Point</u>
<u>Enclosure High Pressure</u>	< 2.2 Psig(a)
<u>Time Delay (b)</u>	> 13 Min < 15 Min(a)

8011100 489

P

Dennis M Crutchfield, Chief
Big Rock Point Plant
November 5, 1980

2

It is requested that the corrections identified herein and in Reference 3 be formally made so that the Big Rock Point Technical Specifications can accurately reflect current conditions.

Gregory C Withrow (Signed)

Gregory C Withrow
Senior Licensing Engineer

CC Director, Region III, USNRC
NRC Resident Inspector - Big Rock Point