



UNITED STATES  
 ATOMIC ENERGY COMMISSION  
 WASHINGTON 25, D.C.

Docket No. 50-29

October 11, 1962

Yankee Atomic Electric Company  
 441 Stuart Street  
 Boston 16, Massachusetts

Attention: Mr. Roger J. Coe  
 Vice President

Distribution

H. J. McAlduff	H. Steele
C. K. Beck	R. Huard
R. Lowenstein	G. Page
E. G. Case	Doc. Room
H. Shapar	Formal
P. Travelstead	Suppl.
P. A. Morris-2	LB-L&R readings
E. E. Hall	
D. C. Clark	
E. Tremmel	

Gentlemen:

Pursuant to the Initial Decision of the Presiding Officer dated October 10, 1962, and on the basis of a report from Yankee Atomic Electric Company dated October 10, 1962 that the physical modifications of the facility described in Yankee's Amendment No. 41 to its license application have been completed, and confirmation by the AEC's Division of Compliance of the satisfactory completion of these modifications, Amendment No. 4 to Facility License No. DPR-3 has been issued.

The amendment to the license (1) increases the maximum authorized steady state power level from 485 megawatts (thermal) to 540 megawatts (thermal) and (2) revises the technical specifications. Copies of Amendment No. 4, which revises License No. DPR-3 in its entirety, and the notice thereof which will be published in the Federal Register are enclosed.

Also enclosed are copies of the revised Technical Specifications (Appendix "A") of License No. DPR-3 and the Initial Decision.

Pursuant to Section 2.761(c) of 10 CFR Part 2, the Initial Decision remains subject to review by the Commission for a period of thirty (30) days after issuance.

Sincerely yours,

R. Lowenstein  
 Director  
 Division of Licensing and Regulation

Enclosures:  
 As stated above

NDMason/dk 10/15/62  
 MGaske  
 RBryan 10/17/62  
 EGCCase  
 OGC  
 Director  
 10/17/62

8011110 564

P