

1 UNITED STATES OF AMERICA  
2 NUCLEAR REGULATORY COMMISSION  
3  
4

5  
6  
7 247th MEETING OF THE  
8 ADVISORY COMMITTEE ON REACTOR SAFETY  
9

10  
11  
12 Room 1046,  
1717 H Street, Northwest  
Washington, D.C.

13 Friday, November 7, 1980  
14

15 The committee met at 8:32 a.m., pursuant to  
16 notice, the Honorable M. Plesset, presiding.

17 ACRS Members Present:

- 18 M. Plesset
- 19 J. Mark
- M. Bender
- M. Carbon
- 20 W. Kerr
- S. Lawroski
- 21 W. Mathis
- D. Moeller
- 22 D. Okrent
- J. Ray
- 23 P. Shewmon
- C. Siess
- 24 D. Ward

8011180072

25 Designated Federal Employee:

R. Major  
ALDERSON REPORTING COMPANY, INC.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

ACRS Consultants Present:

NRC Staff Present:

B. Snyder  
J. Collins

Industry Representatives Present:

P R O C E E D I N G S

1  
2 CHAIRMAN PLESSET: We will now come to order.

3 This is a continuation of the 247th meeting  
4 of the Advisory Committee on Reactor Safeguards.

5 During today's meeting, the Committee will hear a  
6 report on the status of the TMI-2 recovery program; discuss  
7 the seismic interaction study at the Diablo Canyon Nuclear  
8 Plant; discuss the BWR hydraulic scram systems; discuss  
9 Regulatory Guide 1.97, Revision 2, "Instrumentation for  
10 Light-Water-Cooled Nuclear Power Plants to Assess Plant and  
11 Environs Conditions During and Following an Accident," and  
12 lastly, discuss the ACRS proposed letter regarding the Nuclear  
13 Data Link.

14 We have received a request from ANS 4.5 Standard  
15 Working Group for time to make an oral statement on Reg Guide  
16 1.97, Revision 2. Appropriate time will be made available  
17 during our discussion of that regulatory guide.

18 Mr. Richard Major is the Designated Federal  
19 Employee for this portion of the meeting.

20 A transcript of the meeting is being kept and it is  
21 requested that each speaker first identify himself or herself  
22 and speak with sufficient clarity and volume so that he or she  
23 can be readily heard.

24 We will now begin this session of the meeting, and  
25 I will call on Mr. Snyder, who will give us some information

1 regarding recovery operations at TMI-2.

2 MR. SNYDER: John Collins actually is going to give  
3 you the presentation because he is our senior man on the site.  
4 I am the program director back here in Bethesda. John is the  
5 man on the spot, and I think he can probably better answer  
6 your questions that you may have about the site itself.

7 I am going to let John go ahead. I will be glad to  
8 answer any questions you may have also.

9 MR. COLLINS: Good morning. For the record, my name  
10 is John Collins, Deputy Director for the TMI Program Office,  
11 and Senior NRC Official at TMI.

12 What I would like to do this morning in the time  
13 allotted is to discuss briefly with you the current plant  
14 status, and then I do have some slides showing various  
15 pictures of both the first and the second containment entry.  
16 Up until yesterday we were on natural circulation by steam  
17 on the A steam generator, and steaming back to the main  
18 condenser, and then back to the primary system.

19 Yesterday afternoon or yesterday morning we went  
20 to a different cooling mode. I did issue a PN which I assume  
21 that you received some time in the afternoon, which identified  
22 that we are into what we now call a test to ambient. We have  
23 isolated bypass valves and have gone solid on both -- gone  
24 solid on the A steam generator. The B, of course, has been  
25 solid.

1 We are going to remain in that test mode for  
2 about 15 days, to determine whether or not we can maintain  
3 adequate cooling, just by cooling, by convection to the  
4 reactor building atmosphere.

5 At the conclusion of that 15-day test, we will  
6 take a look at and evaluate the data. If it looks good, the  
7 Licensee intends to remain in that cooling mode for the  
8 foreseeable future.

9 We did put this week into readiness the mini-decay  
10 heat removal system that is ready for operation. The only  
11 hold-up on that now is for the NRR Staff to conclude the  
12 necessary tech spec prior to its operation. But it is available  
13 in the event we do need it for back-up cooling.

14 We continue to maintain reactor system pressure  
15 by the standby pressure control system. Reactor pressure right  
16 now is being maintained at about 80 to 85 pounds.

17 The maximum in-core thermocouple reading is about  
18 180°. The average in-core is about 139. We did for a period  
19 of about 15 days actually lose natural circulation from about  
20 October the 15th until last Saturday. We did not experience  
21 any burps that we had been experiencing about every 24 to 30  
22 hours. And then on Friday of last week, we did finally  
23 experience a burp up to about 60°. The delta T after the burp  
24 dropped down to about 10°.

25 As of this morning, I just talked to the office, we

1 are back up now to about a delta T of 60, so it appears that we  
2 may be experiencing another burp over the weekend.

3 MR. SHEWMON: The burp represents a steam bubble?

4 MR. COLLINS: Represents the reestablishment of  
5 flow due to the density in water, recirculating water back to the  
6 core area. We call it burp because you do get a sudden surge  
7 of water through the generator.

8 The reactor building is still being maintained at  
9 negative pressure. It's about minus .3 psig. We will be  
10 releasing --

11 MR. MARK: Minus what?

12 MR. COLLINS: Minus .3.

13 This morning they will be initiating a small purge  
14 in the containment building, prior to a planned containment  
15 test on Wednesday.

16 As you know, if you have been following the status  
17 report that I have put out weekly, the major campaign on  
18 cleaning up the water in the auxiliary building as a result  
19 of the accident has been completed. Approximately 510,000  
20 gallons was processed. That water is being stored in various  
21 tanks in the EPICOR-II building, and also water in the  
22 condensate storage tank.

23 There is, of course, a continuing accumulation of  
24 water in the auxiliary building. That water is being held up  
25 in one of the available reactor coolant bleed tanks.

1           The auxiliary building leak rate has been fairly  
2 constant, at about .06 gallons per minute. The RCS leak rate  
3 has been fairly constant, too, at about .09 gallons per minute.

4           The major effort, of course, over the last couple  
5 of months has been to make containment entries. We have made  
6 three entries into the containment for the purpose of doing  
7 radiation mapping and dose evaluations.

8           We were successful in the last entry to remove  
9 the pre-amplifier for one of the effective neutron source  
10 monitors. We hope to replace those amplifiers on the entry  
11 which is planned for next Wednesday. Next week's entry will  
12 consist of 11 people going in both on the 305 and the 347  
13 level to gain additional information, hopefully, to take  
14 some more smear samples, some more radiation readings, and to  
15 take out some small pieces of equipment for further analysis  
16 by various laboratories.

17           That really sums up the major items at the plant  
18 at the present time. I would like to show you some slides.

19           (Slide.)

20           I think you are all familiar with the fantasy  
21 island. I have been using these at various talks over the  
22 last several months.

23           MR. OKRENT: That must be Three Mile Island 1, 2, 3,  
24 and 4; right?

25           MR. COLLINS: That's correct.

1 (Laughter.)

2 (Slide.)

3 This is the inner door, or the door that leads into  
4 the reactor building itself. The airlock door, of course,  
5 the outer personnel hatch is out upstream of this. This is  
6 what gave us the problem of why we were not able to make  
7 the entry the first time we had planned it, when we had to  
8 abort it.

9 This is the solenoid switch that was actuated.  
10 The safety pin sits directly inside the containment building.  
11 We were not able to rotate the seal to disengage the rabbit  
12 ears on the door.

13 Met Ed then went in and drilled through this solenoid  
14 to free up the pin and, of course, then we made the first entry  
15 which was a two-man entry, which lasted for approximately 20  
16 minutes.

17 As was indicated in some of our reports, the  
18 radiation readings inside were less than what we had anticipated  
19 them to be. The average readings on the 305 level were from  
20 about 400 to 700 mr. The two people who were in there for a  
21 stay time of 20 minutes received a total body dose of less  
22 than 200.

23 Now up on the second entry, of course, it was made  
24 with four people. They went in on a 305 again, and then  
25 went up to the 347 level, the refueling area. The radiation



1 readings up there were about half of what they were on the 305  
2 level.

3 We were able also to get really good readings in  
4 the stairwell which leads down into the sump, which I will show  
5 you pictures of, and the water, and it appears that based on  
6 the teletechter readings, the radiation reading directly above  
7 the water itself is about 120R, which is pretty consistent  
8 with the measurements that were made through the 401 penetration  
9 and the 627 penetration.

10 (Slide.)

11 This is another picture of the famous door.

12 (Slide.)

13 This shows you a picture of the individual. This  
14 was the first entry. This shows you the type of equipment  
15 he was wearing. Of course, the Scott self-contained unit.  
16 The equipment he was equipped with -- later on I will show you  
17 some pictures of all of the TBDs that were strapped on him --  
18 this total weight of equipment, plus his clothing, was  
19 approximately 89 pounds.

20 (Slide.)

21 This shows -- this was on the second entry. Of  
22 course, you can see the difference now. They did not have  
23 to wear the self-contained units. They were using positive  
24 pressure bore units with particulate filters, because the  
25 analysis of the airborne activity in there did not warrant the

1 use of a self-contained. This, of course, allowed them to make  
2 a stay time of up to about 40 minutes. Again, their clothing  
3 this time was not nearly as heavy as it was on the first one.  
4 The total weight of equipment, plus the clothing, was approxi-  
5 mately 40 pounds.

6 (Slide.)

7 Here is on the 305 level. We thought this was a  
8 rather intriguing picture, because it shows you the amount of  
9 rust that had accumulated on the grating, but it is not what  
10 we had expected to see, due to the relatively high humidity  
11 inside the building. We expected to see a lot more rust  
12 than we did which, of course, would further complicate the  
13 decontamination of the building.

14 As you know, in some of the pictures that we were  
15 able to take through the 627 penetration, you could actually  
16 see water droplets passing by the camera.

17 (Slide.)

18 This is an electric heliarc welding instrument. From  
19 our debriefing of the two people who were in there, the  
20 cabling looks very good. The unit itself appears to be in  
21 fairly good condition.

22 (Slide.)

23 MR. SHEWMON: What caused the extreme -- it looks  
24 like there was a flash of something that scorched part of the  
25 face, but not the rest.

1 (Slide.)

2 MR. COLLINS: Well, we are not really sure, but  
3 most of the scorching, we believe, either occurred from the  
4 hydrogen burn or the hydrogen explosion that occurred in the  
5 containment building several hours after the accident  
6 initiated. We did see the pressure transient up to about 28  
7 psi. We believe that caused that. I will show you a better  
8 picture of some deformation of equipment in some of the later  
9 shots.

10 (Slide.)

11 This is looking down into the water, into the sump.  
12 We were able, of course, to put a teletector down in this  
13 area here, which gave us a fairly good reading right over the  
14 water.

15 What is of interest in here is the amount of debris  
16 that can be seen in the water. We are not really sure where  
17 that debris came from, but there is quite a bit of it laying  
18 on top of the water.

19 (Slide.)

20 Here is another picture, and you can see again  
21 some debris sitting down in this area here.

22 (Slide.)

23 Here was back to the first entry. We were just  
24 walking around, taking the various radiation readings around  
25 the D ring.

1           Of interest, though, is even noting the fire  
2 protection system look, in fairly good condition, again the  
3 amount of rust on the floor was not nearly what most of us  
4 had anticipated we would see.

5           (Slide.)

6           This, of course, is looking at the bottom of the  
7 core flood tank. Again it appears to be in very good condition.

8           (Slide.)

9           Here again is another shot going the other way  
10 around the D ring. Again you can see the floor looks in fairly  
11 good shape. The piping is stainless steel piping, and does  
12 not appear to have suffered any type of corrosion or rusting  
13 at all.

14          (Slide.)

15          This was up on the refueling deck. The two men here  
16 on the second entry were taking various smear samples and  
17 radiation readings underneath the bridge.

18          (Slide.)

19          This again is on a refueling area. We are not quite  
20 sure what this is. We haven't yet been able to discern what  
21 that is. It looks like a piece of metal cable piping that  
22 became dislodged from some place, but we really haven't -- we  
23 are going to take a further look at that in our next entry.

24          MR. BENDER: Have there been some surface smears?

25          MR. COLLINS: Yes, there have been, very, very many.

1 In the first entry we were successful in getting approximately  
2 eight. Two of them were lost on the way out, and then on the  
3 second entry, there were in the order of 20, 25 smears. On  
4 the third entry -- on the third entry, the camera they took in  
5 with them for some reason malfunctioned, and so there are no  
6 pictures of the third entry.

7 MR. BENDER: Did they show any apparent radioactivity  
8 at all?

9 MR. COLLINS: Yes, they did. On smear samples  
10 they saw both cesium and strontium.

11 MR. BENDER: Thank you.

12 (Slide.)

13 Again this is just some of the floor area, some of  
14 the stairwells.

15 (Slide.)

16 This was, I think, interesting, too. This is just  
17 some hosing, high pressure hosing that was inside the reactor  
18 building, and does not appear to be brittle. It appears to be  
19 in fairly good condition.

20 (Slide.)

21 This is just one of the drains. This particular  
22 drain spout here is normally used when you are going to pour  
23 liquid down the drain. You take the cover off and put it in.  
24 This normally is galvanized. Of course, it has sustained  
25 quite a bit of corrosion.

1 (Slide.)

2 Here is the interesting one. This telephone is  
3 up on the 347 level, and actually the picture doesn't do  
4 justice, when talking to the two men who shot the picture.  
5 This wiring, you can see, is very, very brittle. The telephone  
6 itself has been badly deformed, suggesting, of course, that  
7 there were extreme temperatures inside the reactor building  
8 as a result of the burn or the explosion.

9 (Slide.)

10 Again some more pictures of the floor.

11 (Slide.)

12 This is an interesting shot. This is up on the 347  
13 level. There are three drums here. The operators who were in  
14 there didn't actually see this. They just happened to take a  
15 picture -- they were actually trying to take a picture of this,  
16 and this got included. We are not really sure what is inside  
17 these drums, but in taking an educating guess, this probably  
18 contains some lube oil. This one probably contains some water,  
19 and then when you did have the explosion, you got that deforma-  
20 tion effect; whereas the other two did not. So it could be  
21 either transformer or some lube oil in there.

22 Again, this is one of the jobs that will be looked  
23 at a little more carefully in our next entry where we have 11  
24 people going in.

25 (Slide.)

arl5

1 This is a picture, of course, of the refueling  
2 bridge. We are going to check this out carefully this time.  
3 There is some thought that perhaps it may have disengaged  
4 from its trolley slightly. This picture would not suggest  
5 that, but Met Ed wants to make a careful examination while they  
6 are in there.

7 (Slide.)

8 Again, I think of interest here was this fire hose  
9 on the wall. It appears again not to have sustained any type  
10 of damage to it.

11 (Slide.)

12 This is the door leading up from the sump area, the  
13 lower level, and I have a close-up picture of this that you  
14 can see. This door was blown open in some type of an explosion,  
15 and then wrapped around this plate very neatly.

16 (Slide.)

17 MR. BENDER: That door enclosed what, again?

18 MR. COLLINS: This is the stairwell going down into  
19 the lower level. You can see how this thing was blown up  
20 against this thing, and badly deformed.

21 Now the door on the upper level did not show this  
22 at all. In fact, it was in very good shape. It was open.

23 (Slide.)

24 This is just another -- this is one of the emergency  
25 telephones. Again it doesn't appear to have -- even the

1 wiring here didn't appear to have suffered any type of damage.

2 (Slide.)

3 Again here is another one. Same thing. Now this  
4 one shows a little brittleness in the lower part here.

5 (Slide.)

6 This is just some of the structures.

7 (Slide.)

8 Piping again appears to be in fairly good condition.  
9 You do see some rust around the bolts, but not to any great  
10 extent.

11 (Slide.)

12 (Slide.)

13 This shows the -- this is on the refueling deck,  
14 and we are looking at one of the cable trays, and the  
15 discussion of the people after our debriefing said it appears  
16 to be in very excellent condition. Even the motors and switch-  
17 gears.

18 (Slide.)

19 This, of course, is the elevator. We had thought  
20 at first from looking at it, it appeared that it might have  
21 been jarred off of its normal carriage. A close-up picture of  
22 it did not indicate that to be the case.

23 Again we are looking at one of the emergency phones.  
24 We see a little bit of brittleness, but to the extent that we  
25 saw on the other telephone.



1 (Slide.)

2 Here they are getting ready now to come out. They  
3 are taking up their equipment and lugging it up prior to making  
4 an egress.

5 (Slide.)

6 This is, of course, a heavy duty extension on a  
7 wooden dolly, and the wooden dolly does not appear to be charred  
8 in any way, nor does the cable itself. It does not appear to be  
9 damaged in any way.

10 (Slide.)

11 Now this was on the second entry, too. You can  
12 see the number of TLDs that were on these people. Of interest  
13 here is that all the people who went in there had digital  
14 readouts on their dosimeters, and they were being read out  
15 continually in the command center. They had an administrative  
16 limit placed on them that if their cumulative dose reached  
17 625 millirems, they were immediately to make an egress. We  
18 have never approached that at all.

19 On the second entry, the total maximum dose received  
20 by any of the men in there was less than 400 millirems.  
21 Even on the third entry, the maximum was less than 500.

22 (Slide.)

23 Again this is some of the operating panel for the  
24 refueling bridge.

25 (Slide.)

1           This, of course, was an interesting shot. This is  
2 one of the emergency lights. You can see that the glass here  
3 has turned an amber color. We were successful in removing some  
4 glass of the same type or the same color, and that is under  
5 analysis in Idaho at the present time.

6           This should give us a pretty accurate reading as  
7 to what the total integrated dose had been since the accident,  
8 since glass is a good indicator of that.

9           (Slide.)

10          Some more pictures.

11          (Slide.)

12          Here is a better picture and a close-up of the  
13 elevator door, where we had originally suspected it might  
14 have been slightly off edge. This picture would not suggest  
15 that at all.

16          (Slide.)

17          Again this is just showing the equipment that the  
18 individuals had carried in with them. Of course, this is an  
19 RO-2A, a monitor which monitors beta radiation. This is his  
20 high-powered light that he carried with him. Each of them had  
21 one, and then he's got a miner's light on his head.

22          (Slide.)

23          This, of course, was interesting, because these  
24 are the things that are used to remove the bolts off the head  
25 of the reactor, and they are covered with a plastic coating,

1 and you can, of course, see that due to extreme temperatures,  
2 some of that plastic has melted off in this area.

3 We were able to get some samples of this, too.

4 This, again, looking at the same door picture  
5 and some of the drums and the floor area was not nearly as  
6 bad as we thought it would be, and I think that's a plus,  
7 because that should help us in decontaminating the building.

8 (Slide.)

9 Just some more shots that were taken showing various  
10 piping systems. Again, all of them appear to be in fairly good  
11 condition.

12 (Slide.)

13 This is part of the in-core thermocouple structure.  
14 This is steel braided pipe, and does not appear to have sustained  
15 any type of damage.

16 (Slide.)

17 And, of course, then a picture of the reactor itself,  
18 which looks in pretty good shape, too.

19 And that's it for the slides.

20 CHAIRMAN PLESSET: Jerry?

21 MR. RAY: Have you had any failures of electrical  
22 equipment components or electrical conductors in containment?  
23 And have they been energized in the meanwhile?

24 MR. COLLINS: We have not lost any since the time we  
25 opened DHV-2, which was several months after the water level

1 began to rise, because actually it is submerged in water now.  
2 There was some concern several months ago about not the water  
3 level increasing so much, but the high humidity may start to  
4 affect some of the electrical switches on the decay heat valves,  
5 and that was the reason why we went ahead and opened up DHV-1.

6 MR. KERR: What is a DHV?

7 MR. COLLINS: DHV is decay heat valve or pipe, a  
8 valve, that permits you then to -- we opened up DHV-1, we were  
9 not successful in that. Of course, there is a bypass on that,  
10 it's DHV-171, but it was not necessary to do that, DHV-1 did  
11 open, but we were afraid that we may lose it because of high  
12 humidity. Not the water level itself. It's approximately three  
13 feet above the water level right now. It's the closest one to  
14 the water level. The water level has not been rising  
15 significantly. It is still approximately eight feet.

16 MR. RAY: Have these components been under voltage  
17 in the meanwhile?

18 MR. COLLINS: Yes, they have, and they have been  
19 merged on a weekly basis, oh, for months.

20 MR. RAY: And the insulation is holding up?

21 MR. COLLINS: Yes, it is.

22 CHAIRMAN PLESSET: Any other questions?

23 Carson.

24 MR. MARK: You said, I think, it was a piece of  
25 glass was going to give you a good integrated dose measurement.

1 MR. COLLINS: That's correct.

2 MR. MARK: Gamma and beta, or just gamma?

3 MR. COLLINS: Just gamma, just gamma.

4 MR. MARK: That was one question. Another is, has  
5 there been a thorough and respectable and authentic inventory  
6 of fission fragments, where they are, where is the iodine,  
7 where is the cesium, and so on, and how much?

8 MR. COLLINS: I would not say that there has been a  
9 thorough evaluation. There have been various evaluations made  
10 both by the Licensee and by B&W and by the Staff, but that  
11 effort is continuing. I don't think that I would want to leave  
12 you with the impression that that analysis is thorough at the  
13 present time.

14 MR. MARK: Well, now, in the Rogovin Commission  
15 Report, there was a table which was put in as an analysis or  
16 inventory, and it seemed to me to show that the amount of  
17 cesium and the amount of iodine thought then to have been in  
18 the water were very much -- very close to the ratio in which  
19 they would have existed in the core. But I didn't feel that  
20 one could take a measure of the total fraction from the core  
21 that was there. It seems to me that is a very interesting  
22 point, and it deserves perhaps more attention than looking at  
23 the telephones. Because all one knows is that the release  
24 fraction of iodine was a factor of  $10^4$  or  $5$  down from what  
25 WASH 1400 would have told you to expect, given the noble gases,

1 the cesium didn't come out, and is that in the form of cesium  
2 iodide? Because that's the thermodynamically favored compound,  
3 and it's very important, if that's the case --

4 MR. COLLINS: Well, there was a paper that was  
5 presented at the Air Cleaning Conference, and you may want to  
6 take a look at it, in which SAI has done or did quite an  
7 evaluation, and by their analysis they would demonstrate that  
8 most of it lies in the cesium iodide.

9 Now with respect to your question as to why more  
10 iodine was not released, if you calculate the iodine inventory  
11 that was available for release and then compare that to what  
12 WASH 1400 would suggest, that matter, of course, is under  
13 investigation and review by the Staff. My own personal opinion  
14 is that, first of all, I think there was an enormous amount  
15 played out inside the reactor building itself. The principal  
16 points of release outside the reactor building were from the  
17 letdown system. At that point in time, you had reduced  
18 pressure from temperatures compared to what you would have  
19 inside the reactor, so that our partitioning factors from the  
20 gas to the liquid phase of iodine is based on the partitioning  
21 at hot water, meaning water that would be at the operating  
22 temperature pressures, so that we may be conservative in a  
23 partitioning factor at that point outside the primary system.

24 MR. MARK: But if you assumed it was cesium iodide  
25 that was there you would have a radially different partitioning

1 factor.

2 MR. COLLINS: That's correct.

3 MR. MARK: And that the iodine is much less  
4 volatile, the compound is pretty stable.

5 MR. COLLINS: It's stable at certain pHs, and I  
6 think that one would have to consider the pH, so if you took a  
7 look at the pH basically normally it's about a pH of 5. I  
8 am not sure that that statement would be completely valid. I  
9 think the partitioning factor would be different. I think we  
10 are assuming a partitioning factor at a much higher pH than  
11 what we actually saw in the primary system at the time of the  
12 accident.

13 MR. MARK: Was that an unusual pH in the primary  
14 system, or just what things normally?

15 MR. COLLINS: Just what they normally are.

16 MR. BENDER: John, is there any way of knowing what  
17 the activity is on the inside of the pressure vessel?

18 MR. COLLINS: No.

19 MR. BENDER: What kind of steps would be taken to  
20 try to find that out?

21 MR. COLLINS: You mean inside the reactor itself?

22 MR. BENDER: Inside the reactor. It seems to me  
23 what you can do lies in whether you will be able to take that  
24 head off, and when you will be able to.

25 MR. COLLINS: From the information that I have seen

ar24

1 developed by Bechtel, I have not seen any firm program for trying  
2 to acquire that information. But I agree, I think it would be  
3 very important to know that before you start lifting that head  
4 out.

5 CHAIRMAN PLESSET: Dade, you had a question?

6 MR. MOELLER: I think what both Carson and Mike --  
7 what their questions show is that although we have learned a  
8 lot of lessons, and the Staff has summarized many of the  
9 lessons learned, apparently or obviously there are still many  
10 lessons yet perhaps to be learned, which won't be learned  
11 until you complete your investigations. Is that correct?

12 MR. COLLINS: I think that is a very accurate  
13 statement. I don't think that we have really scratched the  
14 surface on some of the information that would be gained from  
15 a complete evaluation of various components inside the reactor  
16 building, and that information is being accumulated under  
17 the Technical Information Office, which is a concerted effort  
18 between DOE and NRC and EPRI and GPU, and there is a deliberate  
19 program to try to acquire all of this data at various points  
20 in the program itself, and each one of the containment entries  
21 is designed to collect additional information that would aid  
22 us not only in decontaminating the plant, but would aid us in  
23 understanding whether or not the criteria presently being  
24 applied to other plants should be upgraded. I think there is  
25 an enormous amount of information that has not been learned



1 from the accident.

2 MR. MOELLER: Could I ask one more?

3 CHAIRMAN PLESSET: Sure.

4 MR. MOELLER: How is the plan for each entry  
5 developed, and who all is involved? Are you, for example,  
6 involved?

7 MR. COLLINS: The first two entries, Dade, were  
8 made by Met Ed personnel, and that was primarily for the  
9 purpose of doing initial radiation mapping in the area itself,  
10 and to get a handle as to what kind of radiation exposures  
11 the future teams would be encountering.

12 At the conclusion of the second one, the rest of  
13 the entries have been turned over now to Bechtel Corporation,  
14 and Bechtel has been assigned, of course, the task of putting  
15 together the total recovery and refueling program. There are  
16 very deliberate programs for each one of the entries. They  
17 are reviewed, of course, by Met Ed people and GPU engineering.  
18 They have been submitted to us for our review and solicitation  
19 for any additional information we feel that is necessary.

20 Our people who are on the site, on the staff up  
21 there, participate in most of the meetings as the information  
22 is being jelled, together for each one of the entries, so that  
23 we are very knowledgeable of the programs that will be conducted  
24 each time.

25 MR. LAWROSKI: Have you been able to learn

1 anything from the analysis of the primary samples, as to  
2 whether or not there is a reaction to postulated --

3 MR. COLLINS: Yes, I think there has been some  
4 very detailed analysis done on the primary system water, both  
5 by GPU and by ourselves. I am not in a position to give you  
6 the analysis.

7 MR. SHEWMON: When you say by NRC, those presumably  
8 were not done in Silver Spring. Were they done by Savannah  
9 River, or who did them for you?

10 MR. COLLINS: Well, I'm not sure your statement is  
11 completely accurate. The people in Silver Spring, some of  
12 our research people, were involved.

13 MR. SHEWMON: You have an analytical laboratory  
14 there?

15 MR. COLLINS: No, we took the data that was being  
16 derived from the primary samples, which for months after  
17 the accident was being analyzed by two laboratories, Oak Ridge  
18 and Savannah.

19 MR. SHEWMON: I had heard of some of the things  
20 in Savannah River. I didn't know what other sources you had.

21 MR. COLLINS: Right after the accident, Bettis,  
22 B&W and Oak Ridge were analyzing samples.

23 MR. SHEWMON: One of the things that circulated  
24 out of the Savannah River was that we heard that you did not  
25 find particulate dissolved fuel, or particulate zirconium oxide

1 in that, to the extent that some people would have expected, if  
2 we had had a severe reaction between water and zirconium.

3 MR. COLLINS: That's correct.

4 MR. SHEWMON: Okay.

5 MR. COLLINS: One thing of interest, though, was  
6 although we did not see the transuranics in the samples of  
7 the primary coolant water, they were all down in the parts per  
8 million range in the initial samples. When they removed the  
9 filter from the letdown stream, they removed that to decontaminate  
10 it, they smeared the inside of the filter casing. We did see  
11 at that time -- and that happened about a month ago -- we did  
12 see the transuranics in good quantities. The filter itself  
13 has been taken offsite and is being analyzed at the present  
14 time for a more thorough analysis and I am quite anxious to  
15 see that. I am not -- I don't think I fully understand what  
16 happened, because if you remember, it was hours after the  
17 accident occurred that that filter was isolated, and it was  
18 bypassed, and then several days later we finally bypassed the  
19 demineralizers because the water temperature was going up and  
20 we were afraid of deforming the resins. But I don't quite  
21 understand why we saw it in that filter casing and then we did  
22 not see it in the primary coolant samples that were taken  
23 immediately after that.

24 MR. LAWROSKI: Are you satisfied with the quality of  
25 samples you have been able to get?

1 MR. COLLINS: Absolutely. Absolutely.

2 CHAIRMAN PLESSET: Bill Kerr.

3 MR. KERR: Mr. Collins, at some point I assume you  
4 plan to take the water out of the containment. What is  
5 the schedule for that?

6 MR. COLLINS: Well, Metropolitan Edison has, since  
7 last November, when they submitted a request to us for  
8 approval of the submerged demineralizer system, they have been  
9 in a mode of installing that submerged demineralizer system  
10 into the fuel pool. We have-- the NRC, of course, has not  
11 given approval for that. We have notified Metropolitan twice  
12 that they are proceeding at their own risk.

13 Our approval of that system will come after the  
14 finalization of the programmatic environmental impact  
15 statement, which we have been committed to put together. That  
16 system is a system that could treat the water from the reactor  
17 building.

18 MR. KERR: The environmental impact statement is  
19 not primarily a safety analysis; is that right? It's a  
20 conventional primary environmental impact statement?

21 MR. COLLINS: That's correct, but we required  
22 Metropolitan Edison to submit to us in their technical  
23 evaluation report a completed safety analysis and a determination  
24 under the 50.59 as to why it should not be an unreviewed safety  
25 question. That information is forthcoming to us.

1 MR. KERR: It strikes me that it would be desirable  
2 to get that water out of there in the interest of safety.  
3 How do you balance the need for the amount of paper work and  
4 review required on the environmental impact statement and  
5 the other procedure against the enhancement of safety that  
6 might occur if you went ahead and got the water out, with  
7 perhaps a somewhat less detailed documentation?

8 MR. COLLINS: Well, I think on one hand, you have  
9 to say that the Commission has dictated to the Staff that we  
10 would develop a programmatic impact statement addressing the  
11 total clean-up program.

12 MR. KERR: But the Commission also depends on the  
13 Staff for recommendations, doesn't it?

14 MR. COLLINS: That's correct. But also within the  
15 order itself, we do have the authority -- the Director of NRR  
16 does have the authority to initiate the operation of that system  
17 or other treatment systems, in the event there was an imminent  
18 danger. In balancing the risk, I guess you would have to say  
19 you have to take a look at what is the probability of potential  
20 problems. The water leakage from the RCS system in the  
21 reactor building is very small.

22 MR. KERR: How do you determine the potential for  
23 danger under these circumstances?

24 MR. COLLINS: I think the potential or the most  
25 credible accident I can conceive of at the present time -- and

1 it is addressed in the impact statement -- would be for water  
2 to leak out of the building.

3 Now we recognized that that was a potential  
4 problem, and we requested Metropolitan Edison to install  
5 test wells around the reactor building.

6 MR. KERR: There is no equipment that is likely to  
7 fail or nothing that is likely to fail while people are going  
8 through all this routine about which you are concerned?

9 MR. COLLINS: At the present time, no. The  
10 major equipment that we were concerned with was the actuation  
11 of the motors to open up the valves that would permit us to  
12 pump the water out of the building.

13 MR. KERR: From your point of view, there is no  
14 particular danger in letting that reactor system sit there  
15 indefinitely?

16 MR. COLLINS: Well, I wouldn't want to say that,  
17 because I would characterize it by saying the sooner you clean  
18 up the plant, the sooner you remove the fuel, you remove  
19 potential problems.

20 MR. KERR: Well, I would, too, and --

21 MR. COLLINS: I won't argue that. I would like to  
22 see the program proceed on a much more escalated scale, but I  
23 recognize that we have certain other constraints placed on us  
24 by other agencies.

25 MR. KERR: Have you told these other agencies that

1 you consider perhaps you have an emergency situation and hence  
2 perhaps one might bypass something, like, for example, a  
3 full-fledged environmental impact statement before one starts  
4 clean-up operation?

5 MR. COLLINS: I think the Council on Environmental  
6 Quality has been fully briefed on the problems that could occur  
7 in the plant.

8 MR. KERR: But they look to the NRC, it seems to me,  
9 to make pronouncements on safety. They may not agree with  
10 them, but you are the agency who takes the initiative, aren't  
11 you?

12 MR. COLLINS: That's correct, and I would not want  
13 to say that that plant right now is in imminent danger.

14 MR. KERR: I don't know what it's in, but you did  
15 tell me that you thought the sooner the clean-up started, the  
16 better off -- the better things would be.

17 MR. COLLINS: Well, that's true, because every time  
18 you enter a plant, you have a potential for exposure to the  
19 workers.

20 MR. KERR: If you feel it's a contribution to safety,  
21 do you think it's better to wait until one goes through the  
22 environmental impact statement and perhaps hearings and so on,  
23 before one starts clean-up? Could one establish, to some  
24 reasonable degree, that the system is likely to operate, start  
25 the clean-up operation sooner?

1 MR. COLLINS: Well, even if we were to give approval  
2 for the submerged demineralizer system now, it would not be  
3 operational till mid-March, anyway, and that's about the same  
4 timeframe which we expect to finalize the environmental impact  
5 statement in.

6 MR. KERR: So the system could not start operating  
7 immediately, even if all approvals existed?

8 MR. COLLINS: No, right now it could not. It's not  
9 nearly that completed. I'm sure that if they went to a  
10 three-shift operation and a seven-day work week, they could  
11 escalate that schedule. But I don't think that -- and if we  
12 saw a potential problem and the probability increasing, it  
13 certainly could be done.

14 MR. KERR: It certainly seems to me that it would be  
15 a good idea to get that water out and start the clean-up  
16 operation as soon as feasible. I wouldn't say as soon as  
17 possible, but --

18 MR. COLLINS: I think that is the mode in which  
19 Metropolitan Edison is trying to operate, based on their own  
20 financial constraints, which are serious at this time.

21 MR. KERR: Are the financial constraints holding  
22 up the installation and testing of the water clean-up system?

23 MR. COLLINS: No, that's one of the programs that  
24 has been continuing. That is included in the programs they  
25 are continuing to install, that system.



ar33

1 MR. KERR: Well, I misunderstood a recent letter  
2 from Mr. Snyder, I guess, because I had thought I was seeing  
3 something that told them that they could not begin operation  
4 of the clean-up until the environmental impact statement was  
5 completed; and to me, that implied they were about ready to begin  
6 operation, but they were being prohibited therefrom.

7 That apparently was not the sense of it.

8 MR. COLLINS: Mr. Snyder was saying the NRC will not  
9 consider approval or disapproval of the system until the  
10 impact statement has been completed, and we were very cognizant  
11 of the fact that they are proceeding to install that system, and  
12 we are continuing to do our formal review, and we are continuing  
13 to do our technical evaluation with regard to the operation of  
14 the system. But if an emergency exists, the Director of NRR  
15 does have the authority to initiate operation of that system,  
16 or any other treatment system to handle the removal of the  
17 water.

18 We have also requested Metropolitan Edison to  
19 submit to us a contingency plan for removing the water in the  
20 event that that particular system were not available. We have  
21 just received the response, and it is under evaluation at the  
22 present time. I just received it yesterday.

23 CHAIRMAN PLESSET: Paul?

24 MR. SHEWMON: Two questions:

25 One, where is this filter you were talking about?

1 MR. COLLINS: It's on the letdown system. It's the  
2 letdown filter. As you come out through the letdown, through  
3 the filter, through the demineralizer, and into the makeup tank.

4 MR. SHEWMON: Okay. Completely different question:  
5 Will we hear today about the problems of getting  
6 this waste off the site, or what you have accumulated for the  
7 wastes and potential deterioration of the resin beds, or what  
8 the schedule on that is?

9 MR. COLLINS: Well, let me say that we are continuing  
10 -- let's differentiate those two types of wastes. There is  
11 the combustible, the normal waste that is accumulated, as far  
12 as the decontamination, and that waste that is being put in  
13 55-gallon drums and wooden boxes, and that's continually being  
14 shipped to Richland. With regard to the EPICOR, the resins  
15 that were generated in the EPICOR-II system, we are processing  
16 500,000 gallons of water. They are being stored in the  
17 concrete storage facility on the island.

18 Last November the Commissioners issued an order  
19 to Metropolitan Edison, telling them that the resins must be  
20 solidified. At the present time, Metropolitan Edison is  
21 prepared to go out for quotations to several vendors for a  
22 system to solidify the second and the third stage resins.  
23 So that program is underway.

24 Now with regard to the resins from the first stage,  
25 from the higher activity, the Staff does not believe that

1 because of the high curie per cubic foot loading, that they  
2 should be taken to a shallow land burial ground. We are  
3 investigating with the Department of Energy alternative  
4 ways of disposal of those resins, and those negotiations are  
5 continuing. We are looking also at various solidification  
6 methods for those resins.

7 MR. SHEWMON: Even if they were solidified, you  
8 wouldn't want them there because of the high activity level, or  
9 because of the high activity level you weren't sure they would  
10 solidify?

11 MR. COLLINS: The latter. Both of them. If once  
12 they are solidified, they will be shipped, the second and  
13 third stage resins will be shipped to --

14 MR. SHEWMON: Let's talk about the first stage.

15 MR. COLLINS: The first stage resins, right now  
16 the major effort is tied to identify the resin mixes themselves,  
17 because they were -- they are not all uniform. The vendor  
18 did change various resin beds with various mixes, and it is  
19 incumbent upon us to try to determine what those variations  
20 are, so that we can then proceed in a more intelligent way to  
21 try to understand how we might solidify those. Or maybe you  
22 don't want to solidify them, maybe you want to try to remove  
23 those reactivity concentrates, and then solidify them.

24 MR. SHEWMON: That's already pretty concentrated.

25 MR. COLLINS: It's pretty concentrated, yes. Some of

ar36

1 those beds were loaded up to as high as 1200 curies of  
2 activity.

3 MR. SHEWMON: Do they degrade with that kind of  
4 activity sitting on the shelf?

5 MR. COLLINS: We have a program underway at the  
6 present time, Metropolitan Edison does, to sample the contents  
7 of two lines. What they actually will be doing is trying to  
8 pull off some of the water that had already been dewatered.  
9 We want to go back now and try to dewater them again, and see  
10 if we can get some water off of there, take a look at it and  
11 see if there has been any appreciable change in the pH from the  
12 time it was put in there until the present day. And then, of  
13 course, do a chemical analysis on that. There are corrosion  
14 studies underway. We hope to get some gas samples off the  
15 top of those resin lines and see if there has been any  
16 degradation of the resin itself and gas formation.

17 On top of that, we intend to send to the first  
18 stage resins, we intend to send several donors to one of the  
19 Department of Energy laboratories for more detailed analysis of  
20 the first stage resins, so that we can then put together a  
21 technical report with the Licensee that would establish programs  
22 for handling those resins, and also the resins that will be  
23 generated from the operation of the SDS, if the SDS is approved.

24 MR. SHEWMON: The usual resins that are shipped offsite  
25 are not solidified; is that right? Say Dresden 2 or something?

1 MR. COLLINS: At the present time, that's true,  
2 but all power reactors were issued a letter last fall which  
3 required them by July of 1981 to have systems in place for  
4 solidification, and this is consistent with the requirements  
5 that are now being placed on them by the burial ground, such  
6 as Richland and Barnwell and Nevada. They have also incorporated  
7 those requirements into their license conditions. So by mid-  
8 next year, all of the resins from all power reactors will have  
9 to be solidified.

10 MR. SHEWMON: Thank you.

11 MR. COLLINS: The problem that complicates the  
12 resins at TMI is that they are both a mixture of inorganic-  
13 organic resins. There was a change shortly after the operation  
14 of EPICOR-II where we went to using the zeolite mixtures  
15 in the first filters for better removal of the cesium and  
16 that, of course, is all proprietary information. We are in  
17 negotiations with the vendor to acquire that information, and  
18 once we have that together, with the information we can obtain  
19 from the work that Met Ed is doing, on trying to sample the  
20 contents and the information that will be gained from the  
21 liners that will be sent to DOE, I think we are going to have a  
22 much better handle on how to handle those resins.

23 It may turn out we don't want to solidify them.

24 MR. MARK: You mentioned the exposure of the people  
25 who entered. In fact, it's going to be lower on later entries.

1 This is gamma exposure, I presume? Those suits will keep  
2 the beta from being a factor at all?

3 MR. COLLINS: Well, the beta right now is very  
4 low inside there.

5 MR. MARK: All right. Now also the exposure levels  
6 are lower than expected. Is it not possible to stick probes  
7 through the hole in the wall, for that matter?

8 MR. COLLINS: We did, through the 627 penetration  
9 and the 407 penetration, but, you know, sticking a probe  
10 inside, you are only able to get in a few feet inside that  
11 wall. But, you know, you are going to experience hot spikes  
12 throughout that building, and that's why we saw the range of  
13 400 to 700 at various points.

14 MR. MARK: I see. What you really saw was 400, but  
15 then it turned out to be much higher, and it turned out not to  
16 be?

17 MR. COLLINS: Much higher. We expected it to be  
18 in the R range, and it was not. That doesn't say that there  
19 doesn't exist in there some areas that may be above that, too,  
20 but they did not see them yet.

21 MR. MARK: Well, the gamma is not a very localized  
22 thing.

23 CHAIRMAN PLESSET: One last question. Mr. Ward?

24 MR. COLLINS: Well, I actually did on the equipment  
25 hatch see some localized radiation.

ar39

1 MR. WARD: John, I was curious about the photograph.  
2 You were uncertain about the contents of the drums. Does that  
3 mean that the utility people have looked at the photographs  
4 and they don't know what was in those drums?

5 MR. COLLINS: Well, they have -- these -- they are  
6 the ones that took the picture and they are the ones that are  
7 analyzing them. They do not know for sure what's inside those  
8 drums. They are going back and trying to reconstruct what  
9 occurred in there just prior to the accident. Nobody for sure  
10 can say that's lube oil or transformer oil or water or what.

11 MR. KERR: Is there any evidence that a distorted  
12 drum might have been put in that location initially?

13 MR. COLLINS: That's certainly a possibility. That's  
14 certainly a possibility. But then one would have to conjecture,  
15 too, that what caused the door to wrap itself around the pipe --

16 MR. KERR: No, I think it's quite likely, but I  
17 just wondered if people knew that the drum, when it was put  
18 there, was in good shape or --

19 MR. COLLINS: I have seen drums in buildings that  
20 have been distorted without explosions. My question is, why  
21 was it there to begin with.

22 MR. SHEWMON: Were they sealed or had they been  
23 opened?

MR. COLLINS: I don't know that.

25 CHAIRMAN PLESSET: Well, I think we have to go along.

ar40

1 Thank you very much.

2 MR. COLLINS: Thank you.

3 MR. KERR: It would be interesting to have some  
4 sort of schedule. Maybe one exists, if we knew where to  
5 look, of about where the clean-up process for the water is  
6 going to start.

7 MR. COLLINS: We have probably been sent this --  
8 the information is contained in the programmatic impact  
9 statement, the schedule. That schedule, of course, is going  
10 to have to be revised to reflect the cut-back in programs  
11 in accordance with Met Ed's spending level at the current  
12 time. As a result of those cut-backs, it's going to have a  
13 domino effect, and that will be reflected in the program.

14 MR. KERR: When would you guess the water is likely  
15 to be removed, for example?

16 MR. COLLINS: Well, if everything were to go on  
17 schedule and, as I indicated to you, the current schedule is to  
18 have it operational by March, and if the impact statement --  
19 action on it is taken by the Commission in that same timeframe,  
20 then water could begin processing through the same system in  
21 about April or May, and then it would take approximately a year  
22 to process that water.

23 MR. KERR: Now back to my original question: When  
24 would you guess that the water is likely to be removed?

25 MR. COLLINS: I think my earliest guess right now is



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

that it probably could start being removed as early as April or May of 1981.

MR. KERR: Thank you.

CHAIRMAN PLESSET: Well, thank you. We will have to move on now to our next agenda item, which will be consideration of the interaction study at Diablo Canyon Nuclear Plant.

Dave, would you give the subcommittee report?

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

end AR  
Parker

1           MR. OKRENT: Yes. The agenda showed 30 minutes  
2 for the Subcommittee report and I expect to use less. So if  
3 I may, I would like to spend a couple of minutes commenting  
4 on the material that was brought to my attention Wednesday  
5 evening and Thursday morning, which is on a different  
6 subject but which I think is important.

7           We have received two letters addressed to you, one  
8 from Dr. Cochran and one from Mr. Pollard. And there are a  
9 couple of items in these letters that I would like to make  
10 some observations on, if I may.

11           In the letter from Dr. Cochran he refers to how  
12 the ACRS deals with the matter that arose when three GE  
13 nuclear engineers resigned, Messrs. Minor, Bridenbaugh, and  
14 Hubbard. And he says in his letter that the Committee's  
15 treatment of the three design engineers was shocking.

16           I am going to have to disagree with Dr. Cochran,  
17 and I choose to do it this way. I participated in the start  
18 of the review of that information. I was obviously not  
19 present at all meetings of all working groups, since we had  
20 a working group arrangement. However, at all the sessions  
21 in which I participated, I would say that Messrs. Minor,  
22 Bridenbaugh and Hubbard were treated much more gingerly and  
23 with much more reserve than the ACRS in general and I in  
24 particular treat the regulatory staff, the utilities or the  
25 reactor vendors. That is the first point.

1           Secondly, if you were to look at the letter dated  
2 May 19, 1976, which is entitled "Report of the Review of  
3 Statements by Messrs. Bridenbaugh, Hubbard, Minor and  
4 Pollard," we find that in fact the ACRS made a considerable  
5 number of recommendations for things that the regulatory  
6 staff should do based on the points raised by Messrs. Minor,  
7 Bridenbaugh, and Hubbard.

8           These were in fact not dismissed, but looked at in  
9 considerable detail, and in many cases supported. So I for  
10 one have to disagree with Dr. Cochran's observations. I do  
11 not recall whether he was present at any of the working  
12 group sessions at which I was present, but I have a feeling  
13 that he is somehow misinformed.

14           While I am talking about Dr. Cochran, I myself  
15 have frequently wondered how it is that the NRDC chooses  
16 priorities for those public risks that it will emphasize in  
17 what it brings to the fore before the Congress and so  
18 forth. And as an example, it has been clear to me and to  
19 many people for a decade or two decades that hazardous  
20 chemical wastes represent a very important public risk. It  
21 is not a potential risk. It is not something we might  
22 dispose of. It is something that is being disposed of in  
23 huge amounts.

24           The carcinogenic potential from these hazardous  
25 wastes is larger than that from a large reactor, and the

1 toxicity is much larger. And I have not found -- or rather,  
2 recently, at least in what I observed -- that NRDC has  
3 really looked deeply into what the practices were.

4           And similarly, there are many other public risks  
5 where I don't find, at least from what I read, that NRDC has  
6 placed what I consider proper public emphasis. And I have  
7 on previous occasions indicated that you can do a disservice  
8 by placing your priorities in incorrect regions. In other  
9 words, if you cause the public and the Congress and so forth  
10 to place their attentions in one area and distract them from  
11 another one that is more important, in fact you may not be  
12 reducing risks.

13           So at least at the moment, I guess I have  
14 reluctantly concluded, based on the information available to  
15 me, that as presently constituted NRDC lacks the breadth and  
16 perspective to act as a public interest group in my behalf.  
17 And I would be happy to learn why I am incorrect with regard  
18 to what I have said.

19           Now, Mr. Pollard, who I think is an able technical  
20 person, was invited in the past to appear when we first  
21 began looking at the TMI-2 indications in a broad way. We  
22 hoped he would come in and give us the benefit of what he  
23 thought were things that needed to be improved in safety. I  
24 am unhappy to say then he declined to comment.

25           I think he should reconsider his position. I

1 think for someone like him it is not necessarily in the best  
2 public interest to act only in what is primarily a political  
3 arena and not to have a technical interchange with a group  
4 like the ACRS.

5           So those are one man's opinions on some letters  
6 that were addressed to the ACRS, to Mr. Pollard. With that,  
7 I will go on to the item on the agenda.

8           Mr. Savio has a draft thing that you can look at,  
9 and he will have it out right now. And by the way, I ask,  
10 if Dr. Siess is going to be here, that he carry on because I  
11 have to leave at the end of the day. So if he would see it  
12 through tomorrow. All right.

13           Now, you will recall that as part of the TMI-2  
14 implications, the review, the ACRS tried to look at in a  
15 broader way -- and one of the things we asked ourselves was,  
16 for example, what would be different in a region having a  
17 high seismicity. And we said, well, maybe we have not  
18 looked hard enough at seismically induced interactions of  
19 non-safety systems; that really, TMI non-safety systems were  
20 of interest.

21           And we raised this question and it was later  
22 mentioned in one of our reports to the Commission. The  
23 Diablo Canyon group said that they in fact would look at  
24 their plant and see whether seismic effects on non-safety  
25 systems could interact in a significant way adversely on the

1 ability to shut the plant down, and they instituted a  
2 program which they themselves developed. They took an  
3 approach which I think is similar to what the Committee  
4 recommended might be an approach for Indian Point to do on  
5 systems interactions per se.

6           They first developed a written statement of how  
7 they are going to do it, and then they proceeded and have  
8 put a very considerable amount of effort into it.

9           We had a Subcommittee meeting recently -- I have  
10 forgotten which month; it may have been last month, October  
11 -- in which we heard a partial report on some of the kinds  
12 of things that they had found. And of course, we have  
13 looked in general at the methodology that they were using.

14           And in fact, they did find a reasonably large  
15 number of potential interactions. And in fact they have  
16 made corrections as a result of this.

17           I think the Subcommittee's impression was that  
18 they had done a workmanlike job. But I think it is for the  
19 Committee to hear from both the staff and the Applicant  
20 whether in fact this has been -- is in good shape now or is  
21 likely to be in good shape.

22           I would propose not to use any more of my  
23 introductory time and leave more for the staff and the  
24 utility, unless there are questions to me or the other  
25 Subcommittee members.

1 MR. PLESSET: Go ahead, Bill.

2 MR KERR: I participated in the Subcommittee  
3 meeting and I must say I was impressed by what seemed to me  
4 to be a very thorough and systematic approach.

5 MR. PLESSET: Any other comments?

6 MR. RAY: I support his statement.

7 MR. PLESSET: Thank you, Jerry.

8 Well, I think we can now go to the staff. Who is  
9 going to initiate that?

10 MR. BUCKLEY: My name is Bart Buckley. I am the  
11 NRC Project Manager at Diablo Canyon. Dr. Thomas is here to  
12 describe our results from the systems interaction study.

13 MR. THOMAS: Good morning. I am Cecil Thomas. I  
14 am a member of the Systems Interactions Branch of the  
15 Division of Systems Integration.

16 I would like to take a few minutes at the  
17 beginning of this subject to say a few words of  
18 introduction, primarily for the purpose of putting into  
19 perspective and setting the tone for the presentations to  
20 follow. I would like to begin just briefly going over the  
21 background of the program of the Diablo Canyon systems  
22 interaction program for seismic induced events.

23 Following my presentation -- following my  
24 presentation, PG&E will describe their program.

25 (Slide.)

1           And they will show you some pictures of some of  
2 the results they have obtained to date, describe their  
3 results, and what remains to be done. Following PG&E's  
4 presentation, I will get back up and describe our review of  
5 PG&E's program in more detail. So this is just basically a  
6 way of introducing the subject.

7           I would like to defer detailed questions about the  
8 program and our review of it until the third item.

9           (Slide.)

10           By way of introduction, I will briefly review the  
11 background of the program, I will tell you the objectives of  
12 the program, and describe just very briefly the approach  
13 that PG&E used to postulate systems interactions.

14           (Slide.)

15           The program was developed as a result of  
16 discussions concerning the effect of seismically induced  
17 failures on system safety at a November 1979 ACRS  
18 Subcommittee meeting. The requirement to conduct this  
19 program was subsequently documented in the Action Plan Task  
20 II.C.3, which requires the program be completed prior to  
21 full power operation.

22           (Slide.)

23           The objectives of the program were to establish  
24 confidence that, when subjected to seismic events up to and  
25 including the 7.5 magnitude Hosgri event, structures,



1 systems and components important to safety will not be  
2 prevented from performing their intended safety functions as  
3 a result of physical interactions caused by seismically  
4 induced failures of non-safety related systems, components  
5 and structures.

6 In addition, the way the program was carried out,  
7 the ability of the safety-related structures, systems and  
8 components to accommodate single failures was retained.

9 (Slide.)

10 The approach used by PG&E in the conduct of the  
11 program was to use the walkdown method for postulating  
12 systems interactions. In this method, safety-related  
13 structures, systems and components were designated as  
14 targets. All other -- in other words, the  
15 non-safety-related structures, systems and components were  
16 defined as sources. Interactions between the sources and  
17 targets were postulated by an interdisciplinary team of  
18 experienced engineers, which PG&E refers to as an  
19 interaction team, during systematic in-plant walkdowns of  
20 target equipment.

21 That is basically what I wanted to say by way of  
22 introduction. I thought it was important to establish the  
23 scope of the program and to let you know how the program was  
24 carried out. I think it will put PG&E's description of their  
25 program and the results they have obtained in a little

1 better perspective.

2           So unless there are any preliminary questions, I  
3 would like to turn the program over to PG&E, and we will  
4 follow with a description of our review.

5           MR. MARK: Very good. Are there any questions?

6           (No response.)

7           MR. MARK: Will PG&E proceed, then.

8           MR. HOCH: I am John Hoch, Manager of Nuclear  
9 Projects for Pacific Gas & Electric Company.

10           We would like to repeat, I hope more concisely  
11 than last time, the presentation we made to the Subcommittee  
12 on safety philosophy and technology -- I hope I have that  
13 right -- last month concerning the system interaction  
14 program at Diablo Canyon; I guess, more precisely, the  
15 seismically-induced system interaction program.

16           Our presentation is quite brief. I would like to  
17 mention, we once again brought with us a number of people  
18 that we hope are able to respond to any questions the  
19 Committee may have concerning the program. We hope that the  
20 program and its completion resolves any residual concerns  
21 that the Committee might have concerning the readiness of  
22 Diablo Canyon to receive an operating license.

23           Before we begin, let me mention a couple of I  
24 think unique things about the program. As Dr. Thomas  
25 mentioned and I guess as Dr. Okrent mentioned in his summary

1 to the Committee, the program was undertaken at a time when  
2 the NRC staff was -- I guess I will say -- somewhat  
3 preoccupied with the immediate concerns related to TMI -- to  
4 Three Mile Island.

5           As a result of that, the first portion of the  
6 program was really undertaken by PG&E without direct  
7 involvement from the staff. That involvement later became  
8 much more comprehensive, and during the past eight or nine  
9 months we have been working very closely with the staff,  
10 modifying our program to accommodate their suggestions and  
11 requirements.

12           However, because of the lack of involvement, let's  
13 say, in the early days of the program, we felt it necessary  
14 and important to bring another element into the program, and  
15 that is to obtain an independent -- a body of advice and  
16 guidance as independent as possible outside the company and  
17 outside the regulatory staff, separate from our usual  
18 consultants and company personnel.

19           Consequently, we proceeded to implement something  
20 we called an independent review program, employing an  
21 independent review board in an effort to make this board and  
22 its advice as independent and free from interference by PG&E  
23 as possible. We asked the firm of Keith-Fibush and  
24 Associates in San Francisco if they would manage such a  
25 review effort, that is, obtain people to serve on this board

1 who are uniquely qualified and brought with them a breadth  
2 of experience and background that would provide guidance to  
3 us on how to go forward with the program.

4           Kei<sup>co</sup>-Fibush did accomplish this. The firm  
5 provided Dr. Richard Stewart to be a member of that  
6 independent board and manage the board. Other members of  
7 the board have been Edward Keith, who is president of Keih  
8 Fibush Associates, Dr. Spencer Bush, Battelle Northwest  
9 Laboratories, Mr. Weingarten from the Department of Civil  
10 Engineering at USC, and Dr. Robert Nichell, who is an  
11 independent consultant.

12           This board has met a number of times, has  
13 participated, reviewed our interaction work, both in the  
14 office and in the field, has provided a number of  
15 suggestions for improvements to the program, things they  
16 felt were necessary, which we have made every effort to  
17 follow.

18           I want to mention this particularly because the  
19 board is represented here today. I believe all but one of  
20 its members are present. And I believe these people are, in  
21 addition to PG&E people and our consultants, are available  
22 to respond to questions from the board.

23           MR. MARK: Thank you, Mr. Hoch.

24           MR. HOCH: Let me introduce the gentleman who is  
25 going to do this -- the majority of the work here. Our

1 presentation will be given to you by Lew Killpack, who has  
2 been the project engineer for PG&E on this particular  
3 project on the systems interaction program. He was chosen  
4 because of a rather unique mix of talents, character  
5 strengths, and maybe even weaknesses.

6 Lew's background: He comes to us from -- he has  
7 had experience in PG&E's quality assurance department. He  
8 has had plant operating experience. Most recently, he spent  
9 a little over a year as head mechanical resident in our  
10 general construction department at the site, responsible for  
11 mechanical construction work.

12 Because of this kind of mix of experience and  
13 because of, I guess, the character weakness we'll refer to  
14 as an ability to pay attention to detail -- and that is  
15 primarily the reason he was chosen to head this project.  
16 Lew?

17 MR. KILLPACK: My name is Lew Killpack, and I am  
18 going to talk briefly about the scope, background,  
19 organization, methodology, criteria and results of Diablo  
20 Canyon's physically induced interaction program. The  
21 program was limited to seismically induced physical  
22 interactions between targets and sources, and we define  
23 "targets" as a system, structure or component important to  
24 safety, and a "source" as any other system, structure or  
25 component which does not fall in this category. And we

1 consider seismic events up to and including the postulated  
2 7.5 magnitude Hosgri event.

3           The purpose of the program was to further  
4 eliminate potentially detrimental physical interactions  
5 between targets and sources, so that components important to  
6 safety would not be prevented from carrying out their  
7 required safety function during and after a seismic event.

8           The program was intended to be centered around  
9 on-site evaluation by an interdisciplinary team of our most  
10 experienced engineers. It was a hands-on program  
11 concentrating on analysis, inspection and walkdowns. The  
12 program is an ongoing program in the sense that the lessons  
13 learned by PG&E from a systems interaction program will be  
14 factored into our standard design and construction  
15 procedures, and in addition all future work will be subject  
16 to the same on-site evaluation process employed for this  
17 program.

18           Now, the background -- the background specifics of  
19 this program are covered in detail in PG&E's submittal and  
20 also in the staff's safety evaluation report. So I will not  
21 go over all of that.

22           The organization -- the program was managed by  
23 PG&E's Nuclear Projects Department. You can see on this  
24 chart.

25           (slide.)

1           The engineers and analysts were assigned to the  
2 project from our engineering, construction, operations, and  
3 quality assurance departments. Because at PG&E we are our  
4 own architect-engineer and constructor, we had a  
5 considerable depth of experience and talent to draw from for  
6 this program.

7           We also used several consultants to supplement the  
8 program. Robert L. Cloud and Associates were used for  
9 overall technical direction; the NSSS vendor, Westinghouse,  
10 for systems analysis and NSSS assistance; EDS Nuclear for  
11 analysis of the heating, ventilating and air conditioning  
12 systems; and also Kaiser Engineers for assistance on piping  
13 systems analysis.

14           Our supervisor of program development was assigned  
15 from the quality assurance department. We were desirous of  
16 having quality control built into our program procedures and  
17 having our program in complete conformance with PG&E's  
18 quality assurance program.

19           Our computerized data base and records retrieval  
20 system was managed by an analyst from the records management  
21 system. Our systems engineer was a senior Diablo Canyon  
22 startup engineer. The site evaluations were performed by a  
23 team made up of the technical consultants, the system  
24 engineer, the program supervisor, a design engineer from  
25 each discipline, a field engineer from each discipline, and

1 other specialists as needed.

2           The team was large, typically 10 to 13 people,  
3 since we were desirous of maintaining an interdisciplinary  
4 review as much as possible.

5           (Slide.)

6           This is a shot here of part of the team done in  
7 the field, to give you an idea of what it was like. There  
8 were too many people to get them all in one picture.

9           Analyses referred by the site team to the general  
10 office were performed by PG&E's engineering department and  
11 consultants in some cases. All analyses were reviewed by  
12 the technical consultant, R. L. Cloud and Associates.

13           Approximately 50 professional-level personnel were  
14 required in the program, and we have present at the meeting  
15 today representatives of these different groups -- the  
16 independent review board, NSSS vendor, Cloud Associates, our  
17 engineering department, and PG&E management -- to answer any  
18 questions which you might have.

19           I would like to talk a little bit about the  
20 evaluation criteria now. The evaluation of seismically  
21 induced systems interactions and their effect on plant  
22 safety rests heavily on experienced engineering judgment.

23           (Slide.)

24           The criteria supplement and provide guidelines to  
25 make the evaluations as consistent as possible, and also to



1 make these so that they were repeatable and retrievable.  
2 The criteria specify minimum requirements for failure modes  
3 and effects which must be considered for targets and sources  
4 during the evaluation.

5           The purpose of the site evaluation and the  
6 criteria we developed was to identify doubtful cases for  
7 further evaluation and to resolve the obvious cases. These  
8 criteria were used by engineers with extensive experience,  
9 and we insisted on an interdisciplinary evaluation.

10           The evaluation criteria fell into several general  
11 categories.

12           (Slide.)

13           The first is source and target contact. This  
14 involves impact from falling or vibrating objects, pipe  
15 whip, overturning, lateral or vertical movement, missiles,  
16 and relative motion between sources and targets.

17           The second is fluid leakage. This involves  
18 hostile gases, jet impingement, flooding, unwanted  
19 pressurization, loss of pressure or loss of control, as we  
20 think of it, and loss of lubrication.

21           The third is electrical anomaly, and this includes  
22 unwanted open circuit or loss of power, unwanted closed  
23 circuit, and unwanted energization.

24           The fourth category is environmental effects.  
25 This includes elevation, temperatures, steam and radiation,

1 et cetera.

2           The fifth category is secondary or chain  
3 reactions, and these may involve any of the previously  
4 mentioned criteria where one sources might affect one or  
5 more sources, which in turn reacts with a target.

6           Methodology. Our methodology is discussed in  
7 detail in the PG&E submittal and in the staff safety  
8 evaluation report. I will not repeat all that. However, I  
9 do have a few slides which summarize some of our processes.

10           An early step of the program was the  
11 identification of targets.

12           . (Slide.)

13           This slide shows the matrix, which is this  
14 document right here, and the drawings which we used to  
15 identify the targets. The matrix is a checklist for each  
16 target item, and it shows information like its  
17 identification, location, quality classification, required  
18 failure modes with and without power, seismic category,  
19 system, subsystem, and such information as that.

20           The matrix is over 2,000 pages and required about  
21 6,000 man-hours to complete. We already had similar type  
22 lists developed for the programs like the Hosgri, but in  
23 this particular program it required considerable detail  
24 which was not in our other lists. For example, like vent  
25 lines from an air-operated valve would have to be on this

1 particular matrix.

2           Also, we used the drawings in parallel with this  
3 and we color-coded all of the target systems on our  
4 schematic drawings.

5           (Slide.)

6           This slide shows -- illustrates how the drawings  
7 and matrix was used in the field. Typically, our systems  
8 engineer followed along on the schematic drawings, and we  
9 color-coded over the systems as we completed the walkdown or  
10 the evaluation, and we used the matrix list as a checklist  
11 also, so that we could balance one against the other so we  
12 could check to make sure that we had everything that we were  
13 interested in.

14           The evaluations on side generally fell into four  
15 main categories. The first is a discrimination of whether  
16 or not an interaction could occur or a determination that an  
17 interaction could occur but that no safety function is  
18 impaired. An example of this might be, say, a piece of  
19 half-inch tubing falling on a 16-inch pipe. We determined  
20 that the interaction would occur, but that it was of no  
21 particular consequence because of the relative masses  
22 involved; third, a specific modification is requested; and,  
23 fourth, we recommend further analyses.

24           The analyses conducted at the general office were  
25 done by the engineering department and consultants as

1 required. All analyses, field and general office, were  
2 reviewed by the technical consultant.

3           A computerized information management and  
4 recording system was used to maintain a traceable system and  
5 documentation for our program, postulated interactions,  
6 field reviews, analyses, calculations and results are all  
7 maintained in an auditable and retrievable form. All  
8 documents are microfilmed, and in addition we used this  
9 system for such things as sorting the electrical targets and  
10 determining conduit and cable tray routings, this type of  
11 thing.

12           This type of system was one which was suggested by  
13 the independent review board early in the program and we  
14 adopted it. And this is one example of the value of the  
15 independent review board. They made many suggestions to us  
16 which we incorporated into the program.

17           Independent audit. Our corporate quality  
18 assurance department conducted an audit of the program. It  
19 was a technical audit and their auditing included engineers  
20 from each of the engineering disciplines, who were engineers  
21 who were knowledgeable of the Diablo Canyon plant, but that  
22 were not involved in the systems interaction program.

23           This team of engineers did a number of things.

24           (Slide.)

25           They performed a sampling walkdown to gather data,

1 and they performed an audit of walkdowns by the systems  
2 interaction team. They performed on a sampling basis  
3 separate analyses to verify that previous analyses conducted  
4 by the team were correct. They reviewed program documents  
5 and they reviewed completed modifications.

6 In summary, for Unit 1 it appears that  
7 approximately 1400 potential interactions were documented.  
8 Most of these were not significant in terms of safety. I do  
9 have a few examples of some of the ones that had some  
10 significance. I can show you some pictures of some of these.

11 (Slide.)

12 On this one, the target is this condensing pot  
13 right here on the steam generator. It is used for steam  
14 generator water level. And the source would be a  
15 substructure platform like this. This substructure was  
16 seismically qualified by analysis. It also was modified to  
17 accommodate lateral and vertical movement which might  
18 occur.

19 There is a little bit of a depth perception  
20 problem on this slide, because this condensing pot is  
21 actually located about a foot above this beam here. And the  
22 initial design had considered relative movement between the  
23 two items.

24 But under our program we have increased margins of  
25 safety as much as we could, and this is an example of the

1 types of things we did to make sure there would be no  
2 interaction in the event of a seismic event.

3 (Slide.)

4 On this one, the target is this route valve right  
5 here, a nitrogen connection to a main steam loop; and the  
6 source is the railing. This is before the fix. We fixed  
7 this by just cutting out a piece of the railing there.

8 (Slide.)

9 On this one the target is this motor-operated  
10 valve, power and control cable that you see here in this  
11 flexible conduit; and the source was this trapeze hanger  
12 assembly. You see the rods going up here. They went way  
13 up. And we postulated lateral movement where this or the  
14 pipelines could contact this conduit. So the fix in a case  
15 like this was to redesign the support.

16 Here the target is the steam connection right  
17 here.

18 (Slide.)

19 It is on the steam supply to the auxiliary feed  
20 pump. This is a drain cap which has been capped off here  
21 and here, since it is an abandoned test connection of some  
22 sort. And we postulate this line here, if unrestrained,  
23 could move vertically upward and impact this line. So a fix  
24 in a case like this is usually by restraining the source.

25 (Slide.)

1           Here the target is the charging pump suction line  
2 right here; and the source is this monorail system here for  
3 a small crane which is used to service equipment like the  
4 pump and motor. This monorail is located only a few inches  
5 from the suction line, and you notice it is hung by rods.  
6 So it is possible to move in a lateral direction.

7           We found a number of things like this that were  
8 seismically qualified in terms of vertical loading and in  
9 terms of it not falling, but having excessive lateral  
10 movement. And these monorails are a good example of a  
11 number of interactions where they have a possibility of  
12 interacting different pipelines or components. The fix on  
13 it is to restrain the monorail so it does not have excessive  
14 lateral movement.

15           (Slide.)

16           On this one, the target is a restrained line on  
17 the safety injection system. It is an accumulator test line  
18 right here, this small line. And the source is this large  
19 line. You can see this clevis, and here, as it was welded  
20 onto the line here, it was in very close proximity to this  
21 target line here, the lugs and clevis. The resolution  
22 involved moving this left-hand line support down several  
23 inches.

24           (Slide.)

25           On this one the targets are these control panels;

1 and the source is this battery-operated beam light, which  
2 was not on seismic mountings. In general, all of these  
3 lightse are mounted seismically. This was an extra one of  
4 some sort that was not seismically mounted. So the fix on  
5 that was to upgrade the mount to a seismically approved  
6 mount.

7 (Slide.)

8 Here the target is this tank right here. This is  
9 a component cooling water surge tank. The source is this  
10 large antenna up here. We postulated this falling onto the  
11 tank because the mounts here were not seismically qualified  
12 -- not seismically qualified mounts.

13 (Slide.)

14 Here are some conduits and cable trays.  
15 Incidentally, the colorgrams here and the colors denote the  
16 safety-grade conduits and cable trays. I showed this  
17 because the cable trays were very significant to us because  
18 they required so much analysis. That is, the  
19 non-safety-grade cable trays. And we were not able to  
20 qualify these on a generic basis, as we had hoped  
21 originally, because we found that the details varied  
22 throughout the plant somewhat.

23 So we presently have a testing program underway  
24 where we are individually analysing various types of cable  
25 trays throughout the plant, and we are finding generally



1 that they are qualified. But there are some number of  
2 modifications that are necessary, particularly the  
3 longitudinal seismic braces having spacing wider than they  
4 should.

5 (Slide.)

6 Here the source is the primary water storage tank,  
7 the little tank on the end here. All of the other tanks  
8 were formally seismically qualified during the Hosgri  
9 program. This tank was not. There would be a number of  
10 different targets. It could be one of the other tanks or  
11 systems inside of the building here.

12 We are currently analysing this tank now, and we  
13 think that it probably will qualify. If not, then there  
14 will have to be some sort of a modification.

15 MR. BENDER: Did you look at the level indication  
16 for that tank?

17 MR. KILLPACK: Yes, we did.

18 MR. BENDER: What sort of approach did you use in  
19 determining that it was seismically qualified?

20 MR. HOCH: The tank in question is not a category  
21 one tank, so the question of its level is immaterial.  
22 However, level for the other tanks, the safety-related  
23 tanks, was examined from the standpoint of level indications  
24 and are seismically qualified.

25 I guess I am not --

1           MR. BENDER: That is all right. You presumed that  
2 if the level indicator was seismically qualified, including  
3 its connecting lines --

4           MR. HOCH: That is right. We did not look at it  
5 any further.

6           MR. BENDER: -- that that was good enough?

7           MR. HOCH: Yes.

8           MR. BENDER: Did you look to see whether there was  
9 any redundancy in the system? Is one level indicator  
10 seismically resistant or seismically qualified?

11           MR. HOCH: Let me clear that up, I think, by  
12 seeing that in this particular program, once we determined  
13 that something was indeed category one seismically  
14 qualified, this program had really nothing else to do with  
15 it other than to consider it as a potential target. We were  
16 only looking at things which were not --

17           MR. KILLPACK: We were looking for the non-safety  
18 category. For example, this tank is the only tank in the  
19 non-safety category --

20           MR. BENDER: That is all right. It was more a  
21 matter of curiosity. Thank you.

22           MR. KILLPACK: I have a number of other slides.  
23 But maybe for the sake of time I will not go through all of  
24 them. I think this will give you an idea of the type of  
25 things that we were finding that were significant.

1           Of the 1400 which we documented, I would say less  
2 than a third of these required some sort of modification.  
3 And out of those where we did make modifications, in many  
4 cases we made the modifications simply because that was  
5 easier to do than the analysis to determine whether or not  
6 there would be interaction. It is much easier to put a  
7 seismic brace on something than to go through all of the  
8 analysis.

9           Most of the modifications were minor,  
10 strengthening type things, particularly with the  
11 substructures. At Diablo Canyon all of the main buildings  
12 are already seismically qualified. But with some things  
13 like stairwells and platforms that were not specifically  
14 qualified, we just went in and upgraded that, rather than do  
15 a lot of analysis and "what-iffing."

16           That basically summarizes our program. Are there  
17 any questions?

18           MR. PLESSET: Any questions? Yes, Mr. Ward?

19           MR. WARD: The cost of the fixes as opposed to the  
20 cost of the analysis -- did the analysis cost you more than  
21 the actual physical fixes?

22           MR. KILLPACK: The physical fixes are much  
23 cheaper, I think, because of the time involved. The  
24 analysis might take two weeks and the fix might take one  
25 day. The cost of the materials involved is minimal. it is

1 mainly labor you are talking about, time.

2 MR. HOCH: That is a generality, I think, Mr. Ward.

3 MR. KILLPACK: The construction department may  
4 disagree.

5 MR. BENDER: I believe you said you expended 6,000  
6 man-hours on this effort.

7 MR. KILLPACK: That was only for that list, the  
8 matrix. We expended something like 50 man-years for the  
9 engineering effort, the analysis and the walkdown. And that  
10 does not include the construction department's efforts.

11 MR. SHEWMON: Would you convert those to the same  
12 units? If you're going to use man-hours in one --

13 MR. BENDER: I don't mind.

14 MR. SHEWMON: I do.

15 MR. PLESSET: That is a good point.

16 Jerry?

17 MR. RAY: Do I understand correctly that where you  
18 made modifications you then had walkdowns of those  
19 modifications to make sure that in modifying you did not  
20 introduce new hazards?

21 MR. KILLPACK: That is correct. Our procedure  
22 requires us to go back and walk down the fix, just as we  
23 would any other modifications, to make sure we did not  
24 introduce further interactions. And in addition,  
25 modifications in the future will be addressed. For

1 instance, as we perform some of these last few TMI fixes, we  
2 go in and look at them according to this criteria. It will  
3 be a continuing program.

4 MR. PLESSET: Mr. Ward?

5 MR. WARD: Are you going to be able to have any  
6 feedback to your design standards for this sort of thing?

7 MR. KILLPACK: We think so. The lessons learned  
8 from this program we will just have to write into our  
9 standards, so that not all of these things can really be  
10 addressed when you are making a drawing, but some of them  
11 can. And as a matter of fact, already the engineers are  
12 looking at these criteria and trying to address that.

13 But it appears like a walkdown is probably  
14 necessary when you check some types of things that you just  
15 cannot do up in the office.

16 MR. BENDER: You are suggesting this has to be  
17 done after the plant has been constructed, generally?

18 MR. KILLPACK: That was our feeling. From sitting  
19 up in the office and looking at the drawings, you just don't  
20 see these things. You really have to get down in the  
21 field.

22 For example, what we find in one reactor coolant  
23 pump we did not find on the other, and we are expecting Unit  
24 2 to be different from Unit 1, although they are basically  
25 identical plants. A lot of these are things that are a

1 function of the construction and exactly how things are  
2 placed.

3 MR. BENDER: I hesitate to ask you to speculate on  
4 this, but this was a narrowly constrained kind of survey,  
5 and it would seem to be very effective.

6 MR. PLESSET: What do you mean, "narrowly  
7 constrained," Mike?

8 MR. BENDER: It was intended to look at  
9 interactions that might arise from seismic events largely,  
10 and it included fluid reactions and things of that sort.  
11 But I would have to ask myself, what kind of walkdown would  
12 you need to look at other kinds of interactions that might  
13 have to be addressed, like steam releases and things of that  
14 sort. Could you do it the same way?

15 MR. HOCH: Well, let me point out, we already did  
16 as part of an earlier program for pipe break outside  
17 containment, we already did go through this walkdown  
18 procedure with breaks postulated at locations as required by  
19 the staff's criteria. Even though the program -- you are  
20 correct in it being narrowly constrained. We did not  
21 overlook anything we found during the course of the program,  
22 whether or not it was related to the program.

23 And there were a number of instances where things  
24 were discovered, such as a missing bolt, that might well  
25 have been found during a subsequent walkdown or

1 preoperational inspection, but were documented and taken  
2 care of as part of this program.

3 MR. BENDER: Well, I am probing and I admit to  
4 probing, but --

5 MR. HOCH: Let me make a couple of general  
6 comments in this area, if I can. I think it follows what  
7 Lew said. I think if I had to characterize the difficulty  
8 or problem that is most apparent, that probably resulted in  
9 a majority of the potential interactions, it would be really  
10 the interdisciplinary coordination problem. And that is  
11 really difficult to factor back into your design process,  
12 but it is something we are trying to do.

13 The kinds of things we have seen, the architect's  
14 design of a platform -- you saw an example of this -- the  
15 mechanical engineers and instrumentation control people have  
16 put a level instrument on the side of the steam generator.  
17 The two groups do different things, and that  
18 interdisciplinary thing does not always come together, so  
19 that Group A sees what Group B is doing and evaluates what  
20 that might do to their design.

21 That is probably the biggest area, I guess the  
22 most common area, of generating these kinds of things.

23 MR. BENDER: Well, I think you are hitting at the  
24 principle I was trying to at least explore. I could  
25 envision doing this kind of thing to deal with the sprinkler

1 system, to deal with pipe breaks as you have done, to deal  
2 with lube oil releases, to deal with things that might  
3 happen during maintenance operations, where you have to  
4 bring in special equipment from the outside, just to speak  
5 to what the potential hazards were.

6           And I am not -- don't misunderstand me. I am not  
7 proposing that you do these things at this stage of the  
8 game. I am trying to find out whether some kind of  
9 procedure that dealt with things on a broader basis could be  
10 done at the same time you are doing this. I guess the  
11 answer is yes.

12           MR. HOCH: The answer is definitely yes. And  
13 certainly, after essentially completing this program, I  
14 think it is our feeling that probably the most useful and  
15 most cost effective way of accomplishing this is with a  
16 program that includes a field evaluation and field  
17 inspection program as part of it, rather than sitting in the  
18 office and attempting to look at drawings and brainstorming  
19 what possibilities exist.

20           The finished plant is certainly a far better  
21 depiction of what the finished plant looks like than a set  
22 of drawings.

23           MR. BENDER: Thank you.

24           MR. MARK: The word "walkdown" has been used  
25 frequently. I have a vague picture of it. A half a dozen



1 people go into something like the deisel generator room.  
2 How long does it take? How long do they spend?

3 MR. KILLPACK: It varied depending on how many  
4 targets. But in general, it was very, very slow and  
5 tedious, and it would be more like 10 or 12 people. By the  
6 time we got through general office, engineering types, steel  
7 engineers, consultants, you would have a large group. And  
8 it was very tedious and slow, because there are so many  
9 things to consider.

10 And I think if we had been doing a very broad kind  
11 of a program, we could not have done it. It was almost too  
12 much as it was, as narrow as we had this. And if we had not  
13 been able to narrow this program down as a result of many  
14 previous programs, I think it would have been very, very  
15 difficult. It took us almost a year to get through this.

16 MR KERR: Was this the first time some of these  
17 people had ever seen a reactor?

18 MR. KILLPACK: No, we had nobody there unless they  
19 had been the ones who had designed the reactor. These were  
20 our very senior, experienced people.

21 MR KERR: I did not mean the drawings for one.  
22 Was it the first time they had actually seen a reactor, some  
23 of them?

24 MR. KILLPACK: No, absolutely not.

25 MR. HOCH: Let me point out something I think we

1 mentioned. I think the person you saw with the thick  
2 glasses in some of the slides he showed has been at Diablo  
3 Canyon on startup for what, six or seven years.

4 MR. KILLPACK: We had nobody --

5 (Laughter.)

6 MR. HOCH: Our startup group at Diablo Canyon has  
7 been active, trained, and involved in startup operations for  
8 about seven years.

9 MR. KILLPACK: We picked the engineers who  
10 basically had done the design and were familiar with the  
11 systems in the plant, so we could point to a line and say,  
12 what is that and where does it go and what is in it; is it  
13 safety-related, is it seismically qualified, what is the  
14 safety code.

15 These people had all of the answers, and those are  
16 the people we used. Like our instrumentation engineer, who  
17 has been on the project since the beginning, is sitting  
18 right behind you. He was there or one of his staff was  
19 there. If we saw an instrumentation line, we expected him  
20 to know everything about it.

21 And the same thing, we had an electrical engineer,  
22 in addition the engineer who installed it, who built it.  
23 How was this built, what kind of anchors. And it would have  
24 been very difficult without this kind of information if we  
25 had to go and look it all up. Even having these experienced

1 people, very tedious, very time-consuming.

2 MR. HOCH: Let me point out a potential difficulty  
3 that relates to the long startup period, and that is, the  
4 farther down the road we go, the more we are asked to be  
5 dealing with people that have not had the background, have  
6 not had the experience. We are beginning to start to see a  
7 thinness in our engineering ranks of people who actually  
8 participated in the design.

9 In a few more years, I would expect most of those  
10 people will be gone. It really makes sense to get this  
11 procedure over, I think, while the people with the  
12 experience, with the knowledge, are still alive.

13 (Laughter.)

14 MR. PLESSET: Mr. Ward?

15 MR. WARD: One other question. You said the cable  
16 trays were a particular problem, and I think you said you  
17 assessed those by a testing program rather than analysis.  
18 Could you say just a little bit about that?

19 MR. KILLPACK: On the class one cable trays, which  
20 are already seismically upgraded, they were all very much  
21 the same, and we could analyze a prototype or test a  
22 prototype.

23 And on the class two, the details -- although they  
24 were built essentially the same, they had not gone through  
25 these normal programs. And what we found was that the

1 details varied from area to area. You know, they looked  
2 generally the same, but the joints might be different, there  
3 might be different spacing between the seismic supports.

4           So what we have had to do is go down with our  
5 department of engineering research and vibrate these and  
6 determine what their damping and their resonant frequency  
7 and their rigidity and these types of things are, because it  
8 seems to vary throughout the plant. And we cannot do it on  
9 a generic basis.

10           And we are finding that they are generally  
11 qualified, but we cannot prove it because they are all  
12 different. So it takes a testing program to do this. And  
13 this type of testing is very time-consuming. They sometimes  
14 will spend several days on one cable tray with their  
15 vibrating before they really have good data and we know  
16 exactly what we have with that cable tray.

17           Of course, we have some minor modifications as we  
18 go along. This testing program is under way right now, so I  
19 don't really have a feel for how much modification we are  
20 going to run into. We basically are going to upgrade the  
21 cable trays.

22           Here again, the analysis of what happens when you  
23 break these cables, even though they are non-safety, is very  
24 difficult. Basically, our philosophy throughout, most of  
25 the plant is seismically qualified; we are just doing the

1 rest.

2 MR. PLESSET: Dave, do you have a question?

3 MR. OKRENT: A comment and maybe a question. The  
4 broader question of systems interaction, not necessarily  
5 seismically induced, is something the staff is developing an  
6 approach on. I think it is in the Action Plan. And in that  
7 regard, I would say Diablo Canyon is not unique.

8 We had a little bit of discussion at the  
9 Subcommittee meeting about how they looked at possible  
10 electrical effects. I wonder if you could make any comment  
11 in that regard? What we heard here are physical. I mean, I  
12 think you have, if I recall correctly, a basis for thinking  
13 that electrical effects were handled.

14 MR. HOCH: Why don't you begin and we will kind of  
15 fill in behind you, Lew.

16 MR. KILLPACK: The electrical effects is a sticky  
17 problem, and I think I just sort of stated what our  
18 philosophy was: If we can upgrade all of the cable trays  
19 and conduits in the plant, we did not have to worry about  
20 it. And that was basically our approach.

21 We of course looked, as we were doing the  
22 walkdowns, we looked -- we had many targets that were cable  
23 trays and conduits, and we were looking for things like, can  
24 this -- can we get an open circuit or can something affect  
25 the power to that valve, and that sort of thing. But in

1 general our approach was, I think, to eliminate the  
2 possibility of there being an interaction with any of our  
3 electrical --

4 MR. HOCH: Let me see if I can reword that. At an  
5 earlier meeting, I believe a year or so ago, when you posed  
6 a series of 13 questions and we came in and did a not too  
7 adequate job, I think, of answering those questions, because  
8 they were really representative of maybe a broader series of  
9 questions you had, one of the kinds of questions you were  
10 asking was, have we looked at non-qualified electrical  
11 conduits and postulated the conduits would break and perhaps  
12 be inadvertently reconnected in combinations that might  
13 create some problem for us.

14 And I think what Lew has just said, if I can  
15 rephrase it a little bit, is if we can show that, insofar as  
16 non-qualified, non-category one, if you will, trays,  
17 conduits, and cables, if we can show that they do not fail,  
18 even though not constructed to the same rigorous standards  
19 as safety-related cables and conduits, if we can show that  
20 they do not fail, that they are not reasonably expected to  
21 fail, I think -- I believe we have answered that question.

22 I think the other part of the answer, the answer  
23 to your question, the presumption of failure, does indeed  
24 become very difficult. It becomes a problem of analyzing  
25 countless combinations of events.

1           MR. RAY: As I recall it, though, at the  
2 Subcommittee meeting I think there was some discussion of  
3 the mechanical stability of the switch gear mounting and  
4 that sort of thing.

5           MR. HOCH: I don't remember talking about that,  
6 but we certainly can.

7           MR. RAY: I think that might be significant,  
8 because you could move the switch gear.

9           MR. HOCH: Everything, of course, safety-related  
10 has been rather carefully qualified as far as the Hosgri  
11 analysis and qualification program, the combination of  
12 analysis and a lot of testing of all safety-related  
13 electrical equipment at Diablo.

14           This is Tom Crawford. He may recall what you are  
15 referring to in the Subcommittee meeting.

16           MR. CRAWFORD: What we did to -- I guess the thing  
17 you are really referring to is the problem of, how do you  
18 really know what happens if a relay chatter switch causes a  
19 valve to go closed which is really supposed to be open or  
20 something like that. And what we did is, we went through  
21 and, in doing our original analysis, we determined which  
22 systems had to be functional regardless.

23           If we could get a certain number of systems, a  
24 certain pressure boundary intact and operable with no  
25 failures, then we could guarantee that, regardless of what

1 happened to anything else, we had no problems. But we had  
2 to ensure integrity of the systems and operability of those  
3 systems, so that, like for example, if you had a safety  
4 injection test line, the test line itself has no safety  
5 function and it has an air-operated valve that isolates it  
6 out, you have to ensure that that air-operated valve does  
7 indeed close and no, relay chattering in the control room  
8 does not operate that air-operated valve.

9           Once you establish that air-operated valve is  
10 closed, then you don't worry about air-operated valves  
11 downstream of that.

12           So what we did is, we very carefully went through  
13 our entire system and went on a single-failure criteria  
14 basis and made sure that we had isolated all the required  
15 systems and everything required to make that occur is  
16 seismically qualified.

17           Okay, both from a physical point of view and also  
18 -- from a physical point of view, you know, each device  
19 itself is qualified and there would be no interactions with  
20 it. Now, the one thing -- the only place where we had  
21 something where we did not outright qualify the device is if  
22 the control room gear -- we did that test by similarity. In  
23 other words, the relay looks the same. If it was Class 1 or  
24 non-Class 1, we don't use two different flavors.

25           So that is exactly how we dealt with the issue,



1 and then we just did not worry about control systems  
2 interactions beyond those boundaries.

3 MR. BENDER: I guess I am sort of inclined to  
4 comment again about the point raised earlier about looking  
5 at other things. In view of the fact that the regulatory  
6 staff is looking down the road to other interactions, and in  
7 view of the fact that seven years have gone by and most of  
8 us which that we would stop here, it just seems to me that  
9 it would be prudent to do a little looking ahead yourselves  
10 and be sure that, in the process of doing this, you have  
11 dealt with all the things that are likely to come down the  
12 road, so that there is a fairly good chance that we can draw  
13 the line somewhere, because God knows we've spent enough  
14 time on it.

15 MR. PLESSET: Yes, Steve?

16 MR. OKRENT: Mr. Chairman, one of the reasons why  
17 I raised the electrical problem, I think at Diablo Canyon  
18 they found it necessary to qualify certain things to seismic  
19 Class 1 that would not ordinarily have been so qualified, in  
20 order to accomplish what we just heard. And I raise this  
21 not so much as a point for Diablo Canyon, but as one that  
22 needs, let's say, thought: What is the situation? What if  
23 anything needs to be looked at for other plants?

24 At Diablo Canyon they started to look at it and,  
25 so far as I can tell based on hearing, that they have in

1 fact tried to deal with the matter. But it is less clear  
2 where plants in less seismic an area stand in this regard,  
3 and my inclination is to agree with what we heard; to try to  
4 analyze it wire by wire is not easy.

5           So at some future time, not for Diablo Canyon, I  
6 think we will probably want to hear what the staff thinks  
7 about this. And I don't know, maybe the Electrical  
8 Subcommittee ought to put this on their list as something to  
9 follow, or the seismic group can handle it, one way or the  
10 other.

11           MR. PLESSET: In any case, I think it is not  
12 unreasonable to make a positive, even complimentary, remark  
13 to the Applicant.

14           MR. OKRENT: I did at the Subcommittee meeting.

15           MR. PLESSET: Oh, okay. We can do it on behalf of  
16 the full Committee.

17           MR. OKRENT: I thought in fact I said here I  
18 thought they had done a workmanlike job.

19           MR. PLESSET: Yes.

20           I think maybe we can move to the staff.

21           MR. THOMAS: Mr. Chairman, I would like to make an  
22 additional remark in support of the Applicant. One thing  
23 that has not been brought up this morning that the Committee  
24 may find of interest is, equipment such as valves with  
25 required or assumed failure modes, powered by air or

1 non-vital power, were looked at very carefully by the  
2 Applicant in this program.

3           If a valve had a required or assumed failure mode,  
4 the Applicant looked at that valve and looked at the power  
5 to it, whether it be air or electrical power, and did in  
6 effect a mini-failure modes and effects analysis to make  
7 sure there could be no seismically-induced physical failure  
8 to that power supply, whether it would be air or electrical  
9 power, that would prevent that valve from obtaining its  
10 required or assumed failure mode.

11           So in effect, with those valves the Applicant  
12 defined as targets those air lines or electrical power lines  
13 to the valves and included them in the list of targets, and  
14 assured that they could not be adversely interacted by  
15 failure of non-safety-grade equipment. So I had not heard  
16 this mentioned, but it was one step further that the  
17 Applicant took that I think is maybe a step in the direction  
18 that Dr. Okrent was taking. Certainly it does not go all  
19 the way, but it is, we think, a good first step.

20           MR. PLESSET: Thank you.

21           Yes, Paul?

22           MR. SHEWMON: I don't follow this very carefully,  
23 but could anybody -- would anybody care to speculate or tell  
24 me where Diablo's power is now?

25           MR. PLESSET: The plant itself?

1 MR. SHEWMON: They have been starting up for a few  
2 years here. Are they on line?

3 MR. PLESSET: No, no. The appeals panel -- let me  
4 see if I understand it. The appeals panel has not yet come  
5 back with their decision. Is that correct, Mr. Hoch?

6 MR. HOCH: Why don't I -- if you want a summary of  
7 that, why don't I ask Mr. Norton to give it for us.

8 MR. PLESSET: Let's make it brief. But fine, it  
9 has been brought up.

10 MR. HOCH: He, I am sure, could summarize much  
11 more readily than I the process of licensing. In summary,  
12 no, we don't have an operating license. We began -- after  
13 TMI we were either number one or two in line as a, quote,  
14 unquote, "near-term operating license." And now we are, I  
15 don't know, number five, I guess. It is something like  
16 that.

17 The plant and the process we have been talking  
18 about today, the interaction program, are essentially  
19 complete and can be made complete in a very, very quick  
20 fashion.

21 MR. NORTON: Dr. Shewmon, in answer to your  
22 question, we just finished seismic hearings again last week  
23 on Imperial Valley -- I guess it was two weeks ago, Imperial  
24 Valley '79 earthquake.

25 We are starting hearings on Monday on the security

1 plan. That is before the Appeal Board. We have motions to  
2 reopen on emergency response pending before the Licensing  
3 Board. There are motions to reopen pending on Class 9  
4 accidents before the Licensing Board.

5 There is the low power testing license. There are  
6 contentions to be filed by Governor Brown et al. on the low  
7 power testing license by December 3rd.

8 MR. SHEWMON: These are primarily contentions  
9 brought in by your friends in California, not your friends  
10 in Bethesda or wherever, is that right?

11 That is right.

12 MR. SHEWMON: Thank you.

13 MR. PLESSET: Thank you.

14 MR. BENDER: Mr. Chairman, I think it would help  
15 to clarify a bit more where we stand: Assuming that you get  
16 through all of these appeals which you may go through, what  
17 else would be left in your view to receive an operating  
18 license? What do you think is going to need to be done?

19 MR. NORTON: I think nothing. Once we get through  
20 the appeals, we should go. But when that is going to happen  
21 --

22 MR. BENDER: What does the regulatory staff think?

23 MR. BUCKLEY: There are a few items that need to  
24 be confirmed. For example, we plan on going out to PG&E  
25 December 2nd and confirming their management improvements

1 that have been made since about six months ago. They  
2 reorganized their organization. We plan a two or three-day  
3 trip out there.

4 MR. PLESSET: Has fuel been loaded?

5 MR. BUCKLEY: No, sir. It is at the site.

6 MR. PLESSET: At the site, okay.

7 MR. BUCKLEY: The fuel -- it has been there since  
8 1975.

9 MR. BENDER: Is there a written statement anywhere  
10 of what is needed to get to the operating license stage for  
11 this plant?

12 MR. BUCKLEY: No. The supplement number 9 wrote  
13 off on all non-TMI items for lower power. And supplement 10  
14 wrote off on the TMI items for low power.

15 There are several outstanding items that needed to  
16 be resolved, but they are of a managerial type.

17 MR. BENDER: Is it unreasonable to suggest that  
18 such a list would be appropriate?

19 MR. BUCKLEY: It is not unreasonable. I could  
20 prepare one.

21 MR. BENDER: I think it would be useful to the  
22 Committee to know.

23 MR. THOMAS: Isn't there a list in the SER  
24 somewhere?

25 MR. BUCKLEY: Yes.

1           MR. BENDER: I am not clear. Are you saying that  
2 supplements 9 and 10 contain all that is left to be done?

3           MR. BUCKLEY: Yes, sir, to the best of my  
4 knowledge. Essentially, all of them have been done. There  
5 were two items that needed to be confirmed, that is all.  
6 They are of a minor nature.

7           MR. BENDER: I think if you could provide it to us  
8 I would at least be enlightened. I don't know whether the  
9 rest of the Committee would be or not.

10          MR. BUCKLEY: I can get that for you.

11          MR. PLESSET: Let's get back to our agenda. I  
12 think the staff is going to give us some summary comments on  
13 this. Would you do that?

14                   (Slide.)

15          MR. THOMAS: Okay. I will briefly summarize the  
16 NRC staff review of PG&E's systems interaction program. To  
17 begin with, I would like to point out we used a team concept  
18 in reviewing the program. Our team was composed of five  
19 members, three members from the Systems Interaction Branch.  
20 I am one. The other two were Don Lasher and Leo Gregarian.  
21 We had a representative from the Mechanical Engineering  
22 Branch, Joel Page, and we had a representative of Lawrence  
23 Livermore Laboratory, our consultant for our review, and Mr.  
24 Wang is here from Lawrence today.

25                   Our review was essentially conducted in two

1 parts. First of all, we had an in-house review of PG&E's  
2 program as described in the documentation, and also results  
3 that were provided to us up until the 1st of August.

4           Secondly, we conducted an on-site audit of PG&E's  
5 program. We actually went to the plant and spent three days  
6 in June and did an audit. I will describe that in a little  
7 bit more detail in a minute.

8           (Slide.)

9           Our in-house review. This slide summarizes the  
10 major elements that we looked at. Primarily we looked at  
11 the scope of the program, we looked at the scope of the  
12 equipment to be considered as targets, and the scope of the  
13 interactions that were considered in the program. We looked  
14 at the organization established to implement the program,  
15 specifically the overall organizational structure, the  
16 responsibility, the reporting requirements of each of the  
17 elements of the organization, and especially the  
18 composition, independence and scope of review of the  
19 independent review and audit teams.

20           We looked at the methodology that PG&E used to  
21 implement its program. Specific areas that we looked at  
22 were the initial office activities, the field walkdown  
23 activities. A very important part was the office-based  
24 technical evaluation.

25           I would point out that all of the findings and



1 recommendations of the interaction team were reviewed back  
2 in the office during the inter-office technical evaluation  
3 phase.

4           We looked at the modifications, the criteria for  
5 making the modifications and assuring that the modifications  
6 themselves did not create new systems interactions. We  
7 looked at the independent audit and review function and the  
8 information management system to assure ourselves that all  
9 of the information developed during the course of the  
10 program was maintained in an auditable and retrievable  
11 manner.

12           (Slide.)

13           We spent a lot of time reviewing the criteria and  
14 guidance that PG&E used to evaluate the interactions,  
15 particularly those associated with the failures and sources,  
16 the postulation of interactions, the evaluation of the  
17 postulated interactions, and the resolution of postulated  
18 interactions.

19           And we reviewed results obtained after August 1,  
20 1980, because this was about the time we had to draw the  
21 line and write our safety evaluation report. We were  
22 particularly interested in the number of actions that were  
23 postulated, the type of interactions and the resolution, the  
24 means by which PG&E resolved the interactions.

25           Of interest here that relates a little bit to the

1 following discussion was, we found it interesting that the  
2 interactions that were postulated by PG&E tended to fall in  
3 a finite number of categories. It was not necessarily the  
4 interactions themselves we thought were important, but as  
5 far as possible application to other plants. But certainly  
6 the categories of interactions that they discovered  
7 certainly could apply to any plant, and we think this is  
8 important. And I will talk about that a little bit later  
9 on, on where we go from here.

10 We think these categories are things that  
11 possibly, in the future when we work toward developing  
12 regulatory guidance for future applicants and licensees, \*  
13 that they can use, in their program look at the particular  
14 areas as opposed to particular interactions.

15 (Slide.)

16 In June our team conducted a three-day audit at  
17 the Diablo Canyon site. The objectives of the audit were to  
18 continue discussions relative to our review of the program,  
19 to review the progress made to date by PG&E, to observe  
20 their walkdown technique and examples of postulated  
21 interactions, and to conduct our own independent walkdown to  
22 see how we could do, and to compare the results of our  
23 effort with those of PG&E.

24 For our own independent walkdowns, we looked at  
25 four different areas. First of all, the turbine-driven

1 auxiliary feedwater system. We looked at the steam supply  
2 piping, the electrical power supply to the turbine  
3 motor-operated throttle valves, and to the pump discharge  
4 piping.

5 We looked at the pressurizer relieve tank rupture  
6 disks to see if those disks popped or got in any kind of  
7 trouble. We looked at the containment isolation and purge  
8 system isolation valves. And we looked at the 125-volt DC  
9 battery room.

10 And of interest, these four items questioned  
11 previously came up, on how long it took to do the  
12 interaction walkdown. I think we had four people on our  
13 team. It took us the better part of a day and a half to  
14 walk down the safety-related equipment associated with these  
15 four elements. So it takes quite a bit of time.

16 It is of interest to note, too, that we postulated  
17 a number of interactions associated with these four  
18 elements, and after our independent walkdown we compared  
19 those with PG&E. We did not know their results beforehand  
20 and it turned out we duplicated their list exactly.

21 I don't think this speaks necessarily so well of  
22 us as it does to the method. We spent a lot of time. We  
23 were very deliberate, scratching our heads a lot. And there  
24 was a lot of discussion during the walkdown. And I think it  
25 shows that the method is a viable method of postulating

1 physical interactions.

2 (Slide.)

3 As far as our findings, we believe, as a result of  
4 our review -- which, by the way, I think Bart mentioned, is  
5 documented in supplement number 11 to the Diablo Canyon  
6 safety evaluation report, that is, NUREG 0675 -- as a result  
7 of our review as described in that report, we concluded that  
8 PG&E's program provides reasonable assurance that the  
9 safety-related equipment will not suffer loss of capability  
10 to perform its intended function as a result of physically  
11 induced or seismically induced physical interactions caused  
12 by the failure of non-safety-related equipment.

13 And further, the capability to accommodate single  
14 failures in the safety-related equipment is retained. On  
15 those bases, we concluded that PG&E's program was  
16 acceptable. I emphasize "program" because we really  
17 approved their program.

18 I&E, the Office of Inspection and Enforcement,  
19 will follow up on the completion of their program during the  
20 normal course of their inspection activities. And following  
21 the completion of the program for each unit, PG&E will  
22 provide to us a final report that will summarize -- contain  
23 information on all the interactions that were postulated and  
24 how they were resolved and any supporting analyses.

25 This is, in effect, a quick overview of our

1 review. We can answer any specific questions. Now, if  
2 there are none, we can move --

3 MR. PLESSET: There are two, and I think we will  
4 allow that number.

5 MR. THOMAS: All right.

6 MR. PLESSET: Bill?

7 MR KERR: I am impressed by your description. It  
8 seems to me it was a good program.

9 Do you think there would be any practical way of  
10 estimating the risk reduction that one might achieve by such  
11 a program?

12 MR. THOMAS: Practical, no. There were perhaps  
13 -- there was such a spectrum of interactions found. Some of  
14 them were negligible. Some of them were considered -- well,  
15 maybe it could interact, maybe it could not. These would be  
16 very difficult to quantify.

17 Perhaps if you looked at the biggest ones, maybe  
18 the biggest two or three, those that stood out, it might be  
19 possible. I am not sure it would really be worth it,  
20 because the approach taken by PG&E was to prevent this from  
21 happening to start with. We really did not do a  
22 cost-benefit --

23 MR KERR: No, I know you did not, and it maybe  
24 impossible. But both of you have committed significant  
25 resources to this task with the belief, which I share, that

1 you have thereby reduced risks. There are a lot of ways of  
2 reducing risk, I expect. I just wonder if it would be  
3 possible to choose among this as compared to others, on the  
4 basis of some estimate of how much risk retention one  
5 achieves.

6 This is not meant to be critical of the program at  
7 all. I think it is a good program.

8 MR. THOMAS: It could be done. I am not sure you  
9 would want to spend too much effort in doing it. I would  
10 emphasize in the future, on Indian Point for example, the  
11 Applicant is taking an approach similar to what you are  
12 describing. He is looking at systems he considers to be  
13 more high-risk in terms of they would -- through loss they  
14 might have a greater impact on the plant, the ability to  
15 take the plant to shutdown and maintain it at shutdown.

16 So he is at least -- in discussions we have had  
17 with Indian Point, the Applicant is apparently taking the  
18 approach that the equipment to be looked at will be selected  
19 on a basis of some sort of a preliminary risk basis.

20 MR KERR: Thank you.

21 MR. PLESSET: Steve.

22 MR. MOELLER: You indicated that the interactions  
23 themselves could be grouped into several broad classes.  
24 Several times you mentioned the number of actions  
25 postulated. Could you give me an idea of what numbers you

1 are talking about? How many broad classes were there?

2 MR. THOMAS: Surely. Just a second. I have a  
3 slide I can show you. This information is in the supplement  
4 11 of the safety evaluation report.

5 (Slide.)

6 This slide shows the categories of interactions  
7 and the number of interactions in each category that were  
8 postulated up until August 1. And I think PG&E can correct  
9 me. It probably can be scaled up fairly proportionately to  
10 what we found there.

11 MR. KILLPACK: That is true. They are coming in  
12 at about the same rate.

13 MR. THOMAS: There are about a dozen categories.  
14 The first category, structural grates, platforms and  
15 handrails, represented 199, really, the three categories  
16 that showed the most, electrical light fixtures and pipe and  
17 structural grates.

18 And then there were half a dozen categories that  
19 had probably, oh, significant fewer. And then there were a  
20 few that had relatively few. And you have what, twice that  
21 many total interactions now?

22 MR. KILLPACK: Yes, that is correct.

23 MR. THOMAS: So we feel these categories can  
24 really apply to any plant. The particular type of  
25 interaction that was postulated in each category probably

1 would not apply directly, but the categories certainly are  
2 areas that we feel in the future other plants should take a  
3 look at. And we are trying to come up with ways in which a  
4 program might be implemented for other plants.

5 MR. PLESSET: Can that lead into your part 2?

6 MR. THOMAS: Beautiful lead-in.

7 (Slide.)

8 MR KERR: The response is: "Yes. Maestro?"

9 (Laughter.)

10 MR. THOMAS: Okay. The next plant on our agenda  
11 is Indian Point. The requirement or the recommendation to  
12 conduct a systems interaction program for Indian Point 3  
13 originated with the ACRS in 1979. The Committee has a  
14 letter out on that that suggests perhaps they look at some  
15 different interactions or different potential interactions  
16 in maybe somewhat different ways than Diablo did.

17 We are working with the Indian Point applicant now  
18 to come up with an acceptable program for looking at systems  
19 interactions. We have met with the applicant a couple of  
20 times. We have had some discussions.

21 The applicant has, I think, engaged a number of  
22 consultants to propose a program. We have been doing some  
23 thinking on our own. To date we have not come to agreement  
24 on what should be included in the scope of the program. We  
25 certainly think it should include, as a minimum, the



1 walkdown method as shown so viable by PG&E.

2           It would also include some use of operating  
3 experience and some other method to maybe look at functional  
4 interactions. I believe the Committee referred to them as  
5 connected systems, interactions resulting from connected  
6 systems.

7           There are a couple of methods we are looking at  
8 now that may prove viable. One would be called dependency  
9 analysis, where you look at support systems, such as lube  
10 oil systems, air, electrical supplies, space and component  
11 cooling, and so on, and look at the effect of failures of  
12 these so-called support systems on the safety systems.

13           We are also looking at the possible application of  
14 failure modes and effects analysis on shared systems and on  
15 connecting systems. And there are some other methods we are  
16 looking at.

17           We are not really ready to say now what we are  
18 going to require. We want to see what the applicant will  
19 propose as a result of his discussions with his  
20 consultants. And we will get together, and I will show you  
21 the schedule for this program on the next slide.

22           San Onofre we understand is doing a seismic  
23 upgrade of its previously non-seismically qualified,  
24 non-safety related systems, somewhat analogous to what PG&E  
25 has done. I understand they had some discussions related to

1 their auxiliary feedwater systems yesterday.

2           Our branch has taken the lead in determining what  
3 has been done with regard to systems interactions,  
4 especially seismically induced systems interactions, on this  
5 program. We are just now getting started. We are going to  
6 see what has been done and what can be done and what has  
7 been done by the applicant, also, as far as determining  
8 systems interactions.

9           The applicant has indicated that he is looking at  
10 possible interactions using the walkdown method as used by  
11 PG&E. But this will be another point that we will be  
12 looking at.

13           We are also in the process of developing  
14 regulatory guidance to be used in the future by plant  
15 applicants and licensees. I will show you this schedule for  
16 accomplishing this on the next slide.

17           And then, finally, we are going to, as a result of  
18 information that we obtained from Diablo, from San Onofre,  
19 and from Indian Point, and in the development of the  
20 regulatory guidance, we are going to apply this to a pilot  
21 study of maybe six plants. The plants have not been  
22 selected. They will probably be selected some time toward  
23 the middle of the year.

24           We will use these plants as guinea pigs for our  
25 systems interaction proposed program.

1 (Slide.)

2 This slide just barely shows the schedules for  
3 accomplishing some of the things I talked about. The first  
4 item is the Diablo Canyon program -- I know it is difficult  
5 to see -- the Diablo Canyon program, which is in effect  
6 completed as far as the staff review is concerned. We have  
7 an ongoing program we call a state-of-the-art review of  
8 systematic methods for identifying systems interactions.  
9 That is continuing.

10 We have involved the efforts of a number of  
11 laboratories. We have discussed this program with Dr.  
12 Okrent's Subcommittee a number of times. We are shooting  
13 for early in '81 coming back and informing the ACRS on the  
14 results of those studies.

15 In effect, we have asked three laboratories to  
16 provide us with their opinion of methods that could be used  
17 to diagnose the systems interactions.

18 The Indian Point review is depicted in this  
19 slide. It shows the program being initiated by the licensee  
20 in the middle of December of this year. We understand that  
21 it has slipped a couple of months, primarily as a result of  
22 conflicts with TMI-related requirements. So we have to  
23 coordinate our efforts in NRR to decide priorities and get  
24 this information back to the applicant. But we expect the  
25 schedule will slip a couple of months.

1           It had originally called for issuance of the  
2 safety evaluation report at the end of fiscal year '81.  
3 That will probably also move back a couple of months. And  
4 then, following issuance of our safety evaluation report, we  
5 plan to come back and discuss our findings with the  
6 Committee.

7           Our regulatory requirement development program is  
8 scheduled to begin some time in the next month or so and  
9 continue over -- continue for the next year or so, with the  
10 aim of being able to issue some sort of final regulatory  
11 guidance in September of '82. We would expect to have a  
12 draft out maybe in mid-'81. And we would expect to  
13 coordinate this effort substantially with industry. And we  
14 will hope to be able to issue some sort of final guidance at  
15 the end of fiscal year '81.

16           MR. BENDER: I have to say that, while I am  
17 sympathetic to the idea of it taking a long time, it seems  
18 too long to wait until the end of 1981 to essentially know  
19 what might be required. Is there any way of getting  
20 something in the way of a preliminary list of things that  
21 have to be considered in systems interaction that those  
22 people that have licenses and those people that are thinking  
23 about getting licenses could use as a basis for planning?

24           MR. THOMAS: Yes. As a matter of fact, as a  
25 result of the completion of the Diablo program, we intend to

1 work with the Division of Project Management and the Office  
2 of Inspection and Enforcement and at least issue some sort  
3 of an information bulletin that would make licensees at  
4 least aware of the types of interactions that were found --  
5 the categories of interactions found on Diablo, that would  
6 reference supporting information so they could go and find  
7 out more about this, and hopefully look out for this same  
8 sort of thing in their own plant.

9           We have not really decided how we are going to do  
10 it or what we would require in response from it.

11           MR. BENDER: I think that is a useful first step.  
12 But it is not as far even as I would have envisioned going  
13 for the first phase or preliminary phase of it. In fact, I  
14 think many of us believe that the systems interactions  
15 questions are less important in the areas of seismic  
16 response than in some other places. And I think it would be  
17 useful just to know what the list is of kinds of matters  
18 that have to be dealt with in the systems interaction review.

19           Seismicity, higher protection, steam line breaks,  
20 some other things we know about. But I do not think that we  
21 have enough of a list yet. And I sure would like to see  
22 more of one than I have seen so far.

23           MR. PLESSET: Dave?

24           MR. OKRENT: In the case of possible seismic  
25 effects related to systems interactions, it was PG&E that

1 took the initiative to formulate a program which, so far as  
2 I can see, was a good program. Is it your opinion that  
3 Indian Point 3, for example, are unable to formulate a sound  
4 program, or that they have not put the resources to  
5 formulating a sound program on their own, or that the  
6 environment is such that they think they are supposed to  
7 wait for you to tell them what to do? Or just what is it  
8 that leads to the situation where there is not a program  
9 yet? And you know, it is still somewhat in the future. Can  
10 you give us your perspective on this?

11 MR. THOMAS: Yes. I think two of the factors you  
12 mentioned are the most important. First of all, Indian  
13 Point has apparently been impacted very heavily as a result  
14 of a number of things that have come up post-TMI, both with  
15 respect to siting and post-TMI requirements. We know for a  
16 fact that the manpower is really strapped, so to speak.  
17 This is one thing we have noted that has slowed them down a  
18 lot.

19 Secondly, Indian Point is going to have to go --  
20 is going to have to consider a number of types of systems  
21 interactions beyond that required for Diablo. They are not  
22 only going to have to look at seismically-induced systems  
23 interactions, but we would envision the walkdown approach to  
24 consider things like pipe whip, fire and so on, that we have  
25 been talking about today.

1           In addition, we want them to look at some  
2 functional interactions, and as of yet there is really not  
3 -- no method has really proven practical yet. There are  
4 plenty of methods out there. As we know, the Sandia report  
5 used fault tree and event tree approaches.

6           If you just jump into this head over heels, it is  
7 really not practical, and you have to have some way to  
8 decide on how you are going to apply it. We are also  
9 looking at a number of methods. I mentioned dependency  
10 analysis. This is something we are looking at in-house and  
11 trying to develop a means that can practically be applied  
12 that we can get some useful results out of in a reasonable  
13 period of time.

14           And to some extent they are looking to us for  
15 guidance. I think those are the two prime factors for their  
16 rate of progress.

17           MR. OKRENT: Well, I guess I would have assumed  
18 that, had Indian Point or Zion or the industry chosen to  
19 treat the general question of how to look at systems  
20 interactions as seriously as PG&E chose to do for the  
21 seismic part on their plant, that an approach could have  
22 been developed long before this. And although right now  
23 Indian Point 3 has been indicated as a plant on which the  
24 ACBS at least has recommended such a study be done, I have  
25 to assume that one is interested in knowing that there are

1 not major detractors to safety in all the plants.

2           So I guess it is not clear to me why the delays  
3 are necessary, and I guess I must say it is not clear to me  
4 why the industry itself has not taken a more active role  
5 similar to what PG&E did.

6           As a side comment, I would suggest when you look  
7 at your first six sites, so-called, on that site, that you  
8 include Limerick as a candidate.

9           MR. THOMAS: Any further questions?

10          MR. PLESSET: I guess not. I just wanted to  
11 remark that I had the impression that Diablo Canyon found  
12 this independent board very useful. Have Indian Point  
13 people considered this sort of thing, since, as you say,  
14 they are very short on their own personnel? I just wondered.

15          MR. THOMAS: They have not gotten that far yet,  
16 actually. But I would point out that the staff agrees that  
17 having some sort -- especially in a somewhat subjective type  
18 approach, that the capability for independent review the  
19 staff believes is very important. So we will strongly  
20 encourage that Indian Point have a similar organization. I  
21 am not ready to say it would be totally independent of  
22 PASNY. It may very well be part of the quality assurance  
23 program. But we feel the capability to look independently  
24 at what an interaction team does is very important.

25          MR. PLESSET: Any final comment, Dave?



1           MR. OKRENT: What happened at Indian Point 2 in  
2 the last month? Would you call that a potential system  
3 interaction, where they got some water into the  
4 containment?

5           MR. THOMAS: I am not familiar enough with what  
6 happened. I have been out of town for the last two weeks.

7           MR. OKRENT: I would, in fact. I guess I had  
8 thought that the staff tried to pick up the flooding  
9 question and the effect of water from non-safety systems  
10 almost a decade ago. So I was somewhat curious.

11          MR. PLESSET: Any other comment from the staff  
12 before we -- I guess not.

13          Well, I want to thank you, Mr. Hoch, for your  
14 presentation.

15          MR. HOCH: Could I make just one comment?

16          MR. PLESSET: Yes.

17          MR. HOCH: I think we said this at the  
18 Subcommittee, but I will be presumptuous enough to say it  
19 again and suggest to the Committee that, since you did bring  
20 this matter and your concern up on Diablo Canyon, your  
21 residual concern -- I believe it was in a letter from the  
22 Committee to the Commission it was mentioned, I believe,  
23 that it would be appropriate if you are -- if our program  
24 does indeed put that residual concern to bed, it would be  
25 appropriate to address it in a similar manner, I guess, and

1 formalize its disposal.

2 MR. PLESSET: I think this is already in the  
3 works. Isn't that right, Mr. Subcommittee Chairman?

4 MR. OKRENT: Yes. I think in fact that PG&E said  
5 they were going to do this before we ever put a comment in  
6 writing. We did, I believe, suggest that in a general  
7 sense, not directly, but Diablo Canyon -- seismic effects on  
8 non-safety systems -- probably our letter on TMI-2 final  
9 report or something, I guess.

10 But nevertheless, I believe it is at least the  
11 Subcommittee's plan to propose to the Committee that a  
12 letter be considered at this meeting.

13 MR. PLESSET: I think that is correct.

14 MR. OKRENT: Dr. Giess is supposed to act for me  
15 in that regard.

16 MR. PLESSET: It is already up to draft two, so it  
17 is --

18 (Laughter.)

19 MR. PLESSET: Thank you again.

20 I will now call for a short break.

21 (Recess.)

22

23

24

25

## AFTERNOON SESSION

(1:20 p.m.)

1  
2  
3 MR. PLESSET: Let's come to order and proceed with  
4 our agenda item, Revision 2 to Reg Guide 1.97.

5 Dr. Siess, will you take over as Chairman of the  
6 Subcommittee.

7 MR. SIESS: Gentlemen, I'm going to have a  
8 moderately long Subcommittee report, which I hope will be  
9 compensated for by perhaps reducing somewhat the length of  
10 some of the other presentations, or perhaps even reducing  
11 the number of questions.

12 I wish I had the time to go through the history of  
13 Reg Guide 1.97, but that would take the full two hours. But  
14 let me do take a minute to remind you that it was first  
15 issued in December of 1975 and it was instigated by  
16 recommendations coming from this Committee about  
17 instrumentation to follow the course of an accident. And in  
18 its original form there was a requirement that each licensee  
19 or applicant would perform detailed safety analysis of  
20 postulated accidents, including LOCA and ATWS and a number  
21 of others, to determine the parameters that should be  
22 measured to follow the course of that accident, their  
23 ranges, their accuracies.

24 It referred to a couple of contract studies that  
25 have been made for the staff, one by Battelle - Columbus and

1 one by Battelle - Northwest Labs, as helping them in that  
2 type of thing. And then they were to go on and specify the  
3 instrumentation needed.

4           There was something in the guide about quality  
5 level, about environmental qualifications by Reg Guide 1.89  
6 with regard to isolation, et cetera, et cetera. This is  
7 strictly a forward fit, no backfit required.

8           Essentially nothing was done. Revision 1 in  
9 August of 1977, about two years later, was in some ways  
10 similar. The first requirement was the same, make detailed  
11 analyses of the accident, except now it specified the  
12 accidents in chapter 15 of the PSAR. Again it referred to  
13 the Battelle studies. There was a regulatory position about  
14 selective instruments.

15           But there was a new position added, Position  
16 which said, in addition to what you get out of these, we  
17 want certain extended range instrumentation, and this again  
18 had been culled out specifically by the ACRS.

19           And in the two years since '75 we frequently  
20 mentioned the extended ranges, and this was for containment  
21 pressure, radiation inside containment, reactor coolant  
22 system pressure, and something about measuring radiation  
23 release through identifiable release points, and then a  
24 whole lot of other criteria.

25           There was not much progress made by anybody

1 performing the detailed safety analyses and coming up with  
2 instruments that would be needed or useful in following the  
3 course of an accident. The industry was not doing very  
4 much, nor was the staff.

5           Incidentally, Revision 1 was also a forward fit.  
6 The letter accompanying it to us said it was the intention  
7 to backfit it to all operating reactors. Later on they  
8 said, well, at least backfit the Position 3C, the extended  
9 range stuff. But there really was not much done.

10           Now, after Three Mile Island -- after the Three  
11 Mile Island Unit 2 accident, to put it crudely, I guess the  
12 staff and the industry finally realized what we had been  
13 talking about. And the staff started talking about  
14 implementing the Reg Guide. And in fact the Action Plan or  
15 the Lessons Learned Report called for the high-range  
16 instruments, and they are part of the Action Plan, and they  
17 are being called for now.

18           About that time, it became clear to the staff that  
19 the rest of the guide, the way it was written, did not get  
20 them anywhere. And so they essentially went about deciding  
21 which instruments should be provided. Before the guide had  
22 asked each person -- each Licensee to perform the detailed  
23 safety analyses and come up with a list. The guide was  
24 essentially revised and the staff came up with the list.

25           I did not say the staff performed the detailed

1 safety analysis, but there was some work that was done by  
2 contract at some stage.

3           The industry, various segments of it, have also  
4 performed some of those safety analyses and come up with  
5 lists. And one of the problems, of course, has been that  
6 different people have come up with different lists.

7           Now, that is just enough background to tell you  
8 where we thought where we roughly are. But in August of  
9 this year, the Committee first began to -- that was not the  
10 first. We had previously reviewed Revision 1 -- Revision 2,  
11 I am sorry.

12           Revision 2 was reviewed in August at the  
13 Regulatory Activities Subcommittee meeting that I  
14 fortunately or unfortunately, depending upon your viewpoint,  
15 was not present at, and it was discussed -- presented to and  
16 discussed by the full Committee at the August meeting. The  
17 Committee did not concur in the recommendations of the Reg  
18 Guide at the August meeting and sent a letter to Mr. Dircks,  
19 I believe it was, saying why.

20           Now, there is a status report in tab 9 in which  
21 Sam has summarized what is in the letter, and the letter is  
22 also included for your information. But let me try to  
23 summarize what the Committee said.

24           First it said the guide in its present form is  
25 confusing and should be clarified. And some of the

1 clarification could come out by eliminating what was  
2 referred to as a myriad of footnotes and cross-references.

3           There were three comments that are all related  
4 having to do with the scope of the guide and its  
5 relationship to other instruments and the systems -- I mean,  
6 to other systems in which the instrumentation will be used.  
7 Now, that is going to come up very frequently in this  
8 discussion and in the presentations. So let me explain what  
9 I think the Committee meant. I know what I mean.

10           There are instruments in the control room which  
11 this guide addresses. In addition, there are the SPDS,  
12 Safety Parameter Display Systems, the information that is  
13 transmitted to -- or the instruments that are in the  
14 technical support center, the emergency offsite support  
15 facility, the EOF, and the nuclear data link. And I am  
16 going to lump those things, the SPDS, the EOF, and NDL,  
17 under the heading of NUREG-0696, which is the -- I think  
18 it's the title of 0696, "Functional Criteria for Emergency  
19 Response Facilities."

20           0696 represents, say, the other uses in the  
21 emergency system. The other comments from the Committee --  
22 there were three related to that. We said, either reduce  
23 the scope of the guide and explain the relationship between  
24 these instruments and the 0696 facilities, provide a listing  
25 to clarify the relationships between the instruments and the

1 guide and the various emergency facilities. And it also had  
2 a comment about the requirements in the Action Plan and the  
3 requirements in 1.97.

4           There was a recommendation that some other  
5 instruments that had been culled out in NUREG/CR-1440, which  
6 was a contract study, that should be evaluated to see  
7 whether there should be additional instruments incorporated  
8 into the guide.

9           There was a comment regarding the requirement for  
10 thermocouples in BWR's, and a careful examination of  
11 thermocouples in BWR's should be made and this should  
12 include consideration of a number of in-core thermocouples;  
13 and it said additional efforts should be made to resolve  
14 major differences between NRC and industry. And "industry"  
15 in that context I believe was intended to mean the American  
16 Nuclear Society writing group preparing a national standard,  
17 the ANS Working Group -- Writing Group, I think they call  
18 it.

19           So it was not approved in August and it was sent  
20 back to the staff. The staff has gone to work on this, and  
21 we learned in a Subcommittee meeting on Wednesday what the  
22 staff has accomplished. And we heard from various people,  
23 their opinions of what the staff had accomplished. We had  
24 an all-day meeting most of which was devoted to this. Those  
25 present beside myself were Bender, Kerr, Carbon, Mathis and



1 Ray, and we had three consultants present, Zudans, Lipinski,  
2 and Caton.

3 We have gotten comments from the consultants, and  
4 none of them felt it necessary to stay over to today to  
5 transmit their comments to you. But I will.

6 The document that we had prior to the Subcommittee  
7 meeting was called Revision 2, Draft 3, dated October 6th.  
8 At the Subcommittee meeting we were given Revision 2, Draft  
9 3, October 30, which included quite a few changes, some in  
10 response to the comments they had received, and additional  
11 changes were made as a result of discussions at the  
12 meeting.

13 And you have had placed on your chair while you  
14 were having lunch the document that is now dated November  
15 6th, 1980, Modified Draft 3. And I have not seen it  
16 myself.

17 The staff took the ACRS recommendations seriously,  
18 as they always do, and have done or tried to do everything  
19 that we said was unsatisfactory that needed to be done. In  
20 tab 9, following a copy of our letter to Mr. Dircks, there  
21 is a letter of transmittal from Guy Arlotto which summarizes  
22 what they did, and Sam Duraiswamy has summarized that on  
23 page 2 of the status report.

24 The staff has gotten together with the ANS Writing  
25 Group and tried to resolve as many of the differences as

1 they could, and they have resolved quite a few. The staff  
2 has made a very serious attempt to simplify the guide,  
3 clarify it. They eliminated one table completely, with some  
4 20 or 30 footnotes. There are two remaining tables, each of  
5 which has a fair number of footnotes. Nobody can figure how  
6 to get rid of those. They have eliminated a lot of the  
7 cross-references they had in the previous guide, six levels  
8 of qualification, environmental and other qualifications,  
9 seismic, and they reduced that to three. They have  
10 simplified it.

11           They were told to do something about the scope and  
12 the relationship between instruments in the guide and what  
13 is required in the other facilities, and they have done that  
14 by limiting the scope of the guide to instruments needed by  
15 the operator in the control room. They make no reference to  
16 other uses of those instruments or to what is required in  
17 the other facilities.

18           And this is a very important point, that they have  
19 tried to respond to the ACRS concern by simply saying:  
20 These are the instruments that we think are needed to follow  
21 the course of an accident, and the first place you need  
22 those instruments is in the control room. Now, where else  
23 you need them is not their job.

24           0696 does not tell you what instruments you need  
25 in all the other facilities. And there is in the NRC now a

1 group called -- if I can find it -- Nuclear Data Integration  
2 Group. This is Group No. 47, Coordinating Group No. 47 or  
3 48 or 50 of the staff, of which there are myriad. It is an  
4 inter-office group, the staff of NRR and Research, and they  
5 are trying to decide what instruments should be provided in  
6 the various facilities.

7           NUREG-0696 says that those instruments in Reg  
8 Guide 1.97 constitute a minimum set to be provided in the  
9 other facilities. There may be more, but as near as I can  
10 read it, between 0696 and inside NRC, which is explaining  
11 0696, that says the nuclear data link and the emergency  
12 operations facility and the technical support center will  
13 all have access to these instruments on a call-up basis.

14           I am not sure I know what it means. Apparently  
15 they won't be dials or recorders, just a computer. I don't  
16 know. Somebody said at the Subcommittee meeting that that  
17 was not right, that people -- licensees would decide  
18 themselves or propose what instruments should be there. But  
19 that has been contradicted by something else. We will  
20 address this later, I assume.

21           At the Subcommittee meeting we had presentations  
22 by four people representing three groups. We had a  
23 presentation from the AIF, the Atomic Industrial Forum, and  
24 from NSAC, who had done work for them, reporting on --  
25 chiefly discussing the instrumentation to be provided at the

1 emergency facility and studies they have made of what is  
2 needed where.

3           Most of those studies were made since August. We  
4 had a representative speaking for the American Nuclear  
5 Society Writing Group explaining the differences between the  
6 guide and the standard. That is, you know -- maybe Mr. Ward  
7 doesn't, but everybody else should be reminded anyway -- the  
8 guide does except major portions of the proposed standard,  
9 takes exception to a significant section, and replaces that  
10 by certain other criteria.

11           There are differences. There are three kinds,  
12 basically. The guide requires certain instruments that the  
13 standard does not. There are two whole categories, D and E,  
14 that are not covered by the standard. So there is no  
15 argument there. They are in the guide.

16           But within the Class B and C, Types B and C, there  
17 are some instruments required by the guide and not by the  
18 standard, and these are not random. These are groups. They  
19 are instruments, backup instrumentation that the staff  
20 thinks ought to be in those lists, and it is categories that  
21 are in there.

22           There are still arguments -- or differences, I  
23 should say -- and the arguments follow between the  
24 qualification categories. These are qualifications for  
25 design and environment between the two documents, many, many

1 fewer than there were previously, and there are some  
2 arguments still going on on ranges of instruments. And a  
3 couple of those we may want to hear about today. We'll  
4 probably hear about many of them.

5           But we had a presentation by a representative from  
6 Stone & Webster who had read the guide carefully, and had a  
7 number of suggestions and a number that the staff  
8 immediately picked up on, that that is a good one, we will  
9 fix it up, and some they had already fixed up.

10           The residual concerns that exist, some in the  
11 industry I will mention and some in the Subcommittee. The  
12 concerns that the industry has are the differences between  
13 the proposed standard and the guide: which instruments are  
14 included, certain qualification criteria, and ranges. Some  
15 people felt -- I think Mr. White of the ANS group -- that  
16 another round and they might eliminate all of the  
17 differences.

18           Now, I do have to point out that the changes that  
19 were made from August until now were all made in the  
20 Regulatory Guide. They were not made in the standards.  
21 There were some changes made in the proposed standards, but  
22 they are not substantive to our discussion. They were made  
23 in sections of the standard that the guide does not endorse,  
24 the guide replaces. So they are not substantive.

25           But they did think that another round and they

1 would get closer together. My personal opinion, for what it  
2 is worth, is I think we have the differences down almost to  
3 irreducible minimums for something like a Reg Guide. And I  
4 personally am not sure that we have to have that kind of  
5 complete perfection in a Regulatory Guide. It is a guide.  
6 People can argue about it. If it does turn out that there  
7 is something wrong about it, the staff usually can be  
8 convinced.

9           There are differences on qualification, criteria,  
10 range. All of these things still exist.

11           The Forum people and some of the others, their  
12 thoughts were expressed, are still concerned about the  
13 relation between the Reg Guide 1.97 instrumentation and the  
14 instrumentation readouts or callup capability in the other  
15 emergency response facilities. The Forum people would like  
16 for us to back up completely and start over working with  
17 industry in developing this whole spectrum of instruments.  
18 And this disturbed me a little bit, because they were in  
19 effect saying: Don't work with us; don't work with the  
20 ANS. And I am not sure that they meant that. But they  
21 said, let's start over.

22           We started around this thing, I think, at least  
23 four times, and I was not -- well, the Subcommittee I don't  
24 think is particularly receptive to that approach. The  
25 Subcommittee has a number of concerns that we think should

1 be aired. One has to do with the other uses. And some of  
2 our consultants expressed that concern. Some of the members  
3 did.

4 I will come back to that. But it's something for  
5 you to think about.

6 There is a requirement in the guide to measure  
7 radiation exposure in the environments, not releases but  
8 exposure, at some undefined distance, at some undefined  
9 interval, but with an immediate and continuous readout.  
10 This information would be used in some not clearly defined  
11 way as far as the guide is concerned, but obviously to be  
12 used for determining emergency actions off-site.

13 It occurred to us that this was a very large step  
14 in the emergency planning, emergency action process. And  
15 there was quite a bit of discussion about this. There was  
16 an industry representative who thought it was excessive or  
17 impossible to do if you went very far off. The staff did  
18 not think they wanted to go very far out. They did not know  
19 quite how far they wanted to go.

20 It is a very open-ended requirement that could end  
21 up costing as much as everything else put together,  
22 depending on how it is interpreted. That is not what  
23 bothered us so much as the concept of using instrumentally  
24 to determine exposure rates, say, at exclusion distance, to  
25 take actions further downwind. And we asked the staff to

1 discuss this further before the Subcommittee and make a  
2 presentation on that particular thing, on both the  
3 rationale, et cetera.

4           And I suggested that this should be at a higher  
5 level than seems to be appropriate within NRR. NRR is  
6 involved in this. This is just not all Standards  
7 Development people. And most of the discussion on this was  
8 coming from NRR people. So we invited anybody up to Harold  
9 Denton's level to come in and explain this use of this  
10 particular implementation, keeping in mind that one of the  
11 ACRS' objectives when we asked for instrumentation to follow  
12 the course of an accident was to provide information that  
13 would be useful in determining when to take measures offsite  
14 and what measures to take. And this is clearly in that  
15 category, although some of the instrumentation may be  
16 offsite.

17           We got into a discussion about the range of the  
18 instrumentation to measure hydrogen concentration and oxygen  
19 concentration in inerted and non-inerted containments. The  
20 industry complains about 30 percent versus 10 percent. And  
21 we got so far into a discussion of that and ran out of  
22 people that knew the answers.

23           Walt Butler, who sat through most of the meeting,  
24 but by the time we got to this Walt had run out on us.

25           (Laughter.)



1 I don't blame him. I would have run out too if I  
2 hadn't been Chairman.

3 (Laughter.)

4 So Walt is here. He was accused of being  
5 responsible for those, so if he would explain them or defend  
6 them, as the case may be. BWR thermocouples in-core or core  
7 exist thermocouples. The term "core exit thermocouple" had  
8 been used up until the time we wrote the letter in August.  
9 That letter said considerations should be given to a limited  
10 number of in-core thermocouples.

11 The staff announced, I can say rather proudly but  
12 I am not sure that is proper, that they had reached  
13 agreement with GE on in-core thermocouples, and the guide  
14 calls for these now. Before it said unresolved. What the  
15 guide calls for is two to four thermocouples in each  
16 quadrant of the core, located at a distance of one-fourth to  
17 one-third of the height below the top of the core.

18 These are to be installed in these thimbles  
19 traversing the in-core probes or whatever you call those  
20 things. This raised quite a few questions. One was, would  
21 they tell you anything, which was not exactly a new  
22 question. Industry has been asking that for several  
23 months.

24 Another was, did they need -- they were not core  
25 exit, they were down in the core. Do you really want to

1 know what is happening up there? Walt Lipinski had  
2 questions about this. I think Caton thought they weren't  
3 worth a dime.

4           Sam, I don't have Caton's -- okay, fine, it is  
5 here. And besides, the Committee had said that a careful  
6 examination of their use should be made or studied. And we  
7 asked the staff if they had made a careful examination, and  
8 they said, no, but GE had.

9           So we asked them to invite GE in to present the  
10 results of their careful examination at this meeting. And I  
11 understand that GE will not be here, but that somebody from  
12 staff will be here to explain what GE did. So we plan to  
13 have presentatio on the -- the staff will make a brief one  
14 explaining what they have done.

15           We want to hear -- we have asked the ANS  
16 representative to comment on the differences. The other  
17 people have made oral presentations, did not see any need to  
18 repeat them before the full Committee. Walt Butler is here  
19 to answer the question about the hydrogen range, and there  
20 will be somebody from staff to explain how they arrived at  
21 the in-core thermocouples.

22           Now, Walt Lipinski raised a question as to whether  
23 ATWS was one of the accidents we were supposed to consider,  
24 and he said if it is the range on the neutron flux  
25 measurement is not large enough. It turns out on the BWR it

1 has been revised to say now to use the average power range  
2 monitor, and that does go to 100 percent. So that is high  
3 enough, he thought.

4 But the PWR still says something like up to 5  
5 percent on neutron flux. He says in an ATWS that is not  
6 good enough.

7 And in neither type reactor does the reactor  
8 coolant system pressure go high enough. For the PWR it goes  
9 to 1500 -- I mean, it goes to 3,000, I think, and for a BWR  
10 to 1500 psi.

11 MR. OKRENT: I thought the way it was worded was  
12 there was a footnote saying, we have not decided how high  
13 this should be.

14 MR. SIESS: We got that decided between the last  
15 meeting and this one.

16 MR. OKRENT: They have decided?

17 MR. SIESS: You have the latest copy.

18 MR. OKRENT: All right. Well, I am thinking of  
19 the last copy that was sent to me.

20 MR. SIESS: On the pressure?

21 MR. OKRENT: On the pressure. It still had a  
22 footnote saying they needed to decide the primary system  
23 pressure.

24 MR. SIESS: We will look it up. But it does not  
25 go as high, I think, as the calculated peak ATWS pressure

1 before mitigation installations. I am not really sure about  
2 that. But this was a point Walt raised. He raised it -- we  
3 spent a lot more time talking about neutron flux than about  
4 pressure.

5 MR. OKRENT: I did not understand what you said  
6 about neutron flux. You say it goes to 5 percent?

7 MR. SIESS: The wording in the table originally  
8 said -- oh, my gosh, it got changed back. For a BWR it  
9 originally said 10<sup>-6</sup> and 5 percent full power. Then they  
10 changed it to 10<sup>-6</sup> and 5 percent full power, but in  
11 parentheses "source monitored at APRM." APRM goes to 100.

12 It now says 10<sup>-6</sup> at 100 percent full power --  
13 for peak -- for a boiler. For the pressurized it now --  
14 that is on page 20A. Pressurized water reactor, now it says  
15 100 percent. It got changed overnight.

16 MR. OKRENT: Is there another variable that goes  
17 to a higher neutron flux?

18 MR. SIESS: Ask the staff. I don't think so.

19 MR. KERR: There has to be, because trip is not 100  
20 percent.

21 MR. OKRENT: Exactly.

22 MR. SIESS: We have to make a distinction,  
23 gentlemen, between instruments and Reg Guide 1.97.

24 MR. OKRENT: Let me be quite specific. In terms  
25 of Reg Guide 1.97, is there a need to have an instrument

1 that goes above 100 percent full power or not?

2 MR. SIESS: Walt seemed to be satisfied at 100 and  
3 we did not get a chance to explore that in that much  
4 detail. He was mainly interested in getting it over 5  
5 percent. I think when he got it up to 100 he sort of  
6 relaxed.

7 He mentioned that you can get a peak that goes to  
8 150 or 200 at ATWS, but it comes back down again very fast.

9 Does the staff want to try to address that one  
10 later or do you want to try to settle it? If you think you  
11 can settle it, try to do it now.

12 MR. ROSENTHAL: I think the actual instruments  
13 would go to 150 percent of full power. I can't see at this  
14 point mandating additional hardware be installed.

15 MR. OKRENT: I am curious, I must say. What is  
16 the position on pressure now? For a Westinghouse plant,  
17 what is it you are asking?

18 MR. SIESS: Just a minute.

19 MR. ROSENTHAL: 3,000 psi.

20 MR. SIESS: Page 36 --

21 MR. HINTZE: the footnote is there that it may be  
22 revised upward after the studies are complete.

23 MR. OKRENT: I want to ask a question in that  
24 regard.

25 MR. OKRENT: For a boiler you have 1500 and no

1 footnote.

2 MR. OKRENT: Will you revise it upward on a  
3 Westinghouse plant if they calculate 3100 or 3200, or will  
4 there be some other judgmental basis or what?

5 MR. WENZINGER: In the case of 3,000 pounds --  
6 excuse me. Had it been calculated, I would estimate that we  
7 would probably raise the range to in the neighborhood of  
8 35000.

9 MR. OKRENT: I must say, I would have thought you  
10 would take the primary system up to what you think is a  
11 failure pressure on some kind of not too accurate reading,  
12 because I for one do not think we are able to foresee, you  
13 know, all the situations in which we might be interested in  
14 pressure. And to tie it to what somebody has calculated in  
15 some particular sequence strikes me as going exactly in the  
16 opposite sphere from which this whole thing is inspired,  
17 namely the original problem with everything was for the  
18 design basis event and it did not measure anything beyond  
19 it. And now you say, well, you have sort of a new design  
20 basis for these instruments, namely what they calculate in  
21 ATWS with a little margin.

22 Pressure, it seems to me, you really ought to have  
23 a range, as I say, that goes up to --

24 MR. SIESS: Let me just --

25 MR. OKRENT: Perhaps you should go well above 150

1 percent, because --

2 MR. SIESS: Let me just point out that in Revision  
3 1, Position 3C, which was the extended range  
4 instrumentation, the staff had already agreed they were  
5 going to implement that, remember? Item C, reactor coolant  
6 pressure three times design pressure.

7 MR. OKRENT: I don't have any problem with three  
8 times.

9 MR. SIESS: That may not be quite as high as your  
10 rupture pressure.

11 MR. OKRENT: It is in the ballpark, sure.

12 MR. SIESS: It is not one and a half.

13 MR. OKRENT: Exactly, it is three --

14 MR. SIESS: It is not one and a half. So we  
15 backed off from that. And frankly, I cannot see that much  
16 difference between 3,000 psi and 1500. You don't have  
17 either one now.

18 MR. BENDER: I would like to at least take a  
19 minute to challenge the suggestion that Dave has. There are  
20 some places where you in fact will want to have the range of  
21 the instrumentation very large, and containment is perhaps  
22 one of them. But it does not make much sense to put in  
23 instrumentation that will measure a very high pressure when  
24 you know the only time that that pressure will occur is if  
25 there is a very short interval of time in which that

1 pressure is imposed.

2 I am concerned about putting in developmental  
3 types of instrumentation or specialized types of equipment  
4 to take care of the very rare accident, when the operator  
5 really cannot use that instrumentation for any purpose. The  
6 high pressure coolant pressure measurement is one of those  
7 things.

8 MR. SIESS: I would like to suggest that that is  
9 one item I want the Committee to discuss, but I had sort of  
10 hoped we would discuss it after I finished with my  
11 Subcommittee Chairman's report.

12 MR. PLESSET: Okay. Go ahead, Chet.

13 MR. BENDER: I will hold back.

14 MR. SIESS: I want to go on to one item I  
15 mentioned before. That is the scope of the guide and the  
16 relation of these instruments to the emergency response  
17 facility situation. At the Subcommittee meeting I tried to  
18 limit the scope of our discussion, with the simple objective  
19 of getting through in one day to what was in the guide, that  
20 is, a selection of those instruments -- those parameters and  
21 the instruments, ranges, et cetera, that are necessary to  
22 follow the course of an accident without regard to how those  
23 instruments would be used, other than that they would be in  
24 the control room and the idea that some of them will be tied  
25 into the SPDS, which also will be in the control room.



1           What came out in the discussion, I obviously could  
2 not limit it to that. My gavel was not long enough. And  
3 what came out in the discussion was, there are concerns in  
4 the industry, there are concerns from Walt Lipinski and  
5 others, that the qualifications of these instruments may be  
6 changed by lead time into external facilities, that the way  
7 they are hooked up to external facilities, to a computer or  
8 not to a computer, the way isolation is provided, et cetera,  
9 et cetera, could change the reliability of the instruments  
10 in the control room itself.

11           And I suggested at one point that we might get  
12 around some of those and still be able to keep Reg Guide  
13 1.97, which does list the necessary instruments, separate  
14 from these other questions by simply advising the staff that  
15 the implementation date for Reg Guide 1.97 should not be set  
16 independently of the implementation -- of the decision  
17 regarding the other uses of these instruments. That is,  
18 that the implementation date should be set so that people  
19 have the entire picture of how these instruments are being  
20 used before they start ordering or designing them.

21           It is a little late for that, because some of them  
22 have been required by letters and orders. But that is not  
23 new. That may or may not be a suitable solution.

24           The Committee apparently at the August -- not  
25 apparently, because I read the transcript. The Committee at

1 the August meeting did address all these interfaces,  
2 interconnections, et cetera. And I would propose you want  
3 -- you might want to continue that discussion, but consider  
4 the possibility that, by simply not requiring people to  
5 start soon on implementing this, that they might be able to  
6 work this thing out.

7           That inter-office committee is supposed to come up  
8 with some answers. And according to inside NRC memoes from  
9 reliable sources, it says it is expected to have something  
10 out in one to three weeks. It did not say one to three  
11 weeks from when, but that is enough.

12           So I would like to propose the following: that we  
13 have a brief presentation from the staff -- they can make it  
14 as long as they want, and they will -- that we hear from a  
15 representative of the ANS standards-writing group, and that  
16 -- that is Mr. Ed Wyatt -- and then that we at least discuss  
17 the question of the BWR thermocouples, or at least open that  
18 to discussion, because I think the Committee will want to.  
19 If you don't want to, that is your business.

20           If we discuss the hydrogen emission range and get  
21 that rationale, since it was not settled in the Subcommittee  
22 and it seems to be of some interest, and we discuss the  
23 requirements for the use of the environs radiation exposure  
24 instrumentation, and then that we discuss this integration  
25 into the 0696.

1           Is Warren Ramos here? We have somebody -- do you  
2 represent the inter-office coordinating group.

3           MR. RAMOS: Yes.

4           MR. SIESS: They can address those things. The  
5 staff can address that question and we will take it up as it  
6 comes. That was Lipinski's concern, and I think all of  
7 Lipinski's concerns are included. He was interested in the  
8 ATWS condition, neutron flux and pressure. He had concerns  
9 about the in-core thermocouples and what they would indicate  
10 about cooling of the core over its entire height. And he  
11 was particularly concerned about the use of computers in  
12 integrating all of these systems, the possibility where you  
13 have it hooked up so one failure would knock everything  
14 out.

15           Those are all within the scope of the things I  
16 mentioned. Does that sound reasonable?

17           MR. MARK: Okay.

18           MR. SIESS: I apologize for the length. That is a  
19 factor of about 20 to one on the time that the Subcommittee  
20 took. Oh, yes, and Bill Coley made the presentation on the  
21 AIS study which addresses all the instruments -- needed  
22 instrumentation and miscellaneous uses, and he did not  
23 request time for making a statement at the full Committee  
24 meeting, but he is here and if questions come up about that  
25 he will be very happy to answer them or to make a short

1 presentation.

2           So so we have people available on almost any  
3 subject -- no, I will not say that.

4           (Laughter.)

5           I would like to just remind the Committee of  
6 something we have been fussing at the staff for -- I won't  
7 say months or years -- but about getting this thing out.  
8 And the last six months we have been the delaying factor and  
9 not the staff.

10           MR KERR: I would say that is a very charitable  
11 view.

12           (Laughter.)

13           MR. SIFSS: In favor of who?

14           MR. MOELLER: In terms of the Reg Guide, I have  
15 looked at it, but I need help on certain details. When we  
16 met with the RSK group and talked about instrumentation,  
17 they talked about, to the extent possible and where  
18 practical, they located instruments outside of the  
19 containment, so that not only would they not be harmed by  
20 the environment after an accident, but they could be  
21 repaired.

22           Is there any of that kind of thinking in this  
23 guide?

24           MR. SIESS: I don't believe there is explicitly.  
25 We will let the staff answer -- make a note of it and answer

1 it as part of their presentation. There are qualification  
2 requirements.

3 MR. MOELLER: Right.

4 MR. SIESS: The ones that are in a potentially  
5 hostile environment must be qualified. Obviously, you can  
6 move them out of that environment, but an instrument must be  
7 qualified for whatever environment it is. It might be this  
8 room.

9 MR. MOELLER: Well, they do address it indirectly  
10 on page 3. But I just wondered if they promoted --

11 MR. SIESS: It is not all that simple. You've got  
12 to have -- you have sensors that have to be --

13 MR. MOELLER: The sensors do have to be.

14 The second question was, is the reliability and  
15 accuracy of the instruments addressed in his guide?

16 MR. SIESS: Accuracy is not addressed in the Reg  
17 Guide. That is addressed in the standard which is endorsed  
18 by the Reg Guide. If you don't have a copy of the standard,  
19 we will get you one. We just did not look at the details of  
20 that, and I think the staff is satisfied with the standard  
21 addressing accuracy.

22 MR. MOELLER: What about reliability?

23 MR. SIESS: The qualification categories  
24 essentially define levels of reliability. There are three  
25 categories. The lowest is simply not Class 1-E instruments,

1 but good commercial -- good grade commercial instruments.  
2 That is the lowest category. The others are progressively  
3 higher, up to seismic 1-E and so forth, and presumably that  
4 controls reliability. I say presumably. We don't have that  
5 much proof, I guess.

6 MR. MOELLER: At the same time, presumably someone  
7 is looking at LER's and feeding back the information on the  
8 performance of instruments into this. Why I mentioned that  
9 --

10 MR. SIESS: No, I wouldn't --

11 MR. MOELLER: I said presumably.

12 MR. SIESS: I would not begin to presume that.

13 MR. MOELLER: We were talking about hydrogen and  
14 oxygen measurements, and I will repeat what I think I said  
15 recently. I just looked for one week at the LER's and I may  
16 have hit a vintage week, but there were six reported  
17 failures of hydrogen monitors just in the group of LER's.

18 MR. SIESS: Incidentally, for certain instruments  
19 -- and I am not sure about hydrogen -- redundancy is  
20 required. There are certain parameters where diversity is  
21 required, to so-called backup instrumentation, and these are  
22 all addressed in the categories.

23 MR. KERR: Were there six failures or six LER's?

24 MR. MOELLER: There were six LER's.

25 MR. SIESS: There might be one failure.

1 (Laughter.)

2 MR. SIESS: Mr. Chairman, I have not asked the  
3 other member of the Committee. I think we might well ask  
4 the other members of the Subcommittee for comments; Mr.  
5 Bender, let's say, as to the scope, for one thing. Shall we  
6 do that?

7 [REDACTED] Please.

8 [REDACTED] S: I will take them in the order I have  
9 them on my list. Mike?

10 MR. BENDER: I think Chet did an admirable job of  
11 summing up what was discussed. I want to add a few points  
12 that I have a slightly different perspective on, rather than  
13 standing there and -- first of all, there was a lot of  
14 discussion of the question of what is meant by  
15 "qualification." And while the staff allows and provides  
16 for redundancy and considers to some degree repairability  
17 and the diverse use of informational sources, and even deals  
18 with the question of when to isolate safety-related from  
19 non-safety related equipment, the people that are on the  
20 receiving end and have to apply the standard do not have any  
21 perceptible rationale for how to make those decisions.

22 I think you have to conclude it is going to be a  
23 cookbook and those people that are going to have to deal  
24 with it are going to have to deal with it as a cookbook. My  
25 own perception of that is it will lead to a lot more

1 instrumentation than is needed and a lot more complication  
2 in the system than is desirable.

3           But that is something that the Committee will have  
4 to judge. It probably will be worked out in the application  
5 of the guide. It would have been helpful if the guide had  
6 spent more time trying to develop that rationale.

7           With regard to the instrumentations themselves, I  
8 think we have to recognize some of the most important  
9 requirements involve developmental types of  
10 instrumentation. We do not yet have anything that indicates  
11 unambiguous coolant level in the reactor pressure vessel.  
12 But that is one of the most important instruments to be  
13 included in this thing.

14           We don't yet have the instrumentation that defines  
15 radionuclide content in the primary coolant system or in the  
16 containment, but we do know that we can get something. But  
17 that is still to be defined.

18           And thirdly, I think there is the matter of real  
19 time response of instrumentation that is essential to the  
20 containment if it is to be used to trigger emergency  
21 actions. Those three things may be the most important areas  
22 where we need instrumentation to follow the course of  
23 accidents.

24           A lot of the other instrumentation is essentially  
25 instrumentation that is already in the plant, and the issue



1 is likely to be more whether you can rely on that  
2 instrumentation without some redundancy or some improvement  
3 in its qualifications. And recognizing that the  
4 instrumentation exists in the operating plants and is  
5 designed in others, we are going to have to deal with the  
6 question of what the impact would be of asking for a massive  
7 change in the qualification requirements.

8           With regard to the real need of the  
9 instrumentation, I wanted to offer some thoughts that I have  
10 concerning what might be our criteria for judging these  
11 things. First of all, there is a need to have  
12 instrumentation to trigger emergency response, and that has  
13 to do with what perhaps is getting out of the containment or  
14 what has gotten into the containment.

15           Secondly, there is the question of what  
16 instrumentation is needed to provide guidance to operators  
17 in unanticipated accidents. Now, if we put too much into  
18 this area we may wind up inundating the operator with  
19 information. And as a matter of fact, the Ohio State review  
20 of this thing suggests the only way it could be done is by  
21 adding some kind of computer to analyze the information.  
22 And we will have to think about whether that is a useful  
23 option or not.

24           Thirdly, there is the question of how much  
25 instrumentation is needed to evaluate the extent of the

1 accident as it progresses. We may want to know how fast the  
2 pressure is rising in containment. We may want to know how  
3 fast pressure is rising in the primary coolant system. It  
4 is not clear to me that we need to know the peak pressures  
5 in either case, as long as the operator knows enough to be  
6 able to diagnose his actions.

7           There was some discussion yesterday at the fact  
8 that some instrumentation is needed for the purpose of  
9 deciding whether to start up again. I would argue that that  
10 is an unnecessary or undesirable characteristic of this  
11 instrumentation, because we will never know what we need to  
12 assess the damage and it is unlikely that we could put in  
13 the kind of comprehensive instrumentation that might be  
14 considered.

15           A last point I want to make is that we really need  
16 to make sure that we don't overwhelm the operator or the  
17 control boards with excessive instrumentation. The  
18 criticism that was made at TMI was partially that he had too  
19 much information to deal with. I think we have to recognize  
20 that these requirements may multiply the number of  
21 instruments he has to look at and evaluate, and I think that  
22 that ought to be considered.

23           And that is all I want to say.

24           MR. SIESS: Okay. Bill?

25           MR. KERR: I consider this version of the draft

1 Regulatory Guide a decided improvement over previous  
2 versions. I would hope that we could give approval to it  
3 with minor modifications, not because it is in a form I want  
4 to see final, but I think it is far enough along that with  
5 reasonable wisdom in its application it could be used.

6 I have some reservations, as some of the other  
7 Subcommittee members did, about the thought that has gone  
8 into the specification of dose rate instrumentation  
9 offsite. It seems to me if we can persuade the staff --  
10 maybe indeed I have not looked carefully and they have  
11 changed it. But if I could persuade them to put that  
12 somewhere else, the quality of the work might be enhanced  
13 some.

14 I have no further comment.

15 MR. SIESS: Max?

16 MR. CARBON: I think the summary and the added  
17 points have both been excellent, and I guess I have nothing  
18 worthwhile to add.

19 MR. SIESS: Charlie?

20 MR. MATHIS: One question, I guess. This did not  
21 come up in the Subcommittee meeting, but a disturbing bit of  
22 information in the little epistle called "Inside NRC." In  
23 the latest issue of that, where it discusses 1.97, it  
24 mentions this is a minimum listing of instrumentation  
25 required, and that additional parameters may be called up at

1 a later date. And that to me then is an open-ended  
2 situation, if that is true, and I would like to hear some  
3 more about it.

4 MR. SIESS: Okay. Jerry?

5 MR. RAY: No additional comments. I think he did  
6 an excellent job in summarizing a very difficult topic.

7 MR. SIESS: You have a copy of Caton's comments,  
8 and I summarized Lipinski's for you. And Zudans' again was  
9 concerned about the use of the SPDS.

10 That completes the Subcommittee report, Mr.  
11 Chairman.

12 MR. PLESSET: Chet, is it your view that the NRC  
13 should proceed next?

14 MR. SIESS: Do you have a question?

15 MR. OKRENT: I have two questions. Is it the  
16 Subcommittee's impression that somewhere on the plant now  
17 there exists something that will measure the power  
18 approximately if it goes to 150 percent or 200 percent or  
19 300 percent or to 100 percent or 500 percent?

20 MR. SIESS: I don't think the Subcommittee can  
21 answer that, Dave.

22 MR. KERR: If you can answer it the way it was  
23 posed, which was is it the opinion of -- isn't that what you  
24 said? It is not my opinion that one can measure 400 percent  
25 of operating power.

1           MR. OKRENT: So in other words, if they had a  
2 transient, the ATWS or something else, do we know at what  
3 power level you would no longer get a reading on the  
4 computer or on some permanent record?

5           MR. SIESS: Let's ask the staff.

6           MR. OKRENT: Okay. That is one question I have.  
7 Do you want to deal with that now. I have a couple of other  
8 questions, but that is fine. Let's ask the staff.

9           MR. WENZINGER: Okay. Dr. Okrent, if you are  
10 speaking of neutron flux and measurement of power levels  
11 through that mechanism, to the best of our understanding the  
12 range of those instruments is generally limited to 150  
13 percent of power, 150 percent of full power.

14          MR. OKRENT: And that is limited by what?

15          MR. WENZINGER: The range of the instruments that  
16 are currently installed. Principally the current measuring  
17 capability of the ion chambers and the associated electronic  
18 switch is, for that power level, on the order of a milliamp  
19 or so.

20          MR. OKRENT: That depends on the full range of  
21 instrumentation trying to measure accurately at 20 percent  
22 or whatever, and it can go up perhaps too high before it  
23 gets excessive. In other words, it is not impossible -- not  
24 necessarily difficult to design something that could tell  
25 you.

1 MR. SIESS: You asked if it was there.

2 MR. OKRENT: Right. I am trying to understand.

3 Okay.

4 Now, is it thought that if a transient were to  
5 occur in which the power went above this power level, 150  
6 percent, that such information would not be of interest to  
7 the shift technical advisor or the people back at the  
8 instrument center or back at the facilities headquarters?  
9 Not while it is occurring. I am not talking about on-line,  
10 because I am assuming that at that power level it is not a  
11 steady state situation.

12 MR KERR: That is another Reg Guide. This is only  
13 for following the course of the accident for the operator.

14 MR. OKRENT: There is another Reg Guide?

15 MR KERR: Must be.

16 MR. OKRENT: I don't think so. It's thought that  
17 this -- there is no way in which such information might have  
18 an impact on what you thought should be done and what the  
19 status of affairs was, or so forth? I don't fully  
20 understand what the staff's thinking is.

21 MR. SIESS: You are hypothesizing that you have a  
22 record that shows that the flux meter went off scale, came  
23 on scale. And the question is: Would knowing where it went  
24 to affect how you managed the accident?

25 MR. OKRENT: And what you did thereafter.

1 MR. SIESS: And what you did thereafter.

2 MR. OKRENT: I can perceive things where I would  
3 be interested. I don't know if the staff would.

4 MR. SIESS: Is there a caucus going on back there?

5 MR. ROSENTHAL: Surely one of the functions --

6 MR. SIESS: Identify yourself, please.

7 MR. ROSENTHAL: Jack Rosenthal, ICSB.

8 Surely one of the functions of the guide is  
9 long-term verification. And we did envision scenarios in  
10 which, in order to take long-term action, one would like to  
11 know if a scenario is involved. An example at TMI-2 was the  
12 decision on whether to depressurize or not, and that was  
13 influenced by the fact that the thermocouples were somewhere  
14 reading superheated conditions long after the temperature  
15 was low.

16 We did not pick up -- we did not address extended  
17 range on power, but we do have diagnostics of the condition  
18 of the core in terms of radiation releases, et cetera.

19 MR. OKRENT: Well, I must say I think one is  
20 apparently neglecting an opportunity to get information that  
21 under some circumstances I think could be quite interesting,  
22 quite relevant to some of the decisionmaking in the minutes  
23 or hours after the actual power spike occurred. So that is  
24 a personal opinion.

25 On pressure, again, do you not foresee any reason

1 why you might not be interested -- let's talk about an  
2 example, a PWR -- whether or not it reached 4,000 or 4800,  
3 in other words, if it went off scale at either 3,000 or 3500  
4 and, let's say, came back? Do you think that might not have  
5 a bearing on some of your thinking with regard to recovery  
6 from a situation?

7 I am not going to try to explore the question to  
8 --

9 MR. SIESS: We discussed that in the Subcommittee  
10 and we were told that recovery is really not a concern.

11 MR. OKRENT: I mean recovery down to cold shutdown  
12 when I say recovery. In other words --

13 MR. SIESS: Okay. It was addressed previously.

14 MR. OKRENT: I don't mean recovering the plant  
15 now. Are there no circumstances where you think having the  
16 thing go off scale and come back on has been a possible  
17 significant disadvantage?

18 MR. ROSENTHAL: I can imagine one in which it  
19 would be useful, as follows: You would like to know if you  
20 are in an incipient failure mode and if you suffered a  
21 severe pressure pulse. You see that you are at some point  
22 maintaining now some system integrity, but you are concerned  
23 that because of prior events you are in an incipient failure  
24 mode. And then your actions as far as how fast you want to  
25 do something else might change.



1           MR. OKRENT: I think that is a fine example. In  
2 any event, thank you for giving that example. And I think  
3 one could equally well find one -- anyway, it is my  
4 impression it is not developmental to make these  
5 measurements. I don't think they have to be made very  
6 accurately. In my opinion, we are interested in 10 percent  
7 accuracy, perhaps, at that point, not 1 percent, if I can  
8 pull a number out of thin air. I will leave it at that.

9           MR. SIESS: What I propose, Mr. Chairman, let the  
10 staff start off, and then I think if you would let the  
11 representative from the ANS Working Group make some  
12 comments, it would be appropriate, Ed Wyatt, because this is  
13 tied closely to the proposed standard and that was an issue  
14 last time. And much of the staff's effort has been in that  
15 direction.

16           And then we can explore with representatives of  
17 the staff present particular issues that the Subcommittee  
18 culled out and others the Committee may bring up.

19           MR. PLESSET: All right.

20           MR. SIESS: I would not object to a break before  
21 we start.

22           MR. PLESSET: How does the Committee feel? Okay,  
23 we'll take a break, yes.

24           (Recess.)

25           MR. PLESSET: Will you go ahead?

1           MR. WENZINGER: Good afternoon. My name is Edward  
2 Wenzinger. I am chief of Reactor Systems Standards Branch  
3 in the Office of Standards Development.

4           It has been my experience to have dealt with this  
5 Regulatory Guide for quite some time now. Mr. Hintze of my  
6 staff has been with us since the beginning.

7           I will try and go quickly through the recent  
8 history of this guide. Dr. Siess has told you about the  
9 ancient history and some of the more recent modern history  
10 on this guide, and I will just summarize that.

11           Draft 2 of Revision 2 of Reg Guide 1.97 was  
12 reviewed by the Regulatory Activities Subcommittee on August  
13 6th and by the full Committee on August 7 of this year.  
14 They referred the guide back to us to consider your concerns  
15 and you outlined these in the Chairman's letter dated the  
16 13th of August. The ACRS concern in part will be detailed,  
17 with the guide's technical provisions and particularly the  
18 major differences between the staff and the industrial  
19 representatives who commented on the guide.

20           In an attempt to resolve this concern, we met with  
21 members of the American Nuclear Society, the Atomic  
22 Industrial Forum, the Nuclear Power Engineering Committee,  
23 and the IEEE, some fellows from the Ohio State University  
24 and others, where differences were discussed. This took  
25 place on September 5 at NRC headquarters.

1           Agreement was reached in several areas which  
2 brought the views of the commenters and the NRC staff into  
3 sharper focus. For example, the guide was modified to focus  
4 on monitoring requirements, control room operating  
5 personnel, definition of design basis accident events, as in  
6 the ANS standard.

7           We also had a follow-on meeting, September 25 and  
8 26 in Denver under the auspices of ANS, and a detailed  
9 review of the Type B&C variables was made during this  
10 meeting. Additionally, the Atomic Industrial Forum has  
11 developed independently of this effort a list of variables  
12 needed by the control room operator and a preliminary  
13 version of this has been reviewed and considered.

14           Reg Guide 1.97, this review and comparison did  
15 include the Type D and E variables in the guide. It is  
16 believed by the NRC staff that the major differences between  
17 the staff position and the people who commented on the  
18 previous versions of the guide have been resolved.

19           Incidentally, you were sent on August -- excuse  
20 me, October 15 -- a copy of the guide, and between then and  
21 now there have been some revisions made. You have a copy of  
22 the version that is accurate as of yesterday, as a result of  
23 comments received in between October 15th, the Subcommittee  
24 meeting, and as a result of the Subcommittee meeting this  
25 past Wednesday.

1           About 99 percent of the changes that have been  
2 made in the guide since it was sent to you on October 15  
3 have been changes in the list of variables. The ANS  
4 standard that is endorsed by this guide, ANS 4.5, is  
5 currently in the final stages of development by ANS, has  
6 been approved by the Nuclear Power Plants Standards  
7 Committee of ANS, is expected to be approved for final  
8 publication momentarily. And it is expected that this final  
9 publication would take place around the first of the year.

10           With regard to the ANS -- excuse me. With regard  
11 to the ACRS comments, there were roughly seven in number.  
12 If you like, I would go over those individually and give you  
13 roughly what our response was to them. I will assume that  
14 you would like to hear about that. I will keep my remarks  
15 brief, though.

16           The first comment had to do with the scope of the  
17 guide and reducing it. We have in fact reduced the scope of  
18 the guide to concentrate on the needs of the control room  
19 operator.

20           The second comment had to do with checking with  
21 the NRC Action Plan. We have done that. There were nine  
22 variables explicitly culled out in the NRC Action Plan  
23 having to do with TMI and those are included in the guide.

24           The Committee requested that additional clarity  
25 and guidance be given to avoid confusion in footnotes and

1 cross-references. And we have in fact, as the Chairman of  
2 the Subcommittee noted, done considerable work in that  
3 area. We have in fact deleted one of the tables. We have  
4 removed a number of cross-references, and tried to make the  
5 relationship between ANS 4.5 and the guide much clearer.

6           The Committee referenced NUREG report CR-1440 and  
7 urged that a study be completed to assure important  
8 variables that needed to be measured are not overlooked, and  
9 we had in fact previously looked at the recommendations in  
10 this report and we did make some changes in the guide as a  
11 result. This was reported to you at the last full Committee  
12 meeting on this subject.

13           Another comment recommended --

14           MR. OKRENT: Excuse me. Were you therefore  
15 suggesting to us that you completed that part of the matter?

16           MR. WENZINGER: As far as reviewing that issue of  
17 that report, yes, that is correct.

18           The next comment was careful consideration of the  
19 need for BWR core exit thermocouples be made. We have an  
20 individual here from the NRC staff who can address that, and  
21 he will as a separate matter following my presentation.

22           The next comment was, the Committee believed that  
23 additional efforts should be made to resolve major  
24 differences between the NRC staff and industrial  
25 representatives. We have in fact done that. The Committee

1 believes that the guide should be ready for publication by  
2 the end of the calendar year, or else this matter should be  
3 identified as an unresolved safety issue.

4           We believe that it should be issued by the end of  
5 this year and would like for it very much not to become an  
6 unresolved safety issue. With your assistance, we will  
7 accomplish that.

8           (Laughter.)

9           - MR. OKRENT: Could I come back to the question  
10 that we were just talking about? In fact, I very much don't  
11 want that to keep you from getting this out this year. But  
12 I guess I am less than convinced at the moment that I know  
13 that the look at other accident scenarios has been  
14 sufficient to know that we may not be missing some important  
15 information that is not all that hard to get if you have  
16 thought about it beforehand.

17           So it seems to me you are sort of dismissing our  
18 comment on the basis that you have looked at it already  
19 before and told us about it, and in fact why did we even  
20 bother putting the comment in the letter. And in fact, I  
21 thought we had heard that you had looked at it, but it was  
22 not clear at the September meeting how you knew it was not  
23 useful to try to pursue some of the things that were  
24 recommended in the report and were not in the guide.

25           And also, this was illustrative. I did not think

1 that report was intended to be the be-all and end-all. I am  
2 trying to ascertain whether there is some intent. if not  
3 this year in connection with this version, which you might  
4 in fact get out this year -- whether there is some intent  
5 within the group responsible for this to see whether there  
6 are other potentially important plant status parameters or  
7 whatever.

8 MR. WENZINGER: Dr. Okrent, yes, there may well  
9 be. This report was only an interim report. The work is  
10 still continuing, and it is my understanding -- and the rest  
11 of the staff can correct me if I am wrong -- but I believe  
12 the actual work on CR-1440 will not be completed until early  
13 next calendar year.

14 We will in fact be sensitive to the work that  
15 comes out of that, and if there are additional  
16 recommendations that have not been included in the Reg Guide  
17 they will certainly be considered for inclusion in the next  
18 revision. I do not expect that this will be the last  
19 revision of Reg Guide 1.97.

20 MR. OKRENT: Okay, thank you.

21 MR. WENZINGER: I think Mr. Hintze feels like it  
22 is his life's work.

23 (Laughter.)

24 Let me also mention that we have in fact gotten  
25 comments from the ANS and from the AIS, and certainly have

1 ANS people speak for themselves, but our reading of what  
2 they said was I think summarized by the following: that  
3 they felt we made considerable progress -- and I agree --  
4 and that the number of differences are fairly small -- and I  
5 agree with that also.

6           They have also commented on the ranges of a few  
7 variables. We have, I think, come to a reasonable agreement  
8 on some of those. Some we have agreed to disagree. On Type  
9 C, design and qualification category, I think we have a  
10 basic disagreement there. We believe that the Type C  
11 variables that monitor the status of the various boundaries  
12 to the release of fission products should in fact for the  
13 key variables be made to be redundant. The ANS I believe  
14 disagrees with that. I will let them speak for themselves  
15 on that.

16           The ANS at the moment does not include the  
17 potential for breach of the fuel barrier, or for the  
18 potential for the breach of the principal primary pressure  
19 boundary.

20           BWR in-core thermocouples there was some dispute  
21 on. And again, we will speak on that later. There are  
22 scope differences between 1.97 and 4.5. And in fact, if you  
23 talk merely about the numbers of differences, this is where  
24 the greatest number of them lie. The ANS does not include  
25 the Type D and E variables, and we in fact do. The ANS does



1 not include backup or verification variables, and we do.  
2 And the greatest number, again, lies in those.

3           ANS in fact did point out one or two omissions  
4 that we had in the guide, and we have picked up those  
5 omissions.

6           With regard to the AIF listing, as far as the  
7 numbers are concerned, if you just look at the bottom line  
8 numbers it looks pretty good. In fact, in the case of the  
9 boiling water reactors, Reg Guide 1.97 has roughly 54  
10 variables, and AIF had 55. That was 13 in the B and C  
11 categories, 24 D's, 6 E's.

12           It is not quite that good, though, as far as  
13 agreement is concerned. There are 45 of those variables,  
14 however, that are common among the AIF and the staff list.

15           In the case of the PWR the numbers are 56 and 56  
16 for 1.97 and AIF respectively, and 47 of those variables are  
17 common.

18           Mr. Chairman, those are the extent of my prepared  
19 remarks. If you would like to ask questions, I would be  
20 glad to answer them if I can. I think the most useful way  
21 to do this would be to take the specifics that were brought  
22 up by Dr. Seiss.

23           MR. SIESS: Yes. I had thought we might hear from  
24 Mr. Wyatt just to get the perspective. But if there is no  
25 objection, Mr. Chairman, Walt Butler would like to get out

1 of here. He has a very narrow range of expertise in this  
2 particular case. So I would like to suggest that we take up  
3 that measurement.

4 Now, there have been -- go on up to the lectern,  
5 Walt.

6 Let me call the Committee's attention to the issue  
7 on page 23 on Table 1 for the BWR's and on page 40 in Table  
8 2 are the measurements we are talking about, and they have  
9 been changed since the Subcommittee looked at them. The  
10 questions may have gone away, but I think if Walt could give  
11 us a little explanation it just might settle it.

12 MR. BUTLER: I hope to limit this to no more than  
13 five minutes, to go through the rationale a little bit. The  
14 monitors for hydrogen and oxygen concentration inside  
15 containment was considered from the perspective of this  
16 background.

17 (Slide.)

18 There always was a requirement for hydrogen  
19 monitors by 10 CFR 50.44, combustible gas control, which  
20 requires that hydrogen concentrations be limited to less  
21 than 4 percent in a non-inerted containment. If the  
22 hydrogen concentrations go above that number, other measures  
23 are needed such as inerting. And if you inert, we define  
24 inerting as oxygen concentration being below 4 to 5 percent,  
25 and that number is in the technical specifications.

1           We now come to the availability of the TMI Action  
2 Plan, where in item II.B.7 of the Action Plan it requires  
3 that certain analyses be done. Those were done in a  
4 preliminary way and recorded in SECY-80-107, which the  
5 Committee has already heard.

6           And let me just flash this one up.

7           (Slide.)

8           80-107 is the report that contains this curve, and  
9 I will get back to that one later.

10          (Slide.)

11          Item II.B.8 of the Action Plan calls for  
12 rulemaking proceedings on degraded and melted cores. When  
13 that rulemaking proceeding is completed, we expect to have  
14 acceptance criteria for licensing purposes, and it should  
15 cover the instrumentation requirements associated with  
16 hydrogen and oxygen concentrations.

17          And finally, another item in the Action Plan is  
18 Item II.F.1.6, which requires hydrogen monitors, but not in  
19 the final draft -- it does not in the final draft specify  
20 range or accuracy or time response. While working on Item  
21 II.F.1.6 with the industry, we had some feedback and we  
22 learned that hydrogen monitors are not readily available if  
23 you want to measure them above 10 percent concentration.  
24 They have to work at it.

25          One technique would be to use the dilution

1 technique. In general, the active elements of these  
2 instruments have to be located outside containment, and you  
3 have to use pipelines, maybe 1,000 feet of pipeline, to draw  
4 the suction from the correct locations. Accuracy is  
5 degraded when you increase the range. If you go from 10  
6 percent range to 30 percent range, you lose some amount of  
7 accuracy.

8           And I guess when we specified the range in this  
9 Regulatory Guide, we took into account in a judgmental way  
10 the disadvantage of having a very broad range of hydrogen  
11 concentration.

12           And finally, we understand the response time for  
13 these monitors to be fairly slow. Nevertheless, we believe  
14 they are fast enough for the kinds of operator action that  
15 we have in mind that would result from this information.

16           MR. SIESS: Are these instruments basically a  
17 thermocouple and a heating wire or what?

18           MR. BUTLER: There is a variety of them. That is  
19 one where you have combustion or recombination of hydrogen  
20 on the surface, and then you measure the temperature of  
21 that.

22           MR. SHEWMON: I was thinking simply of  
23 conductivity meter like an old Pirani gauge in a vacuum.

24           MR. BUTLER: That is another one, where you put  
25 the hydrogen in solution and you vary the conductivity of

1 that solution. The other is a catalytic device where you  
2 recombine it on the surface and the surface heats up and you  
3 measure that increase, and it is callibrated for hydrogen  
4 concentration.

5 MR. SHEWMON: Thank you.

6 (Slide.)

7 MR. BUTLER: Regulatory Guide 1.97 provisions we  
8 feel are reasonable compromises, considering the present  
9 state of the staff's requirements relative to degraded core,  
10 is summarized in this table. They are essentially the same  
11 in your latest version, but in a different form. I think it  
12 is more readily understandable in this form.

13 For containment type PWR, large dry containment,  
14 we would recommend a range of zero to 10 percent. For the  
15 ice condenser containment, which is about one-half the size  
16 of large dries, we would recommend a range of zero to 30  
17 percent, recognizing that hydrogen mitigation systems are  
18 required for the ice condenser. Generally, we would hope  
19 you would burn the hydrogen before the concentrations get  
20 much above 10 percent, but locally you might have some  
21 higher concentrations, and we think that that range would be  
22 enough to pick up locally high concentrations.

23 For Mark I and Mark II BWR's, they will all soon  
24 be required to be inerted. They are essentially all inerted  
25 now, and in that event, since they are small containments,

1 we would propose a range of zero to 30 percent for  
2 hydrogen. Now, that will not cover all the hydrogen you can  
3 get out if you have a substantial amount of metal-water  
4 reaction. But we think if you measure more than 30 percent,  
5 you know generally you are in a pretty sorry state of  
6 affairs.

7           And with respect to the inerted containments, it  
8 would be sufficient to monitor the oxygen content, making  
9 sure that you continue to stay in the inerted mode by use of  
10 the recombiners, et cetera. And for that reason, we show on  
11 the right side there the <sup>0</sup> range of zero to 10 percent.

12           And finally, for the BWR Mark III, which at this  
13 time is not required to be inerted, we would propose zero to  
14 30 percent, primarily because its containment size is about  
15 1.5 million cubic feet. It is relatively small. At this  
16 time we don't require an oxygen meter. On the other hand,  
17 if at a later time they decide to inert the Mark III's -- we  
18 don't think it is likely, but if they did -- then we would  
19 have an <sup>0</sup> monitor as well.

20           <sup>2</sup>MR. OKRENT: Before you take that one off on the  
21 BWR Mark I, as an example, if you had 100 percent of the  
22 cladding reacting, about what would you expect the percent  
23 to be?

24           MR. BUTLER: It will appear on here. If you had  
25 100 percent -- this is the Mark I-Mark II curve -- you would

1 have about 70 percent concentration of hydrogen.

2 (Slide.)

3 MR. OKRENT: All right. Now, suppose you are  
4 sitting there as shift technical advisor or at the incident  
5 center or back at whatever is the operational command post  
6 for the utility and you have an inerted BWR containment and  
7 it reaches 30 percent and goes off-scale. Do you think that  
8 you would not be interested in knowing, has it gone to 60  
9 percent, assuming it might, or in principle it might even  
10 exceed 70 percent under other circumstances, other things  
11 interacting?

12 Don't you think that this could be a relevant  
13 parameter?

14 MR. BUTLER: It probably is. There would probably  
15 is -- there would be an interim in determining exactly what  
16 the hydrogen concentration is, and we believe for that  
17 occasion you can rely on the grab sample. It takes longer.

18 MR. OKRENT: How long is "longer"?

19 MR. BUTLER: I suspect on the order of hours.

20 MR. OKRENT: You think you would be content,  
21 sitting there at the incident center, to wait a couple of  
22 hours, say, please take a grab sample? Tell your inspector,  
23 please ask them if they can take a grab sample. He says:  
24 Okay, I will call you back in three hours with the result.

25 Do you think that would be fine? Would it?

1           MR. BUTLER: I think that there are many other  
2 instruments that they could rely on for understanding the  
3 general status of the core. I think that that the  
4 background information that I provided here indicated that  
5 there was a general limitation on the availability of  
6 instruments, and you make a prescription at this time that  
7 was real broad, we think would be nonconstructive.

8           MR. OKRENT: What is another one that will tell me  
9 that 90 percent of the cladding has interacted?

10          MR. BUTLER: Well, I guess you would have process  
11 instruments on the reactor. It depends primarily on the  
12 particular scenario you come up with. If you are working  
13 with a small break and you still have the primary system  
14 pretty much intact, you would have your pressure, your  
15 temperature instruments providing some information.

16          MR. OKRENT: I must say, at the moment I have a  
17 little bit of trouble going from some kind of gas or steam  
18 pressure and temperature in the primary system measurement  
19 and translating that to the amount of cladding which has  
20 undergone metal-water reaction. If you can tell me how I  
21 would be interested.

22          In fact, I can envisage a situation where those  
23 things stay almost constant while the amount of cladding  
24 interaction has been changing drastically. Can't you?

25          MR. SHEWMON: Dave, you feel that what the



1 operator would do under these conditions would be  
2 considerably different if there was 40 or 80 percent  
3 hydrogen? Is that right?

4           MR. OKRENT: I think it affects a variety of  
5 things. I think first, at the moment to me the most direct  
6 measurement I can think of of the state of the fuel in the  
7 degraded situation, because it is harder to go from a  
8 radiation measurement. It would be nice if you could do it  
9 from a radiation -- you would have to take isotope to  
10 isotope and take it apart and know how much has gone out. I  
11 think that is much harder.

12           So to me this is the best handle you have on the  
13 state of degradation. It is imperfect, but by far the  
14 best. And if something came, you know, that you did not  
15 have ready, that you were ready to use, you would have a  
16 better feeling for what it was you were putting the water on  
17 or whatever.

18           And it also might affect the possible other  
19 actions that were available. So I myself would like very  
20 much to know what the hydrogen concentration is in the  
21 containment. And again, I do not want a very high accuracy,  
22 but if you can do it by dilution technique and tell that it  
23 is at 70 percent, I would give that away --

24           MR. PLESSET: I think other people want to make a  
25 comment.

1 MR. SIESS: Dave's question brings out, I think --

2 MR. PLESSET: Let's get Kerr's comment.

3 MR. SIESS: This relates specifically to that  
4 question.

5 MR KERR: So does mine, I think.

6 MR. SIESS: I wanted to explain something about  
7 the way the Committee might think about the question before  
8 we go on any further.



9 MR KERR: You are going to explain how the  
10 Committee might think. Okay.

11 (Laughter.)


12 MR. SIESS: I might suggest something to you,  
13 because it is going to come up again. I think the way this  
14 thing is put together has certain deficiencies. If you look  
15 on Table 1, you will find that the hydrogen measurement  
16 comes under the heading of containment. And Walt's  
17 presentation is thinking about it under the heading of  
18 containment. And Dave is thinking about it under the  
19 heading of fuel cladding, and it does not appear there.

20 The thinking of the staff in putting this together  
21 was not looking at hydrogen concentrations as a measure of  
22 the state of the fuel cladding. I don't know how many  
23 places there are like that, but I think it is important.



24 MR. OKRENT: If you went through the various  
25 accident scenarios, some of which are done in that report





**IMAGE EVALUATION  
TEST TARGET (MT-3)**




**MICROCOPY RESOLUTION TEST CHART**







**IMAGE EVALUATION  
TEST TARGET (MT-3)**



**MICROCOPY RESOLUTION TEST CHART**



1 that was referenced and which we recommended a couple of  
2 years ago that they do -- the general study, I think, was  
3 actually a recommendation that Lewis proposed, that they  
4 look at recommendations, see what might be interesting to do  
5 and so forth.

6 Then I think you arrived at some additional  
7 parameters that are relevant. And I am trying to give an  
8 example, and I think it is a real one, where in fact it  
9 would be of some real interest to know that you were beyond  
10 70 percent.

11 MR. PLESSET: Do you want to make your comment  
12 now, Bill, unless Siess has told you what you are thinking?

13 MR. SIESS: I did not want to tell Bill what he is  
14 thinking. I wanted to point this out to the Committee.

15 MR. PLESSET: You will get a turn too, I promise.

16 MR. LAWROSKI: The question that Dave is raising

17 --

18 MR. PLESSET: Let Bill make his comment, please.  
19 He has had enough trouble with the other members.

20 MR. KERR: Mr. Butler, I don't know whether you are  
21 in the part of hydrogen that ignites hydrogen or in the part  
22 that does not ignite hydrogen. But it strikes me that if  
23 Professor Okrent is going to use this as an indication of  
24 clad condition, we might rethink our hydrogen igniters,  
25 because I believe that if we use these we probably make this

1 indication of clad damage much less accurate than would  
2 otherwise be the case.

3 MR. OKRENT: Not in the inerted BWR.

4 MR KERR: There is discussion -- and I believe Mr.  
5 Gilinsky has suggested -- that igniters be installed in BWR  
6 containments and ice condensers, and perhaps even in large  
7 containments, what are probably Mark III's. I think there  
8 was another instrument there that would be helpful. The  
9 containment has pressure instruments and temperature  
10 instruments, and if you have a lot of hydrogen,  
11 noncondensable, you are going to have drywell and wetwell  
12 pressures that are very high, like about 100 psi gauge.

13 The operator, when he gets a temperature  
14 measurement, will have to know that there was a substantial  
15 amount of noncondensibles. And with some analysis he can  
16 then estimate how much hydrogen was pumped into that  
17 containment.

18 MR. PLESSET: Dade, did you want to make a  
19 comment? Then Steve.

20 MR. MOELLER: Something along the lines of what  
21 Dr. Okrent was asking about the hydrogen monitors. I have a  
22 similar question on the oxygen monitor. Now, if it is  
23 inerted, the oxygen concentration is probably somewhere  
24 between zero and 10 percent. If it is not inerted or you  
25 have lost your inerting, the oxygen concentration would be

1 20 percent.

2           And I might want to know how far or how much of my  
3 inerting I have lost. So I did not understand there why you  
4 did not have zero to 20 percent for the oxygen range.

5           MR. BUTLER: Well, we believed if you have  
6 containment integrity, as you should whenever you are in  
7 operating modes, in inerted containments the oxygen  
8 concentration should be below 5 percent.

9           MR. MOELLER: Let's say I wanted to know when it  
10 is safe for my workers to enter. I want it up near 20  
11 percent.

12           MR. PLESSET: That is not --

13           MR. MOELLER: Get a separate instrument for that.

14           MR. BUTLER: They would have their own  
15 instruments. In fact, they do have oxygen monitors,  
16 non-safety-grade, that go up to that range.

17           MR. MOELLER: All right. Thank you.

18           MR. OKRENT: But it is not too hard to envisage a  
19 scenario where the oxygen has moved above 5 percent.

20           MR. SIESS: Please keep in mind that this Reg  
21 Guide addresses specific, special, qualified  
22 instrumentation.

23           MR. PLESSET: Steve?

24           MR. LAWROSKI: About Dave's concern about how to  
25 get hydrogen concentration measured, I don't know why --

1 whether or not you could modify the synthesis gas analyzers,  
2 which are 75 percent hydrogen, 25 percent nitrogen, for  
3 synthesis of ammonia. People must be measuring  
4 concentrations in those plants. Has anyone -- there is a  
5 lot of it made.

6 MR. BENDER: I still think we have to think about  
7 the fact that the operator has a limited amount of  
8 information to absorb, and trying to put every kind of  
9 instrumentation on it that we can think of, just because it  
10 would be nice information to have, is not going to be very  
11 helpful.

12 MR. OKRENT: If you are willing to say "very nice  
13 information" under those circumstances. I don't think it is  
14 nice.

15 MR. BENDER: It makes very little difference to me  
16 whether I know it is 30 percent or 90 percent. I know there  
17 is a lot of clad damage and the difference in the actions I  
18 can take is somewhere near to zero in the short-term. In  
19 the long-term I might want to know something different. But  
20 under the circumstances there are lots of other things I  
21 have to worry about as well, and why should I concentrate on  
22 this one parameter?

23 MR. SHEWMON: On that scale, three hours for a  
24 grab sample might not be unreasonable.

25 MR. BENDER: Right.



1 MR. PLESSET: Any other questions?

2 MR. BENDER: Two sample lines would be a help. I  
3 would like to think about those things.

4 MR. PLESSET: Any other questions for Mr. Butler?

5 MR. SIESS: Walt, on that last figure, just one  
6 quick question. When Dave asked you what percentage of the  
7 clad would be oxidized, you referred to that. Is that clad  
8 percentage on that figure or is it total metal-water?

9 MR. BUTLER: It is metal-water percent of the  
10 active element of the clad, the clad which contacts the fuel.

11 MR. SIESS: There is other zirc in the core, is  
12 there not?

13 MR. BUTLER: Yes. It is not considered here.

14 MR. MARK: 90,000 pounds.

15 MR. BUTLER: In a BWR it is around 90,000 pounds.

16 MR. MARK: That is not all cladding.

17 MR. BUTLER: Yes, it is.

18 MR. SIESS: The interim rule says 75 percent of  
19 the clad, not 75 percent of the zirc.

20 MR. BUTLER: That is correct.

21 MR. SIESS: I was trying to --

22 MR. SHEWMON: Are the can walls zirc, for example?

23 MR. BUTLER: Yes, and they are not included in  
24 these numbers. There is a lot more zircaloy in the core, in  
25 the plenum chamber, as well, that are all excluded from

1 these analysis.

2 MR. PLESSET: This is percent of clad on this  
3 abscissa here?

4 MR. BUTLER: Yes.

5 MR KERR: Have you or do you plan to make any  
6 estimate of the probability of reaching these various  
7 percentages? I mean, for example, are you going to estimate  
8 the probability of reaching 10 percent compared with 70  
9 percent clad reaction, metal-water reaction?

10 MR. BUTLER: Our view at this time is that is  
11 something that cannot really be responsively calculated,  
12 because we are talking about terminated accidents,  
13 terminated meltdowns, where you depend on operator actions,  
14 and the timing is very important as to when you are able to  
15 arrest the accident.

16 So one cannot really come up with a believable set  
17 of numbers on probabilities.

18 You have the original composition of the air in  
19 the containment.

20 MR. SHEWMON: If it went straight up, it would be  
21 150 percent -- the concentration would be 150 percent.

22 MR. MOELLER: But the bottom curve for PWR dry is  
23 roughly a straight line.

24 MR. SHEWMON: Yes. But I think basically, as you  
25 get above 50 percent, then the other component which is in

1 there starts influencing the change in percent per increment  
2 of hydrogen.

3 MR KERR: Or vice versa.

4 MR. MOELLER: Okay, thank you.

5 MR. PLESSET: Thank you, Mr. Butler.

6 Could we go on with the staff?

7 MR. SIESS: I think we ought to hear from Mr.  
8 Wyatt.

9 MR. WYATT: My name is Ed Wyatt. I am the  
10 coordinator of fuel cycle licensing with NUS Corporation,  
11 Rockville, Maryland. I am also the chairman of the ANS 4.5  
12 Standards Management Committee. One of the writing groups  
13 under that Standards Management Committee is the ANS 4.5  
14 Writing Group, which has developed the ANS 4.5 standard.

15 The standard is, as Mr. Wenzinger said just now,  
16 ready to go to the American National Standards Institute for  
17 approval. There is some very fine points that have to be  
18 cleared up. But I understand in talking to the chairman of  
19 the Nuclear Power Plants Standards Committee today that he  
20 hopes to finish that up today and send it forward.

21 As stated earlier, the ANS 4.5 Writing Group has  
22 worked with the NRC for the purpose of reducing the number  
23 of differences since the August 7 ACRS meeting. The  
24 differences that remain based on the October 8 version of  
25 Reg Guide 1.97 have been sent to the chairman in a letter

1 from the chairman of the Nuclear Power Plant Standards  
2 Committee.

3 I have gone over the charts in that letter and  
4 modified them based on the standard which -- based on the  
5 Reg Guide, excuse me, that was given out Wednesday. There  
6 are now, instead of the 26 mentioned in the letter, only the  
7 23 variable differences: 6 under the Type E variables, 17  
8 under Type C variables.

9 As indicated earlier, they can be quantified as  
10 differences in range, differences in the type of philosophy  
11 in categorizing, and differences in content. Many of the  
12 variables in the Reg Guide do not appear as indicated in the  
13 standard. For Type B variables there is only one difference  
14 in range. For Type E there are three Reg Guide variables  
15 that are not in the ANS standard. There are two Type E  
16 variables in the Reg Guide that are, at least for one type  
17 of reactor, that are not in the ANS 4.5. Type C variables,  
18 there are seven which represent a difference in philosophy  
19 on categorizing.

20 As mentioned, the ANS standard does not call for  
21 single-failure for Type C variables. Three of them are  
22 differences in range, including one that is listed in the  
23 philosophy on categorizing standards. Nine are variables  
24 required by the Reg Guide but not required by ANS 4.5. One  
25 of these includes a category, philosophy of difference for a

1 PWR and one that is not required for a BWR.

2 That summarizes it. Let me quickly run through  
3 the differences as modified by the draft of November 6th.

4 (Slide.)

5 In the Type B variables, under neutron flux, the  
6 Reg Guide range, it is now up to 100 percent. It was  
7 greater than 5 percent in the earlier version. ANS 4.5  
8 upper limit is .1 percent. This represents a definite  
9 difference in philosophy.

10 The 4.5 writing group believes that to accomplish  
11 and maintain the critical safety functions, in this case  
12 reactivity, that the .1 percent is all that is needed.

13 MR. OKRENT: Is there elsewhere a requirement on  
14 neutron flux in ANS 4.5 draft? Is there some other place  
15 where you have a requirement for measurement under neutron  
16 flux?

17 MR. WYATT: No, sir.

18 MR. OKRENT: So in your opinion .1 percent power  
19 is adequate knowledge and you don't see, for example, a  
20 basis for going above 100 percent? For example, we talked  
21 earlier about 150 percent.

22 MR. WYATT: Right. The purpose in the standard,  
23 as indicated by the definition of Type B parameters, is to  
24 accomplish and maintain the critical safety functions.

25 MR. OKRENT: No. I know that that is the

1 purpose. But I am asking in terms of instrumentation to  
2 follow the course of an accident, and I do not want to  
3 constrain the discussion to a subset of the problem. So if  
4 ANS 4.5 thinks they are only addressing part of the problem  
5 and the rest of the problem should be addressed elsewhere,  
6 then I will not ask the question.

7           But if you think you've addressed the entire  
8 problem of instrumentation to follow the course of an  
9 accident, then my question is relevant. Which is it you  
10 have done?

11           MR. WYATT: The philosophy is to --  
12 instrumentation for only the control room operator. There  
13 are other standards being developed. For instance, I have a  
14 Writing Group 4.6 which is looking at monitoring  
15 instrumentation. Their first task is to develop a standard  
16 for the purpose of giving criteria for instrumentation to  
17 rebuilt an event that happened, in other words to recreate  
18 -- reconstruct the accident.

19           This will probably, although I have not seen the  
20 draft yet, this will probably have in it wide-range  
21 instrumentation, things of this nature.

22           MR. OKRENT: So you think this information might  
23 be of interest in reconstructing it for Kemeny Two, but it  
24 would not be useful during the course of the event; is that  
25 it?

1 MR. WYATT: The Writing Group feels this is the  
2 proper instrumentation for the purpose of the event.

3 MR. KERR: Is there any way you could briefly  
4 reconstruct the logic that led to .1 percent as a cutoff?

5 MR. WYATT: I could not do it myself. We do have  
6 in the room here one of the fellows from the Writing Group.  
7 I am not sure. Dave, can you speak to this point?

8 This is Dave Summers from Consumer Power.

9 MR. SUMMERS: Dr. Kerr, the answer is not going to  
10 be quite palatable. It was kind of a negotiated settlement  
11 with the staff at the time. We later, in Denver, came up  
12 with a different number, which is the 5 percent which has  
13 been changed subsequently. But that is the development.

14 MR. KERR: Thank you.

15 MR. SIESS: I thought your criterion was shutdown  
16 amount; am I right?

17 MR. SUMMERS: Correct.

18 MR. WYATT: That is right, that is correct. In  
19 other words, to know that you are in a safe condition, to  
20 know that the reactor is in a safe condition.

21 MR. SIESS: And if it is shut down, it is by  
22 definition less than one-tenth of one percent is safe, and  
23 greater than one-tenth of one percent is not safe.

24 MR. WYATT: That is correct. Action has to be  
25 taken. You have to go look at something else to make sure

1 -- to look after the safe condition.

2 MR. SHEWMON: If it is greater than the .1 percent  
3 there are other ways to determine what the power generation  
4 of the core is?

5 MR. WYATT: Yes. One could look and see if the  
6 rods are in place, yes.

7 The second item has to do with control of position  
8 and soluble boron concentration sample. As it is now  
9 listed, the Reg Guide specifies these variables. ANS 4.5  
10 does not require them because they are verification  
11 variables which are not included in 4.5.

12 Cold leg temperature is specified in the Reg Guide  
13 as category three quality. ANS 4.5 does not require this  
14 variable, again because of the same reason.

15 Coolant level of the reactor, in the October 6  
16 version of the Reg Guide that was still an open issue. I  
17 assume that is no longer true, looking at the November 6th  
18 version of the Reg Guide. Again, ANS does not specify a  
19 range.

20 PWR level sensing is a relevant item with the NSSS  
21 vendors. ANS 4.5 does not require this measurement. The  
22 Writing Group also believes that the quality category one  
23 appears to be inconsistent for the verification purpose. As  
24 I mentioned before, we do not believe that a high quality is  
25 needed for many of these instruments.



1 (Slide.)

2 Continuing with the Type P variables, BWR core  
3 thermocouples are not required by the standard, but are  
4 required by the Reg Guide. PWR core exit temperature, the  
5 Reg Guide states this is a verification purpose, whereas the  
6 standard presents this as one of the two options for a key  
7 variable.

8 Degree of subcooling, the Reg Guide states this is  
9 a verification. The standard does not require this.

10 You notice the next three are deleted because the  
11 Reg Guide and the standard are now in agreement on these  
12 three issues.

13 MR. OKRENT: Can I ask you the same question I  
14 asked the member of the staff: Is there any scenario you  
15 can envisage in which the pressure in the PWR went above  
16 3,000, went off scale for some period of time, and came back  
17 on, where you think it could be relevant to know just what  
18 the pressure did? And I do not mean to reconstruct it some  
19 weeks later.

20 MR. WYATT: There may well be, such as high  
21 pressure events, modeling up of the reactor where you are  
22 generating energy still. Again, the purpose here is  
23 accomplishing and maintaining the shutdown situation, and  
24 that is why the pressure ranges were chosen in the standard.

25 MR. KERR: Excuse me, but I am puzzled by the last

1 statement, because I did not realize that you would want to  
2 go up to 1500 psig in a shutdown situation.

3 MR. WYATT: Oh, no, we wouldn't. This is an  
4 indicator and it is just a wide enough range of indicators  
5 so that you can accomplish the problem. You know where you  
6 are and you can accomplish the problem -- accomplish the  
7 shutdown.

8 (Slide.)

9 Turning now to the Type C variables --

10 MR. OKRENT: At the Sequoyah simulator, if I am  
11 not incorrect, if you run the ATWS transient, what happens  
12 is it goes up to 3,000 and goes off scale on the simulator.  
13 And the operator just sees it goes off scale, or I guess he  
14 doesn't know quite what. I guess he doesn't know what the  
15 calculations predict, 2980 or whatever they predict. It  
16 must leave him wondering, I imagine, if they run that in  
17 training.

18 MR. SIESS: Did they?

19 MR. OKRENT: They did for my class. I don't know  
20 what they routinely do.

21 MR. WYATT: Certainly if something like that  
22 happened in a reactor situation and it ran off scale, the  
23 operator would know he has to take some action pretty quick.

24 MR. SIESS: Would the action be any different if  
25 it was 3,000 psi than if it were 1500? Has anybody worked

1 that out?

2 MR. WYATT: No, I do not think so, in that  
3 I fail. 3,000 would be, say talking about a PWR, which is  
4 normally at about 2,000 or 2250 --

5 MR. SIESS: I was talking about a BWR.

6 MR. WYATT: Oh, a BWR.

7 MR. SIESS: Because the limit is now 1500 on the  
8 BWR.

9 MR. WYATT: Yes, it is. And if he saw it heading  
10 up toward 1500, he would know he would have to take some  
11 action, and so I really don't think range makes much  
12 difference. It is an indicator to tell the operator to take  
13 action to get it back into the safe mode.

14 MR. SIESS: Do you think he gets a stronger  
15 indication by going off scale on a gauge that reads to 1500  
16 than he would simply going to 1500 on a gauge that read to  
17 3,000?

18 MR. WYATT: I would guess that if I were an  
19 operator, either one would push me into immediate action.

20 Again turning to the Type C variables,  
21 radioactivity concentration, radiation level in the  
22 circulating primary coolant system, the A.S 4.5 requires  
23 only a single measurement rather than category one as  
24 required by the Reg Guide, because again of the philosophy  
25 that the Writing Group has that Type C instruments should

1 meet category two only, not category one, because they are  
2 only extended range barrier monitoring instruments. That is  
3 the philosophy and that will appear throughout here.

4 Accent sampling of the primary coolant. The  
5 standard provides no range, whereas the range in the Reg  
6 Guide is specified to be one of two values. The Writing  
7 Group believes that it should be the lower of these two.

8 BWR core thermocouples. The Reg Guide states  
9 requirements now. It did not previously. The standard does  
10 not require the measurement, because the standard differs in  
11 scope from the Reg Guide in that it requires detection of  
12 actual fuel clad breach, but not the measurement of a  
13 potential breach.

14 PWR core exit temperature. Again, it is specified  
15 in the Reg Guide but not in the standard; the same reason.

16 BWR reactor coolant system temperature. The Reg  
17 Guide specifies quality category one and the standard does  
18 not require the variable. Again, the standard requires the  
19 detection of an actual breach, not a potential breach. Reg  
20 Guide 1.97 specifies category one for PWR reactor coolant --

21 MR KERR: Can you tell me why you think it is not  
22 important to measure a potential breach?

23 MR. WYATT: The Type C parameters in the standard  
24 are looking only at a potential containment breach.  
25 Generally speaking, potential breaches in clad and the core

1 -- the coolant system -- are normally covered by the Type A  
2 parameters, because that Type A parameter is for the most  
3 part based on chapter 15-type accident analysis.

4 MR. KERR: So the reason is that there are other  
5 ways of measuring the potential breach and you just don't  
6 want to do it with Type C variables?

7 MR. WYATT: That is right.

8 MR. SIESS: You said Type A, did you not?

9 MR. WYATT: Yes. The Type A variables are those  
10 that are from preplanned events and require preplanned  
11 action.

12 MR. SIESS: Not requiring automatic action. That  
13 is the qualification.

14 MR. WYATT: Yes.

15 MR. SIESS: The definition in the Reg Guide is  
16 different from the one in the standard. It does not differ  
17 in that sense, though, right? It is the one --

18 MR. WYATT: No. The Type A and Type C definitions  
19 are different between the standard and the Reg Guide.

20 MR. SIESS: Because at the Subcommittee meeting we  
21 asked for examples of Type A parameters and I did not recall  
22 getting any that said, you know, these substitute -- these  
23 supplement another Type B or Type C.

24 MR. WYATT: Let me turn to Dave Summers for that.

25 MR. SUMMERS: With regard to potential breach, the

1 Writing Group had the philosophy that the last barrier is  
2 what we were intending to monitor. We did address the  
3 concept of measuring the other two barriers. But what it  
4 basically came down to is we felt, although functionally  
5 this may be desirable, we did not think we could come  
6 through. We could make a promise, but we did not think we  
7 could come through with monitoring the potential for a fuel  
8 clad breach.

9           There was quite a good deal of discussion whether  
10 the reactor coolant system potential for breach should be  
11 included. Again, it was just the final decision not to  
12 include that, but to look at the final barrier in terms of  
13 radiological consequences.

14           MR. SIESS: That is a different answer than Mr.  
15 Wyatt gave.

16           MR. WYATT: Okay. I am accepting Mr. Summers'  
17 answer.

18           MR. SIESS: Fine.

19           MR. WYATT: When I was talking about the Type A,  
20 basically it was under the idea that chapter 15 analyzes  
21 events for the purpose of determining whether there will be  
22 a breach on one of these two systems. And that was my  
23 reference to chapter 15.

24           I guess that pretty well takes care of this  
25 particular slide.

1 (Slide.)

2 The primary containment area radiation is  
3 specified in the Reg Guide but not in the standard, because  
4 the standard looks at only key variables.

5 Containment sump water level is specified as  
6 category one in the Reg Guide and is only a single  
7 measurement in the standard.

8 Suppression pool water level is not required by  
9 the Reg Guide -- not required by the standard, but is  
10 required by the Reg Guide.

11 BWR drywell pressure and PWR containment pressure  
12 are considered category one in the Reg Guide, whereas the  
13 standard requires only a single measurement channel.

14 Effluent radioactive activity, noble gas from  
15 condenser air removal system exhaust, is in the Reg Guide  
16 but not in the standard.

17 (Slide.)

18 Under Type C variables, again reactor coolant  
19 system pressure is category one in the Reg Guide and  
20 requires only a single measurement channel in the standard.  
21 That is also true of primary containment pressure. And as  
22 well as containment or drywell concentration also, the  
23 standard specifies a zero to 10 percent range in the  
24 hydrogen concentration, considering that to be adequate for  
25 the function.

1           The oxygen concentration is listed in the Reg  
2 Guide. The standard as originally written -- it will be  
3 deleting this as a key variable.

4           The Reg Guide lists effluent radioactivity, noble  
5 gases from identified release points. The standard does not  
6 require that particular variable.

7           (Slide.)

8           Environs radioactivity exposure rate is listed in  
9 the Reg Guide with particular ranges.

10          MR. SIESS: That range is 1 millirem to 10 rem.  
11 It got changed again.

12          MR. WYATT: Okay. Okay. At the time of the  
13 review, these were the ranges. It got changed by the  
14 November 6th draft.

15          The Writing Group still believes the five decade  
16 range should be adequate.

17          MR. SIESS: Actually, you are advocating a larger  
18 range, I think, than the staff now has.

19          MR. WYATT: That is --

20          MR. SIESS: You have 1 millirem to  $10^2$ . They  
21 have it  $10^4$ , the staff has  $10^4$ .

22          MR. MOELLER: One to 10,000.

23          MR. WYATT: We have it  $10^{-3}$  to  $10^2$ .

24          MR. MOELLER: One milli-r to 10,000 r.

25          MR. SIESS: When you say "they," would you please



1 indicate who you mean, Dade?

2 MR. MOELLER: The Reg Guide. The staff on page 23  
3 says 1 millirem to 10 r.

4 MR. SIESS: This is environs radioactivity  
5 exposure rate. What page are you on?

6 MR. MOELLER: 23.

7 MR. SIESS: One millirem to ten rem. And he has  
8 one milirem to 100 rem. Am I not right?

9 MR. WYATT: Yes.

10 MR. WENZINGER: That is one of the items we  
11 specially identified for separate discussion.

12 MR. SIESS: I am trying to see where we are now.  
13 This is the first instant, I think, they had a larger range  
14 than you had. I like to catch those.

15 (Laughter.)

16 MR. WYATT: Incidentally, there are some  
17 indications that it might be difficult to do this particular  
18 job. Some information has come to light and the Writing  
19 Group will be looking further at this particular parameter.

20 MR. SIESS: When you find yourself more  
21 conservative than the staff, you decide you had better take  
22 another look at it. Something is wrong.

23 (Laughter.)

24 MR. WYATT: That is not it.

25 The last two items are the fact that Type D and E

1 parameters are in the Reg Guide and not in the standard, as  
2 earlier discussed.

3           Basically, those are the differences. I would  
4 just like to conclude my remarks by saying that, as  
5 indicated earlier, the Reg Guide and the standard are much  
6 closer, and we feel much happier about that.

7           MR. SIESS: And actually, many of the differences  
8 could be grouped as a basic difference in philosophy or  
9 scope. So there are not that many individual differences.

10          MR. WYATT: That is correct.

11          MR. PLESSET: Can we go back to the staff now?

12          MR. SIESS: Unless there are questions of Mr.  
13 Wyatt.

14          MR. PLESSET: Any more questions of Mr. Wyatt?

15          (No response.)

16          I guess not. We can go back to the staff.

17          MR. SIESS: There are three items I thought we  
18 should take up, and one was the BWR in-core thermocouples,  
19 one was the environmental radiation exposure monitoring, and  
20 one I would like to see last, I think, is the other uses to  
21 be made of the instruments outside the control room.

22                 I propose the BWR thermocouples as being  
23 responsive to a specific request by the ACRS. I suggest we  
24 take that up next. I have already told you what is in the  
25 guide, and the staff, Mr. Johnson, is going to tell us how

1 they arrived at it.

2 MR. JOHNSTON: My name is William Johnson. I am  
3 chief of the Core Performance Branch in the Division of  
4 System Integration. I am going to try to answer some of the  
5 questions that arose yesterday.

6 As I understand it, the concern was whether a  
7 thermocouple placed in the instrument string would be able  
8 to sense a temperature rise that took place inside the  
9 channel box. And we have had numerous discussions with  
10 General Electric since your last meeting. There have been  
11 some reports that GE has passed on to us in which  
12 calculations were made. I am going to refer to several of  
13 these. I think they will provide a satisfactory answer to  
14 the question.

15 First I want to show that there are two vugraphs  
16 actually shown to you at the last meeting, and the point  
17 that I want to make is that the -- looking just at these  
18 curves here. This is the mid-plane temperature.

19 (Slide.)

20 This is fuel temperature at the mid-plane. The  
21 following is the temperature risk of a bypass thermocouple  
22 located also at the mid-plane. The delay is on the order of  
23 100 seconds. So that is the difference in delay between the  
24 thermocouple and the bypass sensing a temperature rise that  
25 is taking place in a fuel rod inside the channel box as GE

1 has calculated it using best estimate analysis.

2 MR. SHEWMON: Can you tell me again the difference  
3 between those two dashes, the straight line and the one that  
4 curves upwards?

5 MR. JOHNSTON: This is the fuel temperature, the  
6 dashed line. This is with the core spray on, so you don't  
7 get the cooling or quenching of that thermocouple that is  
8 sitting in there, and with the core spray the thermocouple  
9 does not heat up.

10 The question was, if you were boiling down, which  
11 means no core spray, what would be the difference or the  
12 delay, if you like the lag, in the sensing of temperature  
13 rise. And the same general calculation was shown in the  
14 slide which was also provided to you last time. Again, it  
15 shows the same order of magnitude of delay in time of  
16 sensing it.

17 I think that answers the first part of the  
18 question that was raised. In fact, under conditions of loss  
19 in coolant level, you can detect in a reasonable amount of  
20 time the temperature response that is going on inside the  
21 channel box.

22 (Slide.)

23 This is a point -- a one-level calculation. The  
24 discussions we have had with GE have resulted in the placing  
25 of the thermocouples at two elevations within the channel

1 box, so that you have the opportunity to see the temperature  
2 change.

3           This vugraph is a calculation that was made as a  
4 part of research programs with the channel -- with the  
5 channel module of the TRAC BWR version. And it has the  
6 capabilities of calculating the temperatures and a variety  
7 of things of that sort. This is not calculated -- what I am  
8 showing you here is not a calculation that was made for a  
9 BWR, but actually for severe core damage problem in the  
10 power burst facility.

11           But it does show there is analytical capability to  
12 calculate the temperature inside a shroud as a function of  
13 elevation at any particular time. This is one particular  
14 time cut, but it shows that we can distinguish the shroud  
15 wall temperatures. And I suggest that if you can -- if you  
16 know that the shroud wall is warming up -- as we have  
17 already indicated, if the shroud wall gets hot the  
18 thermocouple gets hot. The thermocouple inside the train  
19 can see that temperature.

20           MR. PLESSET: What is this telling us? Are there  
21 measurements involved here?

22           MR. JOHNSTON: These are calculations. I am  
23 merely saying, we have analytical capability to show --

24           MR. PLESSET: How do you know the analytical  
25 capability is any good? I mean, compared with what? I

1 mean, you can calculate numbers if you have a computing  
2 machine, I guess.

3 MR. JOHNSTON: My point was, I think we have  
4 sophisticated enough computing machinery that we can work  
5 this kind of a problem. That was all I meant to  
6 communicate.

7 MR. PLESSET: How do you know the answer is  
8 correct?

9 MR. JOHNSTON: The answer will be determined when  
10 the test is run, because there are thermocouples spread all  
11 through these portions of the test facility.

12 MR. PLESSET: Has the test been run?

13 MR. JOHNSTON: That test has not been run. The  
14 test was run in the NRU just this week, in which over 35  
15 runs were made in doing heat transfer studies. Those I  
16 think -- they may or may not have been reported to the ACRS  
17 yet, but similar calculations were made for that test using  
18 the same code and the same analytical capability that  
19 predicted temperatures -- the predicted temperatures fit  
20 very closely.

21 The other bottom line is that the other fuel  
22 quench is much more rapid --

23 MR. PLESSET: I think we ought to see that some  
24 time.

25 MR. JOHNSTON: That is not part of this

1 discussion.

2 MR. PLESSET: Oh.

3 MR. JOHNSTON: The other kind of calculations that  
4 can be made again will show the temperature as a function of  
5 time.

6 (Slide.)

7 Again, we can calculate fuel rods, we can  
8 calculate shroud temperatures as a function of time, and  
9 that is simply additional types of capability.

10 General Electric in September provided us with  
11 copies of what it called NEDO-247208, which is a response  
12 which is prepared as part of the Bulletins and Orders  
13 Section, which required that the various vendors make  
14 calculations of events that might occur in a reactor beyond  
15 chapter 15. And GE has supplied a whole series of  
16 calculation, and I have extracted certain portions of them.

17 I am not going to go through very many of them,  
18 but just to give you a summary of the kinds of cases that  
19 they calculated, they calculated systems in which there are  
20 breaks in both the liquid side and in the steam side of the  
21 BWR. They have done it with core spray and depressurization  
22 working. They have done it with one coolant injection pump  
23 working, with the depressurization working. They have done  
24 it with these things not working and so forth.

25 And what I want to show very quickly are a series

1 of vugraphs in which the water level as a function of time  
2 is calculated.

3 (Slide.)

4 And then I want to show you the response that they  
5 calculated of fuel during that same time period.

6 (Slide.)

7 And what you see is that the -- well, the water is  
8 still going down. You will notice number two is the water  
9 level measured outside the shroud, and number one is the  
10 water level calculated inside the shroud of a BWP. And this  
11 curve here is the cladding temperature rising.

12 And the point I wish to make is that the  
13 calculation was terminated at 2,000 F., but at the time they  
14 terminated their temperature calculation the water would be  
15 continuing to drop in the inside of the shroud. And one  
16 would expect the temperature would be continuing to rise.  
17 And the value of being able to make this kind of calculation  
18 or make the measurement that we propose to make I think is  
19 evident here.

20 MR. KERR: I am losing something here. You are  
21 showing me a relationship which is a calculated relationship  
22 between the cladding temperature and the water level?

23 MR. JOHNSTON: That is right. As the water level  
24 drops and the cladding is exposed, it heats up.

25 MR. KERR: What I would be interested in seeing is



1 a relationship between thermocouple temperature where the  
2 thermocouple is out between the shrouds and water level.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1           That comes later, perhaps.

2           MR. JOHNSTON: There is a correlation between the  
3 temperature that would be measured --

4           MR KERR: Could you raise that?

5           MR. JOHNSTON: My first vu-graph was to show that  
6 the temperature of the fuel is followed fairly closely by  
7 the temperature of the thermocouple located in the instrument  
8 train.

9           MR KERR: And that curve, which is -- let's see,  
10 channel --

11          MR. JOHNSTON: This is the temperature of the  
12 fuel. This is the temperature measured by a thermocouple  
13 located in the instrument train outside of the channel box  
14 in the space where the instrument tube is located. My point  
15 is, there is not a long time delay.

16          MR KERR: Those are measurements.

17          MR. JOHNSTON: Those are seconds.

18          MR. PLESSET: Those are not measurements. These  
19 are all calculations.

20          MR. JOHNSTON: These are all calculations.

21          MR. SIESS: What does that tell you about the  
22 temperature of the fuel at a higher level than the  
23 thermocouple?

24          MR. JOHNSTON: This does not tell you anything.  
25 This was a calculation made at mid-plane.

1 MR. BENDER: By following that temperature, you  
2 can keep track of whether you are losing water in the core.

3 MR. JOHNSTON: That is right.

4 MR. BENDER: That is basically what you are  
5 saying. How much time lag was there?

6 MR. JOHNSTON: About 100 seconds' time on that  
7 scale.

8 MR. BENDER: Thank you.

9 MR. CARBON: This is assuming you are losing water  
10 at the elevation of the thermocouple, of course.

11 MR. JOHNSTON: Or below.

12 MR. CARBON: Or below.

13 MR. JOHNSTON: Or below. And what I am showing in  
14 this sequence of calculations is that there are a number of  
15 events in which the water does continue to drop in the core,  
16 and accompanying that, I have the other curve that shows the  
17 temperatures of the fuel beginning to rise. The purpose of  
18 this instrumentation would be to follow that.

19 The event that is modeled there, as you see, is a  
20 suction line break with one LPCI available and recirculation  
21 pumps on.

22 MR. KERR: Are these calculations made with  
23 Appendix K models?

24 MR. PLESSET: I think they are best estimate  
25 models.

1 MR. JOHNSTON: These are best estimate models.  
2 They are made with the CHASTE code, but they have modified  
3 it to put in decay heat. They have modified heat transfer  
4 to steam. There is one other modification.

5 MR. PLESSET: These were made by GE?

6 MR. JOHNSTON: These were made by GE. This is a  
7 NUREG that we received in September.

8 MR. PLESSET: These calculations aren't  
9 necessarily very good.

10 MR. JOHNSTON: No, but the issue is not whether  
11 they are good or not. What I am trying to demonstrate to  
12 you here is that I presume they are consistent among  
13 themselves, and what they do show is a family of events  
14 which results in the water level dropping and a  
15 corresponding increase in the cladding temperature which I  
16 suggest we can measure with a thermocouple.

17 I am further trying to suggest that there are a  
18 number of cases in which the temperature rise of the  
19 thermocouple is relatively early, and the water will  
20 continue to drop for some period -- numbers of minutes even  
21 after the thermocouple temperature that they calculate is  
22 off scale, or above the limit of their calculation, I should  
23 say.

24 And we have this for -- I have examples that they  
25 provided us, both for cases in which the coolant in which

1 the break is on the coolant side of the plant and cases in  
2 which the break is on the steam side of the plant.

3 MR KERR: Would you expect that the temperature of  
4 the thermocouple, if it is going up, say, that there is  
5 water not very near the thermocouple, or would it be an  
6 indication of water level in what sense would you --

7 MR. JOHNSTON: The thermocouples as we discussed  
8 it with General Electric would be placed at two elevations  
9 in the core in the instrument string, so you would see --  
10 essentially, you would get two sets of terms of this sort  
11 displaced in time, and related to the amount of the core --

12 MR KERR: Let me say I have a thermocouple at  
13 Level 30 and the temperature jumps drastically. Does that  
14 mean the water has just at that point dropped below the  
15 thermocouple, or that it has dropped below the thermocouple  
16 by six inches or a foot or --

17 MR. JOHNSTON: Well, all I can show is more  
18 calculations, but there is a delay. These kinds of  
19 calculations answer something of that question. This is a  
20 calculation made of a boil down and what this shows is the  
21 temperatures at different elevations. This is the top of  
22 the core. This is one foot, two foot, three foot, so that  
23 what this tells you is, the temperature versus time at any  
24 particular elevation in the core.

25 Now, from doing these kinds of things for the

1 appropriate power distribution on decay heat and so forth,  
2 you can suggest that if I have a thermocouple located at,  
3 say, three foot down from the top, if the core began to  
4 uncover at time zero, I would have seen a temperature rise  
5 of about 500 degrees in this particular example, in 16 or 17  
6 minutes.

7 MR KERR: Where is the water level? Where is the  
8 water level relative to that temperature?

9 MR. JOHNSTON: The water level in 33 minutes -- it  
10 is dropping at about one foot every four minutes.

11 MR KERR: But pick a --

12 MR. JOHNSTON: This is about four feet from the  
13 top, and the temperature is rising clearly at the two-foot  
14 level, so there, there is a two-foot difference in that  
15 particular example, depending on what kind of resolution you  
16 want to have, the one-foot level took about six minutes.

17 MR KERR: I am not asking a very good question. I  
18 am trying to find out whether I can tell by looking at the  
19 thermocouple temperature where the water is.

20 MR. JOHNSTON: If you have an analytical model to  
21 go with it, you should be able to. The fact this is  
22 involved in the TMI Action Plan 2F2, PWR measurements.

23 MR. PLESSET: PWR, this does not sound too good to  
24 me.

25 MR. JOHNSTON: The same answer to the question as

1 far as chemistry is concerned.

2 MR. PLESSET: Isn't this what Caton was concerned  
3 about, Dr. Siess?

4 MR. SIESS: I think it is. Let's assume I am not  
5 interested at all in where the water level is, but I am  
6 interested in whether the core is being cooled, and my  
7 concern is that the clad or the fuel and the clad are  
8 heating up in, let's say, the top two feet of the core.

9 Now, the Reg. Guide says thermocouples between  
10 one-third and one-half the distance down. A third would be  
11 four feet, right?

12 MR. JOHNSTON: That is not a specified elevation,  
13 yet. That is an approximation.

14 MR. SIESS: Let's assume they are four feet down  
15 for the moment. Now, is that thermocouple reading -- I am  
16 the operator. Does it tell me when the clad is heating up  
17 in the top two feet of the core or just when it is heating  
18 up at the thermocouple?

19 MR. JOHNSTON: When it is heating up at the  
20 thermocouple. You will see no change in the thermocouple  
21 temperature indication if it is at the four-foot level until  
22 the water has boiled down to the four-foot level, and about  
23 another six inches beyond that.

24 MR. SIESS: So if I am interested in whether the  
25 core is being kept cool, this really only tells me when or

1 whether the bottom two-thirds of the core is being kept  
2 cool, right?

3 MR. JOHNSTON: That is correct.

4 MR. BENDER: It is something even different from  
5 that. It seems to me what you can learn from that is what  
6 is happening if you have flow going in and out of the core,  
7 and if the situation is one in which the main steam  
8 isolation valves have closed but you don't have any loss of  
9 coolant accident associated with it, what does that  
10 thermocouple tell you?

11 MR. JOHNSTON: I am not sure I follow the question  
12 entirely.

13 MR. BENDER: What I am saying, if there is nothing  
14 going into the core, and nothing going out, what we are  
15 trying to do is find out whether the water is becoming  
16 superheated --

17 MR. JOHNSTON: The water will already be  
18 superheated under those -- oh, superheated, you mean, the  
19 pressure is rising?

20 MR. BENDER: The main steam isolation valve closes  
21 and you don't have any way to get anything out. The  
22 question that is being developed is --

23 MR. JOHNSTON: If you have already partially  
24 uncovered the core, you will be seeing something like this  
25 on your thermocouple. If you have uncovered to the point of



1 that thermocouple, it will be rising in temperature. If  
2 your thermocouple is still covered, you will be reading the  
3 water temperature. If it is going a superheat, you will be  
4 reading a superheat water temperature.

5 MR. BENDER: Now, the question is, does that  
6 temperature tell me enough so I know before fuel damage  
7 occurs that fuel damage is going to occur. In the PWR's we  
8 are looking for something to tell us whether we have lost  
9 enough water in the core to cause fuel oxidation, and the  
10 same question has to be addressed here.

11 MR. JOHNSTON: All right. I think the answer to  
12 that is, yes, it will, depending on where the thermocouples  
13 are placed in the string. If the thermocouples are placed  
14 near the top of the string, when that level of core has been  
15 uncovered, the thermocouple will begin to change  
16 temperature, and you will know that you are exceeding the  
17 boiling water -- the temperature of the saturation of the  
18 water, and the temperature of that -- that that thermocouple  
19 will see can be calculated.

20 MR. BENDER: Is that soon enough to do something  
21 about it?

22 MR. JOHNSTON: I have indicated here that it took  
23 something like half an hour in this particular case before  
24 temperatures were reached that were high enough to begin to  
25 rupture the cladding. By that time, the coolant was already

1 down something like six feet down.

2 MR. BENDER: But that is not the same case we are  
3 talking about. I am talking about one where the main steam  
4 isolation valves have closed, and there is no flow going out  
5 of the core.

6 MR. JOHNSTON: The temperature in the  
7 thermocouples are still going to rise if there is fuel  
8 uncovered, and you will see it.

9 MR. BENDER: If the thermocouples were high  
10 enough, I suspect they might, but it is a matter of where  
11 they are.

12 MR. JOHNSTON: The thermocouples are sitting right  
13 next to the shroud. We have shown that the shroud warms  
14 up. We have shown that the thermocouples will see the  
15 shroud if they warm up. If the thermocouple is one foot  
16 from the top of the core, and it starts to warm up one foot  
17 from the top of the core, however you got to that stage, the  
18 thermocouple will see it, and it will continue to rise in  
19 the circumstance you describe, because there is no cooling  
20 going on in that region.

21 MR. SIESS: Let me try to explain the concerns --

22 MR. CARBON: Why don't you put the thermocouples  
23 at the end of the fuel element. Why is it a third of the  
24 way down?

25 MR. JOHNSTON: We suggested two elevations.

1           MR. CARBON: Why not one of them right at the very  
2 exit? That, I think, is where you are going to get -

3           MR. SIESS: Let me try something. I was not at  
4 the August meeting, but I can tell you what the concerns  
5 were that came out of the Subcommittee, and I think I knew  
6 what they were before. There were two concerns expressed by  
7 people at the Subcommittee meeting. One was that the  
8 thermocouple in the guide thimble, what the relation was  
9 between that temperature and the temperature of the clad,  
10 and there has been some curves presented.

11           The other question was, if the thermocouple is  
12 below the top of the core, what does it tell you about the  
13 condition of the core at the top?

14           Now, this whole discussion started with the PWR  
15 core exit thermocouples, which measured the temperatures not  
16 right at the top of the core but somewhere above that at  
17 Three Mile Island that were giving information that was  
18 ignored, and which would have been very useful information,  
19 and I believe all the initial discussion about PWR  
20 thermocouples again were core exit thermocouples. People  
21 were thinking about the same kind of thermocouples, same  
22 kinds of locations that you have in the PWR's.

23           The in core thermocouples, the first reference to  
24 that is in the letter, and apparently as a result of the  
25 discussion in August, there was something about, we cannot

1 put them up here, but maybe we can put them in the thimble,  
2 which would be in core, and the letter said something about  
3 study that, and basically the question that came up at the  
4 subcommittee is that if you do use in core thermocouples,  
5 how does that tell the operator something about the  
6 temperatures of the portions of the core above that,  
7 assuming he wants to know whether that clad is burning or  
8 not.

9 MR. KERR: In fact, the question was a little  
10 broader than that. It was, how does that tell the operator  
11 anything useful?

12 MR. PLESSET: That is a broader question.

13 MR. JOHNSTON: I think I tried to answer the  
14 question by showing this curve. If you put it down in the  
15 instrument string, you can measure it.

16 MR. SIESS: Are you saying -- Let me try this. I  
17 am looking at my thermocouple reading, and it stays down at  
18 some normal temperature. Does that -- saturation  
19 temperature. Does that assure me as operator that I am not  
20 getting any core oxidation anywhere?

21 MR. JOHNSTON: It depends on where the  
22 thermocouple is located.

23 MR. SIESS: It is four feet down from the top of  
24 the core. I will put it there. One-third of the core  
25 height down.

1 MR. JOHNSTON: No, it will not guarantee that you  
2 are not exceeding saturation temperatures anywhere in the  
3 core.

4 MR. SIESS: No, if I do see high temperatures, I  
5 know I have a problem, but if I don't see high temperatures,  
6 I don't know I don't have a problem.

7 MR. KERR: That was not the question you asked.  
8 You asked if he was sure, one, he was not seeing fuel  
9 damage. He said it would not assure you that it was not  
10 exceeding saturation temperature. And the two are quite  
11 different.

12 MR. SIESS: Let's start over again. I --

13 MR. JOHNSTON: It will not -- No, there is on  
14 way. If the thermocouple is sitting in water because we  
15 have designed it four feet down underneath the water, there  
16 is no way it is going to tell you the temperature that is  
17 going on inside the fuel assembly.

18 MR. SIESS: The four feet is not arbitrary. It is  
19 taken in the footnote in the table which is the Reg. Guide  
20 we are reviewing and have been asked to concur in.

21 MR. KERR: You did this to me earlier, and I am  
22 going to do it to you.

23 (General laughter.)

24 MR. KERR: Is there some way that one can predict  
25 the temperature above the water when one knows that one has

1 boiling water in a fuel channel? I am not sure that this is  
2 impossible.

3 MR. JOHNSTON: That is what this curve that I put  
4 here does.

5 MR. KERR: As long as I have water at the four-foot  
6 level, I think it is impossible to predict what is happening  
7 the fuel above that, even though I don't have a thermocouple  
8 up there.

9 MR. JOHNSTON: That is true. That is an  
10 analytical function. You can do that if you know where your  
11 water level is.

12 MR. SIESS: Wait a minute.

13 MR. CARBON: You can only do that on the  
14 assumption that you know the rate at which the water level  
15 is going down, and you don't know that.

16 MR. JOHNSTON: Well, you have a variety of ways of  
17 having a good handle on that. It can be strictly boil off  
18 by decay heat. You have a pretty good idea of what the boil  
19 off rate will be. If you couple that with a small break,  
20 you know how much material you will get out of the break.

21 I think that sort of thing will give you a basis  
22 for making a calculation of that type if you don't have a  
23 direct measurement of it.

24 MR. CARBON: Yes, you can make the calculation all  
25 right, but if the operator is sitting there and he does not

1 know that he is losing water, he has no way of knowing  
2 that. He has a thermocouple that reads a normal  
3 temperature. He does not know he is losing water.

4           The top two or three feet has exceeded a  
5 temperature. Perhaps he is getting melting of the  
6 cladding. He does not know this. Is this not so?

7           MR. JOHNSTON: That is perfectly correct, and I am  
8 not defending -- I don't know where the number got into the  
9 Reg. Guide that talks about the elevation of the  
10 thermocouple, because that has not been established between  
11 ourselves and at GE. Somebody just put something in, and I  
12 would suggest we not get hung up on a particular elevation  
13 because I can put it at one foot --

14           MR. CARBON: You cannot do that, can you? Don't  
15 these tubes come up from the bottom, and you cannot go to  
16 the top?

17           MR. JOHNSTON: You can put it within one foot of  
18 the top.

19           MR. CARBON: You can put it in one foot?

20           MR. JOHNSTON: Yes.

21           MR. CARBON: Why aren't they at that height then  
22 instead of four feet down?

23           MR. JOHNSTON: They have never been at four feet  
24 down until somebody pushed that button on a typewriter, is  
25 what I am trying to suggest.

1 (General laughter.)

2 MR. JOHNSTON: Nobody has decided where they are  
3 going to be in any firm way to this date.

4 MR. CARBON: Wouldn't it be logical to put them as  
5 near the exit, as near the end of the active zone of the  
6 fuel as possible, even including right at the very end of  
7 the fuel?

8 MR. JOHNSTON: If you are using them for that  
9 single function only, that would be true. If you want to  
10 also have some ability to monitor the condition of the core  
11 afterwards, if there has been some damage sufficient to  
12 change the geometry of the channel boxes, then it is better  
13 if it is down further.

14 MR. CARBON: But your first goal is to find out if  
15 the core is becoming uncovered, I believe. I think you have  
16 just said that, that for that goal you would want the  
17 thermocouple just as close to the exit as possible.

18 MR. BENDER: I think we are putting words in Mr.  
19 Johnston's mouth. I believe he really said that initially  
20 they had planned to use the thermocouples to monitor the  
21 condition of a coolant during some of these loss of coolant  
22 accidents, and now we have changed the ground rules on him,  
23 and I am not sure that he really understands the conditions  
24 under which we are asking the question, and it is unfair.

25 I believe he is right in saying that they need to



1 look at all the locations where they might look at  
2 thermocouples, and if we leave it there, they will sort  
3 those out. At least, that is what I would propose to  
4 suggest.

5 MR. JOHNSTON: That is what we plan to do.

6 MR. CARBON: I would still like to ask my  
7 question, though, and I believe it has been answered, but I  
8 am not sure. If you want to know as early as possible  
9 whether the core is becoming uncovered, you would, would you  
10 not, want to put a thermocouple at the exit of the core or  
11 as close to it as you could get?

12 MR. MATHIS: You would look at the water level.

13 MR. JOHNSTON: I will answer that with a  
14 speculation. Let me speculate in a different way than what  
15 I have been answering you before. The calculations that  
16 have been made previously have shown that if the water level  
17 of the core does not drop off more than a foot or two, that  
18 you will not get high temperatures at the top of the core,  
19 because there is sufficient boiling to do decay heat  
20 generation, and other matters, that you will not get a  
21 superheated -- an overheated fuel assembly.

22 It is only if you drop down on the order of  
23 several feet that you really get the temperature rises that  
24 we are talking about. So I guess I could change my answer,  
25 but I don't have any calculations to show you, but I know

1 they have been made because I have had them done.

2 MR. SIESS: Mr. Chairman, I think it would be  
3 worthwhile, since the representative from the Office of  
4 Nuclear Reactor Regulation says he does not know where the  
5 one-third to one-halfway down came from, I think it would be  
6 appropriate to ask the people from the Office of Standards  
7 Development whether they know where it came from.

8 MR. HINTZE: I will take the responsibility for  
9 pushing the typewriter key.

10 (General laughter.)

11 MR. HINTZE: If we left the "from" out in the  
12 transmission from Dr. Johnston -- that is where it came  
13 from. We did not mean to specify any specific place.

14 MR. SIESS: From one-third to one-half means  
15 between one-third and one-half, to me. If I go from  
16 Washington to Chicago, I am somewhere in between there.

17 (General laughter.)

18 MR. SIESS: There is no way I can start in Bermuda.

19 (General laughter.)

20 MR. JOHNSTON: The discussions we had with General  
21 Electric which we are talking about putting four  
22 thermocouples per quadrant, we discussed two thermocouples  
23 would be at one elevation and two thermocouples would be at  
24 a different elevation. We have not established what those  
25 two elevations will be.

1           One way to approach that is to make the  
2 calculation of the heatup rates for different elevations of  
3 water as I have suggested here. I think you will find if  
4 the water level only drops a couple of feet in the core for  
5 the first 50 -- for the first 10 to 15 minutes after the  
6 accident, there will not be a high temperature recorded for  
7 those fuel rods in that portion.

8           It may not be necessary to put a thermocouple in  
9 the top couple of feet for that reason.

10           MR. PLESSET: Let's try to shorten a little bit.  
11 Chet?

12           MR. SIESS: I have no preferences. This was the  
13 Committee's question. The Committee has questioned whether  
14 core exit thermocouples in BWR's would do any good, and as I  
15 say, the staff has reached an agreement with GE and you  
16 heard the story. Now, I am satisfied.

17           MR. BENDER: I want to try one more time --

18           MR. SIESS: I have learned something. They could  
19 be as high as one foot from the top of the core.

20           MR. BENDER: There are two conditions to be  
21 considered. One is the one in which you have continuing  
22 flow through the core, and you may be losing coolant because  
23 of some kind of loss of coolant accident, and for that one  
24 you may very well want the thermocouples down in the core so  
25 that you can see what is happening as the fluid level drops.

1           The other is a condition where you close the main  
2 steam isolation valves and there is no outflow, and for that  
3 one do you want to know something? Now, Dr. Caton suggested  
4 that that might be an important consideration as well, and  
5 that it had not been addressed, and I don't know whether it  
6 should be addressed. I am just trying to point out that it  
7 is an existing question.

8           MR. ROSENTHAL: I think the correct scenario would  
9 be as follows. You turn the core off. You have decay heat  
10 being generated. You close the MSIV's, as you should. You  
11 are not making up water or removing decay heat from the  
12 system. You heat up the water. You lift the safeties, and  
13 you are dumping inventory down into the torus. You would  
14 like your emergency safety features to function, and keep  
15 the core covered with water, with makeup water.

16           I was coming from the view that the operator would  
17 like to be assured that he has water in the core. He has  
18 one redundant but not diverse means of measuring water  
19 level, and that is the DP cells, and it would be useful to  
20 have a diverse means to tell the operator that he does not  
21 have water in the core.

22           MR. PLESSET: I think --

23           MR. BENDER: It still needs to be clarified, but I  
24 think we understand the scenario.

25           MR. PLESSET: I think it should be left open where

1 one would put those thermocouples.

2 MR. ROSENTHAL: I apologize for interrupting. We  
3 will delete all reference to height.

4 MR. PLESSET: Okay. Because I think it is  
5 possible that we will have techniques which will make more  
6 reliable calculations available in the CHASTE code, for  
7 example. I think if they leave it open, there is no great  
8 harm.

9 MR. JOHNSTON: I am not sure if I should take more  
10 of your time. I have a number of these other calculations.

11 MR. PLESSET: You might just as well quit while  
12 you are ahead.

13 (General laughter.)

14 MR. SIESS: There is a question we can ask the  
15 Committee. Have you heard enough to know what your position  
16 is on this item?

17 MR. PLESSET: I think the Committee is fairly well  
18 satisfied, Chet.

19 MR. KERR: If they are in core thermocouples, we  
20 put them somewhere in the core.

21 MR. PLESSET: Where it will be useful.

22 MR. SIESS: The next item I think the Committee  
23 should here then is some discussion of this environs  
24 exposure monitoring. As it stands now, the requirement --  
25 it occurs at two places in each table, because there is some

1 listed under both Type C and Type E. But a perfectly  
2 typical one is Page 23, the bottom item, and I will have to  
3 have the staff tell me where it is explained, because the  
4 table itself does not tell you how many, and maybe it is not  
5 intending to.

6           Is there something in the discussion that tells  
7 you how many of those -- that elaborates on that  
8 requirement? Could you give us a page reference?

9           MR. KREEGER: How many of the detectors?

10          MR. SIESS: Yes.

11          MR. KREEGER: I am Bill Kraeger.

12           We deleted the number of specific detectors in an  
13 environs monitoring system as well as changing the range of  
14 the detectors in order to reduce the specificity enough to  
15 allow for some what I would call innovation in view of the  
16 criticisms we got in just very recent days about what the  
17 system can do and how it should function.

18           So, we removed the number and we reduced the  
19 range, and we hope that that will enable the industry to  
20 provide recommendations of their own. We have several  
21 reports which we just received and have just had a chance to  
22 look at, one from the Atomic Industrial Forum, some  
23 additional comments from Consumers Power.

24           We also have a paper from Pacific Gas and  
25 Electric, Diablo Canyon, proposing an actual system. We

1 have a paper from Germany which proposes a similar system,  
2 and the staff has been bombarded in fairly recent days with  
3 quite a bit of new information, so we are trying to make the  
4 writing as it now appears in the document flexible enough to  
5 permit innovative proposals.

6 MR. SIESS: In the Reg. Guide, where it is listed  
7 under Type C -- correction -- Under Type C, the heading is  
8 Environs Radioactivity Exposure Rate, and under Type E,  
9 there is a parentheses that says Installed Instrumentation.  
10 Was that just to distinguish it from portable  
11 instrumentation that occurs in the next -- fourth item down  
12 -- third item down?

13 MR. KREEGER: Yes. The issue that I was asked to  
14 -- go ahead.

15 MR. SIESS: I guess one of our problems is that we  
16 could not get too much information from the Subcommittee  
17 meeting as to the purpose of this, and when we -- what we  
18 did get the purpose suggested that the number had to be  
19 very large. I will admit the guide does not always tell you  
20 how many, but it does talk in other areas about redundancy  
21 and diversity, so you have some idea of how many instruments  
22 and how many channels.

23 But as it reads now, it simply says, and I think  
24 what you are saying is that they should be able to monitor  
25 with installed instrumentation the radiation exposure rate

1 in the environs in a range from one millirem per hour to ten  
2 rem per hour.

3 Is environs defined anywhere in here?

4 MR. KREEGER: I am not sure that it is. I had  
5 discussed with other members of the staff the possibility  
6 that we did need an environs definition. Actually, environs  
7 is usually used to be site boundary and beyond, although  
8 occasionally you will find our regulatory guidance talking  
9 about plant environs as if it is within the site boundary.

10 In this particular case, I believe it means site  
11 boundary and beyond. It may be that it should be defined. I  
12 think --

13 MR. SIESS: But in your thinking, in terms of the  
14 scenarios or objectives, you think site boundary and beyond?

15 MR. KREEGER: Yes.

16 MR. SIESS: And that means that these instruments  
17 have to be then beyond -- at and beyond the site boundary?

18 MR. KREEGER: Yes, sir. You will recall we had  
19 originally 16 to 20 stations, one of the criticisms of the  
20 industry report was that 16 stations would have neither the  
21 accuracy nor the sensitivity under scenarios that you could  
22 describe to actually even see the plume under a number of  
23 conditions such as an elevated release, certain  
24 meteorological conditions. However --

25 MR. SIESS: Were those 16 stations in a circle at



1 the boundary or were they --

2 MR. KREEGER: We did not specify where they had to  
3 be, because we asked that they do a certain job, that is,  
4 that they enabled you to decide, and particularly for an  
5 unmonitored release point such as breach of containment or  
6 containment penetration, where we had not anticipated  
7 release and did not have monitors to the TMI task action  
8 plans, lessons learned, and so forth.

9 We conceived of these as being mechanisms for  
10 getting back information that would tell us there was an  
11 unmonitored release point venting radioactive material.  
12 That is what is specified in the requirement, so to speak.  
13 That is what is specified in the requirement for these  
14 devices.

15 MR. SIESS: Where is that in the guide?

16 MR. HINTZE: This comes under the category of Type  
17 C, where you are detecting a potential for or an actual  
18 breach of the barriers to radioactive materials release, and  
19 the environs monitors was the containment breach from an  
20 unidentified source.

21 MR. SIESS: I understand that. I heard it  
22 yesterday -- Wednesday, and I am hearing it now, but if I  
23 were reading the guide, where would I find that, that this  
24 is related to the unidentified releases?

25 MR. KREEGER: In a sense, at the head of the

1 table, Type C variables. At the top of the table, it says,  
2 those variables that provide indication or indicate the  
3 potential for being breached or the actual breach. That is  
4 up at the top of the table, Page 22, for example, Page 28,  
5 for example.

6 MR. SIESS: Yes, I know that, but --

7 MR. KREEGER: But, that is one specification.

8 MR. HINTZE: It is under the definition of Type E  
9 variables, which is on Page 16 and 17. Page 17, Line 3,  
10 Item 3, on-site locations where unplanned releases of  
11 radioactive materials can be detected.

12 MR. SIESS: Where is that?

13 MR. HINTZE: Page 17, Item 3.

14 MR. SIESS: That is what I wanted.

15 MR. HINTZE: Line 3, top of the page.

16 MR. KERR: But that is for Type E, it says.

17 MR. SIESS: That is Type C and Type E. If you  
18 want to look at Type E, it is on the other page number I  
19 gave you, consisting of two categories here, Type C and Type  
20 E.

21 I am trying to find the origin. Process for  
22 selecting system operation and effluent release variables  
23 should include the identification of, and then for Type D I  
24 go down and see, on-site locations for unplanned releases of  
25 radioactive materials should be detected, right? Is that

1 the way you read it?

2 Now, what does on-site location mean? Is that  
3 where the release is on-site or the detection is on-site?

4 MR. KREEGER: The detection is on-site.

5 MR. SIESS: But Mr. Kraeger, you just said it is  
6 at the site boundaries. Does it mean beyond the site  
7 boundaries? I am quite confused.

8 MR. KREEGER: I am sorry, I cannot answer that  
9 question. I had not recognized the three --

10 MR. SIESS: What is bothering me is this. This  
11 Reg. Guide has become quite proscriptive. And I don't think  
12 we have complained too much about the proscriptive nature of  
13 it, because if I go through the history, I know why it is  
14 proscriptive, and yet here it is insufficiently  
15 proscriptive, and I have not yet found the words that tell  
16 me what the objective is to offset the lack of proscription.

17 I have to locate these, decide how many and  
18 where. I either have to have you tell me where to put them  
19 and how many, or give me criteria so that I can determine  
20 where to put them and how many. I have heard it orally,  
21 but --

22 MR. KREEGER: The purpose of the statement in the  
23 table -- it also says, detection of significant releases,  
24 verification, release assessment, and the long-term  
25 surveillance. For example, Page 30, the last column, the

1 purpose column, under radiation exposure rate devices.

2 MR KERR: Table 2, Type C.

3 MR. SIESS: You have a different purpose under  
4 Type C than you do under Type E.

5 MR KERR: On Page 30, I am looking at -- I am  
6 sorry. Installed instrumentation. Okay.

7 MR. KREEGER: Page 41, we have a slightly  
8 different wording, too, detection of breach, accomplishment  
9 of mitigation and verification.

10 MR. SIESS: That is the Type C purpose. The other  
11 is the Type E purpose.

12 MR. KREEGER: Right.

13 MR. SIESS: I guess that is logical.

14 MR. BENDER: The question that seemed to be  
15 hanging around, though, is why do we need so many, and are  
16 they really going to be all that effective in alerting the  
17 operator to the emergency?

18 MR. KREEGER: That is what I alluded to by saying  
19 we do have a report from the Atomic Industrial Forums NSP  
20 study done by Science Applications, Incorporated, which we  
21 just received a week or so ago, which says that such a  
22 system with perhaps more detectors than we had specified,  
23 more than the 16 or 20 that were originally specified, would  
24 be only possible potentially if being within a factor of two  
25 of saying what the dose rate was under certain conditions,

1 and might in fact if one went to the 16-20 detectors miss  
2 the plume entirely for a number of potential scenarios of  
3 release, including breach of containment, with a high  
4 elevated release.

5           What we have proposed is that with proper  
6 selection of the number and location or what -- what we  
7 don't propose in here but what we have left out because we  
8 believe it can be appropriately proposed, that with a proper  
9 selection and location, a selection of number and location  
10 of the devices which might include using the meteorological  
11 information for the site that is the annual -- the  
12 information about how the meteorology varies with time in  
13 the site environs, that you could select an appropriate  
14 location and number of devices to be the only method for  
15 predicting both the dose rate and that in fact getting some  
16 idea about the quantity of release in an unmonitored release  
17 path.

18           That is one that did not go buy the new effluent  
19 monitoring required by the task action plan, would not be in  
20 a sense seen, at least informatively, by the high radiation  
21 containment monitor, and so forth, and in fact the scenario  
22 that we have been discussing with Mr. Case and Dr. Ross, and  
23 before the first meeting with Mr. Denton, was a scenario in  
24 which the event was in progress, the staff had not been  
25 available to get monitoring teams out into the environment

1 yet.

2           The response center was not necessarily manned,  
3 and the only person who might be able to see a release on a  
4 device might be the operator who was getting feedback from  
5 the environs monitoring devices properly placed and with a  
6 proper number so that he could alert people to what was  
7 happening.

8           Now, that admittedly requires sophisticated  
9 instrumentation and computer usage of that information, but  
10 the computers will be there and or mini-computers can be  
11 proposed -- have been proposed, in fact, in the Diablo  
12 Canyon case, that would analyze such information from such  
13 detectors and would give useful guidance.

14           MR. BENDER: Well, the question that seemed to be  
15 concerning most people was why the need for such careful  
16 determination of dose rate, you want to know whether to  
17 evacuate or not, and beyond making that decision, what is  
18 the urgent need for very careful measurement of dose rates?

19           MR. KREGER: I would not characterize this as  
20 very careful. In a sense, we are not saying -- We are not  
21 proposing that it is any more accurate than these studies.  
22 If by careful, you mean accurate. I want to know what it  
23 is, though, and if I do not have --

24           MR. BENDER: Do I need to know it within a factor  
25 of two, or would it be all right to know it within a factor

1 of ten or 100? I don't know.

2 MR. KREEGER: It might be that that would still  
3 require, I think -- What we are looking at now is 32 to 40  
4 stations. What we think now would be appropriate is 32 to  
5 40 stations. But without nearly as sophisticated a  
6 detection system. It has to be telemetered back or  
7 hardwired back, and it has to come into a computerized  
8 information analysis device which is also getting data.

9 MR. BENDER: But I just want to make a simple  
10 point. The SAI study said to get within a factor of two you  
11 needed a number more than 16. I don't know how many more.  
12 I think the Committee would find it useful to find whether  
13 you need to know the number to a factor of 10 or a factor of  
14 100 before it tries to make a judgment on whether this  
15 scheme is a good one to use.

16 My suspicion is, a factor of 10 is probably no  
17 more than you need.

18 MR. KREEGER: Looking at the SAI curves, even with  
19 a factor of 10, you need --

20 MR. BENDER: I am not going to argue what it is  
21 going to be. It would be nice to know what the accuracy is  
22 you are looking for.

23 MR. KREEGER: The staff considered taking the  
24 requirement out entirely. We discussed that with Harold  
25 Denton. Harold said that if it took a couple of months to

1 do the appropriate additional analysis by the staff or by  
2 contract to determine exactly what was the right number and  
3 what was the right accuracy, if you will -- right is a  
4 matter of decisions -- he would be willing to have it taken  
5 out and enter another way, like the branch technical  
6 position, or like an additional regulatory guide, or  
7 something like that.

8           Mr. Case, on the other hand, felt that in our  
9 discussion after the meeting of Wednesday, that it was more  
10 desirable to leave it in as a relatively unspecific  
11 proscription, so that we would have industry still working  
12 themselves on what kind of a system was appropriate for  
13 getting decision-making guidance.

14           MR. BENDER: I like Mr. Case's approach, but I  
15 think the guide should give that kind of guidance to the  
16 licensees.

17           MR. MARK: I think there might have been a comment  
18 from the staff. Perhaps two or three steps back to clarify  
19 something. Is that correct? Excuse me, Bill.

20           MR. KERR: I can't tell whether we are trying to  
21 devise something that will enable us, given a significant  
22 amount of computer message, to predict the course and  
23 intensity of radiation in a cloud that is ten miles downwind  
24 from the site or whether we are just trying to find out  
25 whether there is a break in the containment whereupon one



1 goes outside and makes more careful measurements.

2 Which of these two is one trying to accomplish?

3 It seems to me the instrumentation you use is very

4 different, depending on which one of the two.

5 MR. KREEGER: I would conceive of both  
6 possibilities. I cannot get away from the fact that there  
7 are circumstances in which I do not have survey teams  
8 available yet and in which this instrumentation starts  
9 telling me information immediately, and I can use that with  
10 a mini-computer and meteorological data to tell me where  
11 that plume is going and what the dose rate is going to be in  
12 the worst part of that plume.

13 MR KERR: And it is conceivable that one would  
14 make a decision to evacuate based only on that information.

15 MR. KREEGER: I do not know that. Steve Ramos is  
16 the --

17 MR KERR: If you would not make a decision based  
18 on that, and you have to go out and get some other  
19 information, it seems to me that other information is what  
20 you make a plume decision on. But if there are situations  
21 in which you have to depend on this, and this only, to make  
22 an evacuation decision, then it is a different system, and  
23 it seems to me a licensee needs to know which of those two  
24 objectives, or if you have all of those objectives in mind.

25 MR. RAMOS: I am Steve Ramos, chief, emergency

1 preparedness branch, and we would not -- and I will probably  
2 not make the decision to evacuate based strictly on this  
3 instrument. The purpose of the instruments is so that we  
4 can give a prompt notification to the state, local, the NRC,  
5 based on that immediate reading.

6           It is going to give us a reading based on the  
7 plants that we would have hand-plotted or coming in from a  
8 computer to show the operator that he has a high radiation  
9 or possibly high radiation level.

10           Based on that, he would make his notification to  
11 the state and local and to the NRC. He would immediately  
12 dispatch the shift monitoring teams to go out and verify  
13 exactly what that level is.

14           MR KERR: Suppose that one had a level that was  
15 ten times background. Would that be high?

16           MR. RAMOS: Yes, it would be high. We would go  
17 out and check it.

18           MR KERR: Would you do something different if it  
19 were 15 times background than you would if it were ten?

20           MR. RAMOS: Ten and 15 times background is no  
21 different.

22           MR KERP: What about 20?

23           MR. RAMOS: Still no difference. You are trying  
24 to get a number out of me.

25           (General laughter.)

1 MR KERR: I am trying to get some idea of the  
2 accuracy you need.

3 MR. RAMOS: We are not looking for something real  
4 accurate. We are looking for something to give us an idea  
5 what the level is at that point. That is why we agreed to  
6 these various changes.

7 MR KERR: Can a licensee reading what is in this  
8 Reg. Guide get the information which you just gave me? I  
9 rather doubt it.

10 MR. RAMOS: If he will read NUREG-0654, which is  
11 the criteria for preparation and evaluation of the plans for  
12 emergency plans in conjunction with this Reg. Guide, yes.

13 MR KERR: As I read this Reg. Guide, the  
14 instrument has to be able to read something that has  
15 significance from one MR above background to 10 R. Now, if  
16 all I really want is something like maybe 8 to 20 times  
17 background, I don't really understand the reason for the  
18 wide scale.

19 MR. RAMOS: If I knew that where this instrument  
20 was, that it read one-half R, 500 MR, I can lay an isoplat  
21 down and determine, based on the meteorological conditions,  
22 approximately how much I have at the highest point. It  
23 helps me to decide whether or not I have a real off-site  
24 problem or not.

25 Now, we have some curves that we can show you on

1 how we would want to use this.

2 MR KERR: I am laboring from a situation which I  
3 have seen on the curves and so on. So you are telling me  
4 there is indeed more information, and the licensee has  
5 access to that, and he will read this, and he will say, hey,  
6 if you want to design this, go get NUREG so and so. That is  
7 one of the footnotes that I have missed somewhere.

8 MR. RAMOS: There is no footnote in this.

9 MR KERR: We told you to take the footnotes out.

10 (General laughter.)

11 MR. RAMOS: Reg. Guide 1.97 is only for the  
12 instrumentation to go into the control room, as the title  
13 says. NUREG-0654 is specifically for emergency  
14 preparedness, and it says you must have an off-site  
15 radiological monitoring system real time to be able to make  
16 decisions on giving prompt notification. It is in Reg.  
17 Guide 1.97, the requirement -- the fact that in NUREG-0696,  
18 which gives the requirement for emergency response  
19 facilities, we decided we would use 1.97 as the minimum data  
20 base for all of the facilities, making a subset for each one  
21 of those facilities.

22 And if we did not have it in 1.97, we would then  
23 have to come up with several other lists. There was no  
24 reason to do that.

25 MR. PLESSET: Dade, I want to point out that we

1 are creeping through this at a snail's pace. I wonder if we  
2 could not accelerate things a little bit.

3 MR. MOELLER: As I understand the reason for the  
4 instrumentation here, it is to help the operator in the  
5 control room decide whether he has had a breach of  
6 containment or yes, indeed, he is having radioactive  
7 materials released to the environment, and if it can be used  
8 for other decisions, fine.

9 The question I have on it then, you mentioned  
10 Diablo Canyon, in order to tell the operator there whether  
11 he is leaking radioactive material into the environment,  
12 then I would need these installed instruments out in a  
13 perimeter in the Pacific Ocean, because although people are  
14 not there and I don't need it for emergency planning, I do  
15 need to know whether there has been a breach of containment  
16 and whether a cloud is moving the material.

17 Am I correct, then, that plants located on a  
18 seashore or on a lake and so forth, you would expect the  
19 perimeter of instruments to go out over a water area.

20 MR. RAMOS: To answer your question, no. As we in  
21 emergency preparedness envision it, this ring -- we don't  
22 care if it is a ring or square or star or what have you.  
23 The shape, we don't specify in emergency planning documents  
24 what kind of a shape it should be. All we say is, you must  
25 have a system.

1           Now, in order to fit a system in correctly, the  
2 licensee has got to do a study of the environmental  
3 conditions at his particular place to determine where the  
4 best location for an instrument has to be. We envisage it  
5 would probably be on site close to the plant. You could  
6 circle the plant very easily.

7           MR. KREEGER: I would like to comment that we had  
8 speculated that he would also see a breach of containment on  
9 other radiation monitors. That is what I was calling an  
10 unmonitored breach of containment, but we would not know for  
11 sure that it was a breach of containment.

12           For example, we might see area monitors within the  
13 plant go off -- go up, if there was a penetration in  
14 containment, that was what was breached. It might be a  
15 penetration into some other part of the facility. It might  
16 be a penetration to the outside. Since we were coupling the  
17 fact that we wanted some mechanism for recognizing  
18 unmonitored release of radioactivity or an unmonitored  
19 effluent point, that he would expect to have devices at a  
20 fairly uniform distribution outside the plant, but we are  
21 coupling that with the fact that the most important reason  
22 for knowing that is for decisions about people, so that if  
23 the wind were blowing offshore toward the ocean, and so  
24 forth, we might not be as concerned at that point, knowing  
25 that containment had been breached.

1           So, I could foresee, as Steve said, that you would  
2 not instrument the offshore or the beach necessarily,  
3 because then you would not care so much -- of course, the  
4 wind can always shift, and it can shift pretty fast, but you  
5 have things that would then see it as it swung back, and you  
6 would be using your isoplat. You would see it as it swung  
7 back on shore.

8           MR. PLESSET: Can we move along? Let's do that.

9           MR. SIESS: Has the Committee heard enough on this  
10 to know what its position is?

11          MR. PLESSET: Yes.

12          MR. SUMMERS: With regard to environs monitoring --

13          MR. SIESS: That is not working. You have to fix  
14 it so it works.

15          MR. SUMMERS: Dave Summers, Consumers Power.

16           I was a member of the ANS 4.5 group.

17          MR. PLESSET: I cannot hear you.

18          MR. SUMMERS: I was involved insofar as being on  
19 the committee scoping out the study by Scientific  
20 Applications, and I guess I would first like to say that  
21 that report at this point in time is a draft report, and it  
22 has not had adequate peer review in terms of at the NRC or  
23 throughout the industry at this point.

24           But there is a couple of, I think, pertinent  
25 results from that study which indicate that environs

1 exposure rate monitoring is at best an ambiguous indication  
2 of breach of containment, and cannot be used for a release  
3 assessment. Specifically, if we take as an example the  
4 Three Mile Island accident, and I ask Phil Stoddard to  
5 correct me if I am wrong, where we had estimated, I believe,  
6 40 percent TID source term and noble gases were released at  
7 Three Mile Island, the numbers that we were seeing at Three  
8 Mile Island which we could see in an environs exposure rate  
9 was in the vicinity of somewhere around 500 MR per hour, was  
10 the peak.

11           We are talking 10 to the 9 curies total noble gas  
12 for core inventory. We are talking in terms of a design  
13 base accident, 1 percent failed fuel, 3 orders of magnitude  
14 lower. If you start looking at all of the classes of  
15 accidents which have lower curie releases, it becomes  
16 apparent you are not even going to see anything if you get  
17 out much beyond 500 meters, and depending on how many you  
18 have, you still have the problem for the given accident in  
19 what the leak rate is.

20           Again, if you go back to the design base accident  
21 as opposed to Three Mile Island, where you may only have a 1  
22 percent leakage rate out of containment per day or a tenth  
23 of a percent leakage rate out of containment per day instead  
24 of everything going out in two days, what you can pick up on  
25 these monitors decreases drastically.



1           We have -- I have to apologize. This was just  
2 done on the plane coming in from Michigan. It appears that  
3 if you couple this with the release, an unidentified release  
4 at .00 meters, the range we are talking about, attempting to  
5 detect for 1 percent failed fuel is between one-tenth of a  
6 microcurie -- excuse me, a tenth of a micro r per hour and 2  
7 micro r per hour at 200 meters.

8           Although these devices are extremely sensitive,  
9 you won't be able to tell between background and the  
10 release. As a consequence, as a representative of the ANS  
11 4.5, I informed our chairman we may have to go back and do a  
12 little more homework in terms of endorsing this parameter  
13 for 4.5, because in summation it is at best ambiguous  
14 indication and only applies for a very narrow set of  
15 accident scenarios, where there are very severe radiological  
16 releases.

17           MR. KREEGER: That latter point is one that we  
18 were perfectly cognizant of during most of the process of  
19 discussing this. It is not a high probability situation.  
20 The kinds of things that are going on and would cause you to  
21 want to have such a system, are low probability, both in  
22 terms of an event happening and other things that are  
23 coupled with it, such as not being able to get your teams  
24 out fast and such things.

25           In that sense, it is hardly a cost effective kind

1 of proposal, but I think a lot of the things that we are  
2 talking about are not.

3 MR. BENDER: Mr. Chairman, I suggest we know  
4 enough to ask for more investigation of the proposal.

5 MR. PLESSET: I think we can leave it at that. We  
6 got your point. I think we can go on to the next item.

7 MR. SIESS: Okay. This is the last item that I  
8 intend to bring up, and this relates to the relation between  
9 Reg. Guide 1.97 and the instrumentation defined therein, and  
10 NUREG 0696, which relates to the emergency operating  
11 facilities, emergency response facilities, the alphabet soup  
12 that I mentioned earlier.

13 In its letter last August, the Committee mentioned  
14 this. I will not try to repeat the letter. I have read it  
15 three times now, and I don't understand it. But I assume  
16 you do. They mentioned the safety parameter display system  
17 at the Subcommittee meeting, I think both members of the --  
18 both consultants mentioned that we -- we should go through  
19 Tables 1 and 2 of the guide and put asterisks by those items  
20 which would be a part of the safety parameter display  
21 system. This would not be entirely inconsistent with the  
22 purpose of the guide, since that system will be part of the  
23 control room.

24 Other people, industry representatives, proposed  
25 that the whole thing be integrated in some way, and that the

1 guide be held up until all of these other questions can be  
2 straightened out.

3           Now, the staff restricted the scope of this to the  
4 instrumentation available to the operator in the control  
5 room, I think in response to the recommendation by the ACRS  
6 that they limit the scope. I don't know how the Committee  
7 wants to do it. You can discuss NUREG-0696, and what will  
8 presumably be some subsequent guidance from the staff as a  
9 result of the nuclear data integration group  
10 recommendations, and I think that this committee should  
11 discuss NUREG-0696.

12           We have discussed the nuclear data link. These  
13 are equivalent type things. But I don't see quite how we  
14 can discuss NUREG-0696 and Reg. Guide 1.97 and still help  
15 the staff meet the deadline we have set for the end of the  
16 year for Reg. Guide 1.97.

17           I have looked at it in the light that the staff  
18 has determined the instruments that are needed to follow the  
19 course of an accident. They have assigned those three  
20 categories, and some relationship to their importance as to  
21 redundancy, seismic qualification, environmental  
22 qualification, and reliability, et cetera, and what uses are  
23 made of those instruments outside of the control room is  
24 another matter.

25           As I mentioned earlier, I do think it is important

1 that something be done to not require licensees to rush into  
2 implementation of Reg. Guide 1.97 as far as requirements for  
3 the other emergency support facilities require changes. And  
4 as I said earlier, I thought this could be handled by  
5 recommending the implementation of this -- and take that  
6 into account.

7           Now, the implementation of Reg. Guide 1.97 is no  
8 later than June, 1983, I assume. I know it is the first of  
9 June or the last of June. It is a strange lack of precision  
10 there. No later. But a number of the items in here have  
11 already been referenced in NUREG-0578, 0660, 0694, 0737, et  
12 cetera. And they are to be implemented on operating plants  
13 or on plants getting licenses before June, 1983, according  
14 to that schedule.

15           So, there are certain things that are on a little  
16 faster schedule, but not because they are in this Reg.  
17 Guide, but because they have been required by something  
18 else. So, basically, if a nuclear data integration group is  
19 going to reach a conclusion and the Commission is going to  
20 agree on some criteria for the multiple facilities within  
21 one to three weeks as predicted inside NRC, then I think the  
22 June, 1980, pre-date is far enough ahead.

23           But if it turned out it got to be June, 1982,  
24 before they decided those other things, I would not be too  
25 happy about people getting started here.

1           Now, what does the Committee want to do about  
2 discussing the interrelationship between this document which  
3 the staff would like to consider complete and the other  
4 situation which is still in a state of flux?

5           MR. PLESSET: Mike?

6           MR. BENDER: As reluctant as I am to support it,  
7 it seems to me that we have to encourage the release of this  
8 Reg. Guide. I think it is too pervasive, and it is not so  
9 much because they have not settled what is to be done with  
10 the off-site instrumentation I am concerned about, but more  
11 because I think it has a lot of requirement in it that goes  
12 beyond what is really needed for emergency purposes in terms  
13 of operator use.

14           But we need to get something out so that the  
15 industry can go with it. I am inclined to believe that we  
16 can work on 0696 at some future date, and integrate that  
17 with this requirement, and I would be inclined to encourage  
18 the release of the Reg. Guide with a few provisos.

19           One of those has to do with the matter of not  
20 going too fast with this off-site monitoring requirement,  
21 because it is clearly not as well defined as it ought to  
22 be. Secondly, I think some of the in-core instrumentation  
23 that has been talked about, the temperature monitoring needs  
24 to be understood a little bit better.

25           Thirdly, I personally think that some of the

1 purposes of the instrumentation go beyond the emergency.  
2 They are intended for the purpose of evaluating the plant  
3 later on, and even though that is not said directly, I think  
4 some of it is being used that way, and I would like to  
5 discourage that for the purpose of this Reg. Guide.

6 MR. PLESSET: Any other comment?

7 MR. MATHIS: I think that is a good summary.

8 MR. PLESSET: Chet, do you want to comment?

9 MR. SIESS: On the basis of what I have heard, I  
10 believe that the Committee is ready to recommend  
11 concurrence, with certain exceptions, and I have listed four  
12 things that we might comment on. One would be some comment  
13 regarding implementation, that the schedule consider that.  
14 I would expect some kind of comment on the environs exposure  
15 monitoring, and the cleanest thing would be to say, we agree  
16 with Denton, take the darn thing out and put it in some  
17 place later or put it in here later. That would be clean.  
18 I can write that paragraph.

19 The BWR thermocouples, if the staff eliminates the  
20 reference to the height, I think that might satisfy the  
21 Committee, and we would not have to say anything except, we  
22 have not seen the draft that has that out. We can make a  
23 reference to it. And if Dave were here, I am sure he would  
24 like to see us say something about reactor coolant system  
25 pressure, which in Revision 1, position C-3, was three times

1 the design pressure, and it has been reduced to 1.5 times  
2 the design pressure.

3 I would think the recommendation that we revert to  
4 what we had before be included in the letter with some  
5 comment about accuracy. As near as I can figure it out, in  
6 ANS 4.5, we are talking about an accuracy of 10 percent of a  
7 span. I am not quite sure if it is a single gauge that  
8 reads from zero to 3,000. I assume 10 percent of 3,000. If  
9 there are multiple gauges, that is what I think they mean by  
10 span, and from what Dave said, I think 10 percent, you know,  
11 the span probably would not bother anybody. We might  
12 mention that, or we can just ignore it.

13 MR. BENDER: If it is recommended that the range  
14 be increased, I would like to take exception to it and put  
15 some remarks in to the intent that --

16 MR. SIESS: That is your privilege.

17 MR. SHEWMON: We might even put Dave's motion to a  
18 vote.

19 MR. SIESS: That would be appropriate when we  
20 write the letter, I think. I will draft the letter. I will  
21 include a paragraph on coolant system pressure and  
22 implementation.

23 MR. RAMOS: Could I interrupt for just a second?

24 MR. SIESS: Go ahead.

25 MR. RAMOS: Dr. Siess, in your comment about the

1 high range, based on what Dr. Okrent said, as it is set up  
2 now in the technical support center, you are required to  
3 maintain a complete record tape of the -- all of the  
4 parameters for at least 30 minutes before the incident and  
5 then continuously throughout, so you can take that piece of  
6 data --

7 MR. SIESS: I am sorry. Are you talking about --  
8 What are you talking about?

9 MR. RAMOS: You are talking about wide-range  
10 instrumentation.

11 MR. SIESS: I am talking about reactor coolant  
12 system pressure instrumentation to be three times the design  
13 pressure rather than 1.5.

14 MR. RAMOS: Okay. I am saying --

15 MR. SIESS: If you don't have a gauge that reads  
16 three times, I don't care how many minutes you --

17 MR. RAMOS: I am saying you are going to get that  
18 information.

19 MR. SIESS: Where?

20 MR. RAMOS: In the TSC.

21 MR. SIESS: Not if the gauge stops at 1500, you  
22 don't.

23 MR. RAMOS: You take the raw data coming into a  
24 computer. All you do is display it on the CRT, and --

25 MR. SIESS: We are talking about the control room



1 operator. That we settled a few minutes ago. Not the TSC.  
2 And we agreed to that.

3 MR KERR: We are also talking about the  
4 instrument, not the display.

5 MR. SIESS: He is saying you compute it from other  
6 parameters.

7 MR. RAMOS: You can show it, display it, pulling  
8 it out and displaying it on a CRT because you have the raw  
9 data.

10 MR. SIESS: How do you get the pressure? What  
11 signal delivers the pressure?

12 MR. RAMOS: I think it is the --

13 MR. SIESS: The only question is the range, not  
14 where you display it.

15 MR. PLESSET: Do you have something?

16 MR. COLEY: My name is Bill Coley. I am  
17 representing the AIF working group. Yesterday, in a  
18 presentation in which we related to the similarity and the  
19 parallelism of Reg. Guide 1.97 and NUREG-0696, yesterday, we  
20 encouraged that 1.97 identify which parameters are monitored  
21 in which facilities.

22 The subject is not really that simple, though,  
23 because there are direct equipment qualification  
24 contradictions between 1.97 and the current version of 0696,  
25 which means that as a utility, I would implement 1.97 and

1 then later go back and tear some of that out to meet the  
2 requirements of 0696.

3           There also is a basic contradiction between the  
4 two documents, in that 1.97 encourages the use of normal  
5 instrumentation; NUREG-0696 discourages the use of normal  
6 instrumentation.

7           MR. SIESS: I think those comments are covered by  
8 the proposal I made that we recommend there be no  
9 implementation until they are settled on all the uses of  
10 these instruments.

11           MR. COLEY: Yes, sir, Dr. Siess. This is, I  
12 guess, a summary we wanted to make rather than the unholy  
13 alliance that we suggested between the Commission and the  
14 industry, is that this would probably be a very good way for  
15 the industry and the Commission to get these facilities in  
16 operation to make sure they were in concert with each other,  
17 and to make sure we did put in the safety improvements in  
18 the plant as soon as possible, and I think that would be an  
19 excellent approach.

20           MR. PLESSET: Okay. Well, thank you.

21           Chet, why don't you go on?

22           MR. SIESS: I can draft the paragraphs on the  
23 pressure implementation. I can draft one on environs  
24 exposure monitoring, if it says delete it. I think I can  
25 cover them all, at least for a first shot.

1 MR. PLESSET: The question of the span, I think  
2 that could be settled by --

3 MR. SIESS: I would not -- if my interpretation of  
4 span is right, I am satisfied.

5 MR. PLESSET: I was talking about whether -- the  
6 range, I should have said.

7 MR. SIESS: That is the coolant system pressure.  
8 There will be a paragraph in there. You can take it out if  
9 you like.

10 MR. MOELLER: I don't really understand completely  
11 the negative response to the environs monitoring, because if  
12 we are looking for instruments to help the operator know  
13 what is going on to follow the course of the accident, they  
14 certainly could help confirm whether there has been a major  
15 environmental release.

16 MR. KERR: Our negative response is not to environs  
17 monitoring, which I think is necessary, but to the fact -- I  
18 don't think enough thought has been given to this yet to  
19 incorporate it into a Reg. Guide.

20 MR. SIESS: In the past, I thought we were relying  
21 on monitoring crews out with portable instrumentation, and  
22 isoplats, and tower readings, et cetera. The scenario Mr.  
23 Kreeger described was the first half-hour or hour or  
24 whatever before those people are there, he wants the  
25 operator to have something special.

1           Now, I am still not convinced that 32 to 40, which  
2 is twice 16 to 20, and feeding everything into the computer,  
3 is going to distinguish between a ground level release and a  
4 high plume -- I can't follow it all, but it seems to me the  
5 staff is not in that complete agreement.

6           We did not ask the staff yesterday. We should ask  
7 them today whether there are any differing professional  
8 opinions. I should not use that term, because a differing  
9 professional opinion is a formal designation now, according  
10 to the regulations.

11           MR. MOELLER: I think we have to keep separate the  
12 emergency planning side and what we are supposed to be doing  
13 here.

14           MR. SIESS: That was one of the suggestions  
15 yesterday, that they take that out and put it in as part of  
16 the emergency plan.

17           MR. MOELLER: In his review of the differing  
18 professional opinions, could he comment on this particular  
19 subject?

20           MR. SIESS: We had one between Denton and Case,  
21 but that is not really differing --

22           (General laughter.)

23           MR. SIESS: At that level, I don't think they  
24 classify it --

25           MR. ROSENTHAL: On the peasant level --

(General laughter.)

2 MR. PLESSET: That is what we want.

3 MR. ROSENTHAL: There were several people who felt  
4 that the technology problems getting a meaningful signal at  
5 a reasonable cost precluded including this device in the  
6 Reg. Guide. There were others who felt that it was an  
7 important parameter and admitted that we did know how to do  
8 it but felt it was sufficiently desirable that we should  
9 have some indication of it in the Reg. Guide, in part  
10 because the Reg. Guide carries more persuasion or persuasive  
11 force than some other documents we might use.

12 MR. PLESSET: Okay. Well, thank you very much.

13 MR. SIESS: Very well put. Very well put.

14 MR. PLESSET: Yes, and we appreciate it.

15 MR. SIESS: It sounds like Denton versus Case.

16 (General laughter.)

17 MR. SIESS: Mr. Chairman, I am through.

18 Are you sure you don't want to quit while you are  
19 ahead?

20 MR. HINTZE: If you think I am ahead, yes.

21 (General laughter.)

22 MR. PLESSET: I think you are relatively ahead,  
23 yes.

24 MR. HINTZE: I just wanted to mention that if you  
25 take it out of the guide, you are eliminating one of the

1 areas of scope which we had in the guide, and that was to  
2 detect a breach of containment to keep the operator informed  
3 of that.

4 MR. PLESSET: Okay.

5 MR. HINTZE: Just keep that in mind when you make  
6 your decision.

7 MR. PLESSET: The Japanese had this kind of  
8 system. They already have this.

9 MR. SIESS: You can get that without a breach of  
10 containment, can't you?

11 MR. HINTZE: That is true. If the staff monitor  
12 has nothing, then you know nothing is happening.

13 MR. KERR: Do these have these monitors --

14 MR. PLESSET: They have a monitor. It is made in  
15 Japan. That is what it says on it.

16 (General laughter.)

17 MR. FRALEY: They have a panel in the control room  
18 that reads several off-site monitors and alarms.

19 MR. SIESS: Somebody mentioned yesterday that if  
20 the thing had really worked -- this was from the industry --  
21 that they were trying to figure a way to use it to monitor  
22 for Appendix I releases.

23 MR. PLESSET: Is that what you were going to say?

24 MR. SCARAPA: Yes.

25 MR. PLESSET: Can you be as succinct as Dr. Siess?

1           MR. SCARAPA: My name is Joy Scarapa. The systems  
2 that you are talking about are installed in Japan. Six  
3 utilities -- six utilities will be installing these in the  
4 next few months in the United States for emergency planning  
5 as well as for Appendix I levels. This would be a range of  
6 one micro r to ten r. So, it would cover the original range  
7 you had at Reg. Guide 1.97 of 10<sup>-6</sup> up to 10 r.

8           This would be with activating alarms and computer  
9 printout and diagnostics as an on-line continuous system, so  
10 they will be installed at Indian Point, TMI, Diablo Canyon,  
11 one foreign reactor and the reactors in Illinois.

12           MR. MARK: That is the range now wanted in 1.97?

13           MR. SCARAPA: Yes. That is what our system can do.

14           MR. MARK: The background is?

15           MR. SCARAPA: Typical background levels with our  
16 unit is about 10 micro r per hour, which would go to 120 per  
17 year.

18           MR. WARD: How are the sensors arranged around the  
19 plant?

20           MR. SCARAPA: It varies with the utility, and they  
21 have elected based on their geography and wind direction in  
22 some cases 16 sensors in 22 and a half degree quadrants.  
23 Others only ten, like Diablo Canyon, because they are on the  
24 ocean. They have not monitored the ocean, but have it along  
25 the coastline, so that the wind does shift.

1           If people in San Luis Obispo -- there is a warning  
2 if the level is exceeded, and it has alarm levels that can  
3 be adjusted by the operator.

4           So, in that sense, you consider anywhere from a  
5 background of 10 r -- you can set it at any level, depending  
6 on the utility.

7           MR. WARD: The plant boundary?

8           MR. SCARAPA: Yes. Some go out to ten miles.  
9 Some go out to site boundary.

10          MR. BENDER: Can I ask one question? Have you  
11 looked at the SAI report?

12          MR. SCARAPA: Yes, we were visited by SAI to  
13 evaluate our system as a viable system for making this type  
14 of measurement. I have only heard comments about the SAI  
15 report. I have not received a copy.

16          MR. BENDER: It would be useful to know whether  
17 your instrument can do something that is more than --

18          MR. SCARAPA: They brought out some points about  
19 the placement of the sensors and the number of sensors --

20          MR. PLESSET: I don't think we want to pursue this  
21 any more. Thank you very much. We appreciate the little  
22 sales pitch or whatever.

23          Chet, are you satisfied?

24          MR. SIESS: I am through.

25          MR. PLESSET: I guess we can then take a break, a



1 short one, and come back for further labors.

2 (Whereupon, a brief recess was taken.)

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

\_\_\_\_\_

in the matter of: ACRS - 247TH GENERAL MEETING

Date of Proceeding: November 7, 1980

Docket Number: \_\_\_\_\_

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Davis S. Parker

\_\_\_\_\_  
Official Reporter (Typed)



\_\_\_\_\_  
(SIGNATURE OF REPORTER)

POOR ORIGINAL

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the  
Advisory Committee on Reactor Safeguards 247TH GENERAL MEETING  
in the matter of:

Date of Proceeding: November 7, 1980

Docket Number: \_\_\_\_\_

Place of Proceeding: Washington, D.C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Ann Riley

Official Reporter (Typed)

ANN RILEY

*Ann Riley*

Official Reporter (Signature)

MDC FUNCTIONAL REQUIREMENTS FOR  
NUCLEAR POWER PLANT EMERGENCY FACILITIES

- SAFETY PARAMETER DISPLAY SYSTEM (SPDS)
- TECHNICAL SUPPORT CENTER - ONSITE (TSC)
- EMERGENCY OPERATIONS FACILITY - NEARSITE (EOF)
- NUCLEAR DATA LINK (NDL)

## EMERGENCY RESPONSE FACILITIES

SYSTEM	LOCATION	TIME OF OPERATION	PRIME USERS	MINIMUM DATA REQUIREMENTS	PRIMARY FUNCTIONS
SPDS	CONTROL RM.	CONTINUOUS	REACTOR OPERATORS	SUBSET OF RG 1.97	<ul style="list-style-type: none"> <li>- MONITOR SAFETY STATUS OF IMPORTANT PLANT SYSTEMS</li> <li>- DISPLAY OVERALL SAFETY STATUS</li> <li>- PROVIDE ALERT (SIGNAL) IF ANY SAFETY PARAMETER APPROACHES AN UNSAFE CONDITION</li> </ul>
TSC	NEAR CONTROL ROOM	DURING EMERGENCY & RECOVERY OPERATIONS	LICENSEE MGT. & TECHNICAL SUPPORT STAFF/ NRC SITE TEAM	RG 1.97	<ul style="list-style-type: none"> <li>- PLANT MGT. &amp; TECH. SUPPORT FOR CONTROL ROOM</li> <li>- ADDITIONAL INFO SOURCE FOR EOF &amp; NRC</li> <li>- EOF FUNCTIONS UNTIL EOF IS STAFFED</li> </ul>
EOF	NEAR REACTOR (1-3 MILES)	DURING EMERGENCY & RECOVERY	LICENSEE MGT. & TECHNICAL SUPPORT STAFF/ NRC SITE TEAM PLUS STATE OFFICIALS & OTHER FEDERAL AGENCIES	RG 1.97	<ul style="list-style-type: none"> <li>- OVERALL MGT. OF LICENSEE EMERGENCY RESPONSE RESOURCES</li> <li>- COORDINATE &amp; EVALUATE ACTIONS HAVING POTENTIAL ENVIRONMENTAL IMPACT</li> <li>- COORDINATE WITH LOCAL, STATE &amp; FEDERAL AGENCIES</li> <li>- PUBLIC INFORMATION</li> </ul>
NDL	NRC HQS	CONTINUOUS	NRC EMERGENCY MGT. TEAM & TECH. STAFF	SUBSET OF RG 1.97	<ul style="list-style-type: none"> <li>- MONITOR &amp; INDEPENDENTLY ASSESS</li> <li>- ADVISE LICENSEE</li> <li>- PROVIDE PUBLIC INFORMATION</li> </ul>

POOR ORIGINAL




Figure 1  
Functional Block Diagram of Data Flow.

MONITORS FOR HYDROGEN AND OXYGEN  
BACKGROUND


1. 10 CFR 50.44 AND TECHNICAL SPECIFICATIONS
  - . LIMITS HYDROGEN CONCENTRATION TO 4% IN NON-INERTED CONTAINMENTS;
  - . LIMITS OXYGEN CONCENTRATION TO 4-5% IN INERTED CONTAINMENTS.
  
2. THE ACTION PLAN
  - . ITEM II.B.7 RESULTED IN SECY 80-107
  - . ITEM II.B.8 CALLS FOR RULEMAKING PROCEEDINGS ON DEGRADED AND MELTED CORES
  - . ITEM II.F.1.6 REQUIRES HYDROGEN MONITORS
  
3. INDUSTRY FEEDBACK
  - . HYDROGEN MONITORS THAT HAVE RANGE BEYOND 10% ARE NOT READILY AVAILABLE
  - . ACCURACY IS DEGRADED AS RANGE IS INCREASED
  - . RESPONSE TIME TENDS TO BE SLOW

REGULATORY GUIDE 197 PROVISIONS

<u>CONTAINMENT TYPE</u>	<u>H<sub>2</sub> RANGE</u>	<u>O<sub>2</sub> RANGE</u>	<u>REMARKS</u>
PWR - DRY	0 - 10%	-	
PWR - ICE	0 - 30%	-	NEED H <sub>2</sub> MITIGATION
BWR - MK I	0 - 30%	0 - 10%	INERTED
BWR - MK II	0 - 30%	0 - 10%	INERTED
BWR - MK III	0 - 30%	-	NEED H <sub>2</sub> MITIGATION



# VOLUME % HYDROGEN IN CONTAINMENT VS % METAL-WATER REACTION



### INTERACTION CRITERIA

1. SOURCE AND TARGET CONTACT
2. FLUID LEAKAGE
3. ELECTRICAL ANAOMALY
4. ENVIRONMENTAL EFFECTS
5. SECONDARY OR CHAIN INTERACTION

ONSITE (INITIAL) EVALUATION

1. WHETHER OR NOT INTERACTION OCCURS
2. INTERACTION OCCURS BUT NO SAFETY  
FUNCTION IMPAIRED
3. RECOMMEND A MODIFICATION
4. RECOMMEND FURTHER EVALUATION

### INDEPENDENT AUDIT

- PERFORMED SAMPLING WALKDOWN
- AUDITED TEAM WALKDOWNS
- PERFORMED ANALYSIS
- DOCUMENT REVIEW
- REVIEWED COMPLETED MODIFICATIONS