

INTERIM REPORT

Accession No. _____

Contract Program or Project Title:

LWR Pressure Vessel Irradiation Surveillance Dosimetry Program

Subject of this Document:

LWR Pressure Vessel Irradiation Surveillance Dosimetry Program

Type of Document:

Bi-Monthly Status Letter

Author(s):

C. C. Preston & W. N. McElroy

Date of Document:

August 21, 1980

Responsible NRC Individual and NRC Office or Division:

C. Z. Serpan, Jr., Chief
Metallurgy & Materials Research Branch
Division of Reactor Safety Research

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

Prepared for
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

INTERIM REPORT

8011180 079

8052960

August 21, 1980

Mr. Charles Z. Serpan, Jr., Chief
Metallurgy & Materials Research Division
Office of Nuclear Regulatory Research
Nuclear Regulatory Commission
Washington, DC 20555

**JUNE-JULY BI-MONTHLY STATUS LETTER: LWR PRESSURE VESSEL IRRADIATION
SURVEILLANCE DOSIMETRY PROGRAM**

The objective of this program is to make measurements in neutron fields ["Benchmark" and reactor "Test and Surveillance Regions"] for the subsequent validation/calibration of available state-of-the-art data and dosimetry, damage correlation, and the associated reactor analysis procedures used for predicting the integrated effect of neutron exposure for light-water reactor [LWR] pressure vessel [PV] steel test irradiation and surveillance programs. The task includes selection of the neutron fields, the validation/calibration of dosimetry and damage exposure and correlation procedures in these fields, and the establishment of a set of seventeen ASTM recommended standard practices, guides, and methods, Figures 1 and 2.

PROGRAM REVIEW AND DEFINITION

Work was started on the preparation of the NRC LWR-PV Surveillance Dosimetry Improvement Program report for the NRC 8th Research Information Meeting, October 27-31, 1980 at National Bureau of Standards. An expanded version of this document is also being prepared for the NRC 1980 Annual Report (this report will also serve as the NRC program quarterly progress report for July-September 1980).

The Emulsion Scanning Processor (ESP) an interactive computer-controlled microscope system for scanning proton tracks in emulsions has been checked out and is now fully operational. Data collection rates are about 250 tracks/day using a team of about eight trained scanners. Hence, a complete neutron spectral measurement, constituting about 10,000 tracks, takes 2-3 months. Different techniques to increase the data collection rates are under consideration. The ESP system has been developed at HEDL in support of both FBR and LWR program work. It is currently being used for FBR measurements associated with the FFTF startup Reactor Characterization Program. Starting in FY81 it will be used in support of the LWR PCA Pressure Vessel Mockup studies.

The γ -spectrometer Janus probe and associated data acquisition system is continuing to be tested and improved for in- and ex-vessel reactor measurements in support of both FBR and LWR program work. Response function testing of the new Janus probe reveals adequate sensitivity up to about 6.2 MeV. Based on these results, gamma spectrometry with this probe is expected to extend up to the neighborhood of 7 MeV. Results of this calibration work are reported in a paper on "Continuous Gamma-Ray Spectrometry in the Fast Flux Test Facility" prepared by R. Gold, B. J. Kaiser, F. S. Moore, W. L. Bunch, W. N. McElroy, and E. M. Sheen for the September 14-17, 1980 ANS Topical Meeting on 1930 Advances in Reactor Physics and Shielding, Sun Valley, Idaho.

TASK A - NEUTRON FIELDS

PCA-PSF

All nuclear emulsions that were exposed in PCA have been processed. Scanning of these emulsions awaits a decision on the priority of the emulsion data in relation to other program work and the time (2 to 3 months) required for data analysis.

^{238}U fission rates have been remeasured using solid state track recorders in 13 PVS block locations in the PCA 8/7 configuration and the results have been reported. ^{232}Th fission rates for 13 block locations and 3 void box locations for both the 8/7 and 12/13 configurations have been previously reported along with mid-plane ^{237}Np and ^{235}U (bare and cadmium covered) fission rates.

The SSTR subcapsules from the PSF perturbation experiment have been retrieved and are ready for processing.

Crown's Ferry 3 (BWR)

SSTR dosimeters irradiated in BF-3 have finally arrived at HEDL. Processing of these BF-3 SSTR will not start until a review of GE and EPRI requests for this work have been received and evaluated, including accuracy requirements.

McGuire I (PWR)

A total of 28 dosimetry sets were prepared by the HEDL Reactor Dosimetry Center for irradiation in the McGuire reactor cavity. These sets are a maximum 3/4 inch in diameter and from 1/4" to 1" thick. They will be inserted on plates along with the dosimeters provided by IRT Corporation at 16 cavity locations (4 azimuthal positions with 4 axial positions each) and 4 outer positions. At one of the azimuthal cavity locations sets containing SSTR and Cd covered sets are included in addition to the standard set.

TASK B - RECOMMENDED ASTM STANDARDS

A revised draft of the "IA" ASTM Standard, "Analysis and Interpretation of Nuclear Reactor Surveillance Results", Figures 1 and 2, was prepared by S. Anderson of Westinghouse. This and the revised E706-80 draft of the "O" Master Matrix Guide of Figures 1 and 2 will be attached as Appendices to the FY80 NRC Program Annual Report.

TASK C - DAMAGE ANALYSIS AND CORRELATION

The re-analysis of the LWR power plant surveillance reports is continuing. The Table 1 re-analysis of nineteen Westinghouse reports for errors in reported exposure values has provided more reliable neutron exposure data for analyzing the reported shifts in the Charpy 30 ft. lb. transition temperature. Analysis of the shifts reported for the so-called "ASTM reference heat" of A302 steel shows that a simple law of the type $\Delta NDTT = f(c) \cdot (\phi t)^n$ fits the data as well as laws containing terms specifically introduced to account for annealing effects or rate effects. In the expression above, $f(c)$ is a function of chemical composition (e.g. A+B·Cu%) and ϕt is the fluence.

A HEDL statistical analysis of a large data base for evidence of errors in reported values of neutron fluence indicates that the errors in neutron fluence values, while important, do not constitute the major source of scatter in data relating irradiation induced shift in Charpy transition temperature to exposure and chemistry. However this analysis was based on the use of power reactor data for both development and application of the laws relating Charpy shift to neutron exposure and chemistry. The intermixture of test reactor data with power reactor data can be expected to add to the importance of correct procedures in calculating neutron exposure. Additionally, the magnitude of scatter is not the sole measure of merit in considering the effect of errors in dosimetry, as the laws derived from faulty data not only have a slightly larger scatter, but incorrect values for the fitting constants. A HEDL study has also shown that when a more complicated fitting formula is used which includes a saturation term, the standard deviation of the fit does not improve, but the saturation time constant is a realistic 7 years. Extrapolation to a 30 year exposure using the more complete formula shows typically a 20% reduction in the 30 ft. lb. Charpy temperature shift compared to the shift predicted by the more simple formulation which does not explicitly contain a saturation term.

Cooperative work with EPRI aimed at analyzing a data bank collected by EPRI has been delayed pending receipt of EPRI data tapes. The tapes contain chemistry and Charpy test information placed on the tapes by Fracture Control Corporation, an EPRI contractor in Goleta, California.

Current plans for the dis-assembly of the 1st PSF "Simulated Surveillance Capsule" metallurgical irradiation package at Oak Ridge is scheduled for early September 1980.

C. C. Preston
C. C. Preston
Irradiation Environment

CONCURRENCE:

W. N. McElroy
W. N. McElroy, Manager
Irradiation

Enclosures

LWR PRESSURE VESSEL IRRADIATION SURVEILLANCE

DOSIMETRY PROGRAM BI-MONTHLY STATUS LETTER

DISTRIBUTION LIST

U. S. DEPARTMENT OF ENERGY

FFTF Project Office

A. R. DeGrazia
T. King

Reactor Research & Technology

Chief, Reactor Physics Branch
J. W. Lewellen, Reactor Physics
Branch

CEN/SCK-MOL, BELGIUM

J. Debrue
A. Fabry

ELECTRIC POWER RESEARCH INSTITUTE

W. B. Lowenstein
T. U. Marston
O. Ozer
R. J. Rahn
K. Stahlkopf
H. H. Till

NATIONAL BUREAU OF STANDARDS

C. D. Bowman
R. S. Caswell
J. A. Grundl
C. E. Kuyatt
E. D. McGarry

NUCLEAR REGULATORY COMMISSION

Chief, Metallurgy & Materials
Research Branch
W. Morris
Public Document Room (3)

OAK RIDGE NATIONAL LABORATORY

F. B. K. Kam
R. E. Maerker
J. H. Swanks

WESTINGHOUSE

Advanced Reactors Division

G. W. Hardigg

Light Water Power Division

S. L. Anderson
J. J. Taylor

Research Division

R. Holland

HANFORD ENGINEERING DEVELOPMENT LABORATORY

H. J. Anderson	W/C-39
R. A. Bennett	W/B-43
L. D. Blackburn	W/A-40
D. G. Doran	W/A-57
R. Gold	W/C-39
G. L. Guthrie	W/C-39
B. R. Hayward	W/A-62
J. J. Holmes	W/A-58
L. A. James	W/A-40
R. L. Knecht	W/A-40
J. J. Laidler	W/JAD-8
E. P. Lippincott	W/C-39
W. N. McElroy (4)	W/C-39
R. P. Omberg	W/F420
R. E. Peterson	W/E-18
C. C. Preston	W/C-39
W. E. Roake	W/C-16
F. A. Scott	W/C-37
T. A. Strom	W/A-21
J. A. Williams	W/A-40
H. H. Yoshikawa	W/A-62
Correspondence (2)	W/C-123

DOCUMENT CLEARANCE REQUEST

(DO NOT USE FOR SPEECHES AND ARTICLES)
AUTHOR COMPLETES PART 1 AND SUBMITS WITH TWO (2)
COPIES OF DOCUMENT TO DOCUMENT CLEARANCE.

IDENTIFICATION NO.

COST CODE

WORK ORDER NO.

TITLE

AUTHOR(S)

NAME

PHONE

DISTRIBUTION:

☐ TID - 4500 CATEGORY☐ OTHER

DATE CLEARANCE REQUIRED

AUGUST 25, 1970

CONTRACT NUMBER

HEDL 6017-70FF0017

DOES THIS DOCUMENT CONTAIN OR DISCLOSE ANY OF THE FOLLOWING? (IF YES, IDENTIFY THE INFORMATION AND LOCATION IN DOCUMENT)

1. APPLIED TECHNOLOGY?

☐ NO ☐ YES

2. COPYRIGHTED MATERIAL?

☐ NO ☐ YES-IDENTIFY

(B) HAS PERMISSION BEEN GRANTED?

☐ NO ☐ YES

3. (A) NEW OR NOVEL (PATENTABLE) SUBJECT MATTER?

☐ NO ☐ YES-IDENTIFY

(B) HAS DISCLOSURE BEEN SUBMITTED BY HEDL OR OTHER COMPANY?

☐ NO ☐ YES-DISCLOSURE NO(S).4. INFORMATION RECEIVED FROM A FOREIGN COUNTRY UNDER AN
EXCHANGE AGREEMENT?☐ NO ☐ YES-IDENTIFY5. INFORMATION RECEIVED FROM OTHERS IN CONFIDENCE, SUCH AS
PROPRIETARY DATA, TRADE SECRETS AND/OR INVENTIONS?☐ NO ☐ YES-IDENTIFYI HAVE REVIEWED THE ATTACHED DOCUMENT AND CERTIFY THE INFORMATION CONTAINED THEREIN IS TECHNICALLY CORRECT,
REQUIRES NO FURTHER HEDL/ERDA TECHNICAL/POLICY REVIEW AND IS APPROPRIATE FOR DISTRIBUTION AS STATED ABOVE.

AUTHOR

SUPERVISOR

MANAGER

DATE

CLEARANCE REVIEW / APPROVAL SIGNATURES

HEDL LEGAL (INCLUDING PATENT AND COPYRIGHT) ☐ APPROVED ☐ DISAPPROVED☐ SEE REMARKS BELOW ☐ NO PATENTABLE PROPRIETARY OR
COPYRIGHTED MATTER NOTED.

LEGENDS REQUIRED:

☐ APPLIED TECHNOLOGY☐ PROPRIETARY INFORMATION☐ PATENT HOLD☐ PRELIMINARY INFORMATION☐ FOREIGN LIMITED INFORMATION

CLASSIFICATION

☐ APPROVED ☐ DISAPPROVED

PATENT-ERDA

☐ SEE REMARKS BELOW

ERDA

REFERENCES

☐ APPROVED ☐ DISAPPROVED☐ NOT CHECKED

REMARKS:

POOR ORIGINAL

FOR DOCUMENT CLEARANCE USE ONLY

DATE REQUEST RECEIVED

CLEARANCE APPROVAL

DISTRIBUTION APPROVAL


426 DATE

☐ TIC ☐ 6A ☐ 7A☐ NO TIC ☐ 6X ☐ 7B

BY

DATE

FIGURE 1. INTERRELATIONSHIPS FOR
ASTM STANDARDS FOR SURVEILLANCE
OF NUCLEAR REACTOR PRESSURE VESSELS



RECOMMENDED E10 ASTM STANDARDS

I. MASTER MATRIX GUIDE TO I, II, III

II. METHODS OF SURVEILLANCE AND CORRELATION PRACTICES

A. ANALYSIS AND INTERPRETATION OF NUCLEAR REACTOR SURVEILLANCE RESULTS

B. SURVEILLANCE TESTS FOR NUCLEAR REACTOR VESSELS (4)

C. EXTRAPOLATING REACTOR VESSEL SURVEILLANCE RESULTS

D. CHARACTERIZING NEUTRON EXPOSURES IN FERRITIC STEELS IN TERMS OF DISPLACEMENTS PER ATOM, INCLUDING ASTM E107/A DPA FILE

E. DAMAGE CORRELATION FOR REACTOR VESSEL SURVEILLANCE

III. SUPPORTING METHODOLOGY GUIDES

A. APPLICATION OF MULTIPLE SENSOR FLUX FLUENCE SPECTRAL DETERMINATION CODES

B. APPLICATION OF ASTM E107/A CROSS SECTION AND ERROR FILE

C. SENSOR SET DESIGN AND IRRADIATION FOR REACTOR VESSEL SURVEILLANCE

D. APPLICATION OF NEUTRON TRANSPORT METHODS FOR REACTOR VESSEL SURVEILLANCE

E. BENCHMARK TESTING OF REACTOR NEUTRON DOSIMETRY

F. CORRELATION OF Δ NOTT WITH FLUENCE (4)

III. SENSOR MEASUREMENTS METHODS

A. ANALYSIS OF RADIO-METRIC MONITORS FOR REACTOR VESSEL SURVEILLANCE


B. ANALYSIS OF SOLID STATE TRACK RECORDER (SSTR) MONITORS FOR REACTOR VESSEL SURVEILLANCE

C. ANALYSIS OF HELIUM ACCUMULATION FLUX-FLUENCE (HAFM) MONITORS FOR REACTOR VESSEL SURVEILLANCE

D. ANALYSIS OF DAMAGE MONITORS FOR REACTOR VESSEL SURVEILLANCE

E. ANALYSIS OF TEMPERATURE MONITORS FOR REACTOR VESSEL SURVEILLANCE

* AN ASTERISK INDICATES THAT THE LEAD RESPONSIBILITY IS WITH SUBCOMMITTEE E10.02 INSTEAD OF WITH SUBCOMMITTEE E10.05.



HEDL 8002-267.2

Figure 2. Schedule for the preparation of ASTM Standards for Surveillance of Nuclear Reactor Pressure Vessels.

POOR ORIGINAL

TABLE 1
RE-EVALUATED EXPOSURE VALUES FOR SURVEILLANCE CAPSULES

Reactor	Unit	Capsule	old $\phi t > 1$	new $\phi t > 1$	Ratio new/old	dpa	Ratio dpa/ ϕt new	D_{ϕ}	A302B ΔT Correlation Monitor ($^{\circ}F$)	time(sec)
Turkey Point	4	S	1.25+19	1.81+19	1.45	.032	1.77-21	2.96-10	115*	1.084+8
"	4	T	6.05+18	8.57+18	1.42	.0140	1.62-21	3.66-10	100	3.840+7
"	3	S	1.41+19	1.99+19	1.40	.0350	1.77-21	3.14-10	135	1.114+8
"	3	T	5.68+18	6.44+18	1.13	.0123	1.90-21	3.99-10	82	3.094+7
H. B. Robinson	2	S	3.2+18	5.09+18	1.59	.00936	1.83-21	2.14-10	80	4.385+7
"	2	V	4.51+18	7.76+18	1.72	.0137	1.77-21	1.29-10	105	1.061+8
Praire Island	1	V	5.21+18	6.29+18	1.21	.0109	1.73-21	2.51-10	---	4.350+7
"	2	V	5.49+18	7.18+18	1.31	.0122	1.70-21	2.74-10	---	4.454+7
Point Beach	1	S	---	9.52+18	--	.0157	1.65-21	1.35-10	---	1.163+8
"	1	R	2.22+19	2.69+19	1.21	.0442	1.64-21	2.71-10	110	1.632+8
R. E. Ginnea	1	R	7.60+18	1.33+19	1.75	.0247	1.86-21	2.87-10	---	8.628+7
"	1	V	5.32+18	6.91+18	1.30	.0110	1.84-21	2.80-10	90	3.923+7
Kewaunee		V	5.59+18	7.23+18	1.29	.0123	1.71-21	2.96-10	---	4.167+7
San Onofre	1	A	1.20+19	1.48+19	1.23	.0310	2.04-21	5.30-10	115	5.846+7
"	1	D	2.36+19	4.98+19	2.11	.0887	1.78-21	9.95-10	150	8.914+7
Point Beach	2	T	9.45+18	1.02+19	1.08	.0170	1.67-21	1.55-10	105*	1.098+8
"	2	V	4.74+18	7.71+18	1.63	.0127	1.65-21	2.61-10	90*	4.859+7
Conn. Yank.		A	2.08+18	2.85+18	1.37	.00516	1.81-21	9.59-11	85	5.377+7
"		F	4.04+18	5.54+18	1.37	.00977	1.76-21	1.26-10	80	7.728+7
Average					1.42					

*A533B Steel

1. REPORT NUMBER	Obtain in advance from Division of Document Control.	NRC FORM 426 (6-76) NRCM 3201	U.S. NUCLEAR REGULATORY COMMISSION
2. DISTRIBUTION CATEGORY NO.	Insert appropriate number from the NRC Distribution Category List	PUBLICATIONS RELEASE FOR UNCLASSIFIED FORMAL NRC STAFF, CONSULTANT, AND CONTRACTOR REPORTS	
3. TITLE AND SUBTITLE (State in full as shown on document.) June-July Bi-Monthly Status Letter: LWR Pressure Vessel Irradiation Surveillance Dosimetry Program			
4. AUTHORS (If more than three, name first author followed by "and others.") C. C. Preston and W. N. McElroy			
5. ORGANIZATIONAL UNIT (If contract, give organizational unit of author to whom inquiries may be addressed.)			
OFFICE/DIVISION HEDL	BRANCH/UNIT Applied Systems Development/ Technology/Mat'l's Tech/Irr. Tech/Irr. Env	TELEPHONE NO. 444-3791(FTS)	
6. REPORT DATE(S) August 21, 1980		BASIS FOR EACH DATE (e.g. date manuscript submitted; date manuscript published.) Report Period: Letter Date	
7. CONTRACT NUMBER DE-AC14-76FF02170 and NRC Service Contract TV 176		8. NAME OF NRC PROGRAM SPONSOR FOR CONTRACT C. Z. Serpan, Jr.	TELEPHONE NO. 427-4262
9. TYPE OF DOCUMENT ("X" one)			
<input type="checkbox"/> a. REGULATORY REPORT (e.g. Environmental Impact Statement, Safety Evaluation Report, etc.) <input checked="" type="checkbox"/> b. TECHNICAL REPORT <input type="checkbox"/> c. CONFERENCE PAPER (1) TITLE OF CONFERENCE: _____ (2) DATE(S) OF CONFERENCE: _____ (3) LOCATION OF CONFERENCE: _____ <input type="checkbox"/> d. OTHER (Indicate type of item, e.g. thesis, translation, guide, etc.): _____			
10. RECOMMENDED DISTRIBUTION ("X" one) (If reproduced by Contractor, send all copies to the Division of Document Control for distribution.)			
<input type="checkbox"/> a. STANDARD DISTRIBUTION AND NTIS SALE { Document may be distributed to Distribution Category identified in Item 2, above, and to the NTIS for sale to the public.			
<input checked="" type="checkbox"/> b. OTHER: { Specify special instructions such as "Make available only as specifically approved by program office," "Send to attached addressees in addition to standard distribution," etc. Such request must be justified. Continue on reverse or separate sheet if necessary.			
11. ADDITIONAL INFORMATION AND REMARKS (Use this space if necessary to expand on answers given above. Continue on reverse or separate sheet.)			
12. OELD CLEARANCE		13. SUBMITTED BY:	
Forward completed, signed NRC Form 426 together with the related document for review. TO: Patent Counsel Office of Executive Legal Director		a. NAME OF HEAD OF ORGANIZATIONAL UNIT (type or print) W. N. McElroy W. N. McElroy 8/20/80	
<input type="checkbox"/> a. PATENT CLEARANCE GRANTED. <input type="checkbox"/> b. PATENT CLEARANCE NOT GRANTED.		b. ORGANIZATIONAL UNIT Irradiation Technology	
c. PATENT COUNSEL'S SIGNATURE		c. DIVISION Irradiation Environment	
d. DATE:		d. SIGNATURE (NRC responsible staff member.)	
e. DATE:		e. DATE:	