



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 REGION III
 799 ROOSEVELT ROAD
 GLEN ELLYN, ILLINOIS 60137

T19

SEP 29 1980

RECEIVED DISTRIBUTION SERVICES UNIT
 1980 NOV 7 PM 12 32
 US NRC
 DISTRIBUTION SERVICES
 BRANCH

Docket No. 50-483

Union Electric Company
 ATTN: Mr. John K. Bryan
 Vice President - Nuclear
 Post Office Box 149
 St. Louis, MO 63166

Gentlemen:

This refers to the inspection conducted by Messrs. R. B. Landsman and J. Schapker of this office on August 18-28, 1980, of activities at the Callaway Plant, Unit 1, authorized by NRC Construction Permit No. CPPR-139 and to the discussion of our findings with Mr. W. H. Weber and others of your staff at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

During this inspection, certain of your activities appeared to be in non-compliance with NRC requirements, as described in the enclosed Appendix A.

This notice is sent to you pursuant to the provisions of Section 2.201 of the NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations. Section 2.201 requires you to submit to this office within thirty days of your receipt of this notice a written statement or explanation in reply, including for each item of noncompliance: (1) corrective action taken and the results achieved; (2) corrective action to be taken to avoid further noncompliance; and (3) the date when full compliance will be achieved.

Concerning Item 2 of the enclosed Appendix A, in addition to responding to the item of noncompliance please discuss your program for establishing that all different gradations of the subject material meets your commitment of 95% of modified proctor contained in Section 2.5.4.5.1 of the Callaway PSAR.


In accordance with Section 2.790 of the NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter, the enclosures, and your response to this letter will be placed in the NRC's Public Document

8011180 379

SEP 29 1980

Room, except as follows. If the enclosures contain information that you or your contractors believe to be proprietary, you must apply in writing to this office, within twenty days of your receipt of this letter, to withhold such information from public disclosure. The application must include a full statement of the reasons for which the information is considered proprietary, and should be prepared so that proprietary information identified in the application is contained in an enclosure to the application.

Sincerely,



G. Fiorelli, Chief
Reactor Construction and
Engineering Support Branch

Enclosures:

1. Appendix A, Notice
of Violation
2. IE Inspection Report
No. 50-483/80-22

cc w/encls:

Mr. W. H. Weber, Manager
Nuclear Construction
Central Files
Reproduction Unit NRC 20b
PDR
Local PDR
NSIC
TIC
Regions I & IV
Ms. K. Drey
Mr. Ronald Fluegge, Utility
Division, Missouri Public
Service Commission