

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE: C O F S V 1; LICENSE NUMBER: 0 0 0 - 0 0 0 0 0 0 - 0 0 0; LICENSE TYPE: 4 1 1 2 0; CAT: 5

REPORT SOURCE: L; DOCKET NUMBER: 0 5 0 0 0 2 6 7; EVENT DATE: 1 0 1 7 8 0; REPORT DATE: 1 1 1 4 8 0

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

0 2 During valve lineup for a normal gas waste release, a valve was inadvertently left open which routed the release through an unsampled tank. Release of the contents of the unsampled tank is contrary to LCO 4.8.1 and is reportable per Fort St. Vrain Technical Specification AC 7.5.2(b)3. Previous unauthorized releases were reported as Reportable Occurrences 78-22 and 79-33 and Abnormal Occurrence 76-26. There was no effect on the health or safety of the public.

SYSTEM CODE: Z Z; CAUSE CODE: E; CAUSE SUBCODE: B; COMPONENT CODE: V A L V E X; COMP. SUBCODE: F; VALVE SUBCODE: D; LER NO: 8 0; SEQUENTIAL REPORT NO.: 0 6 3; OCCURRENCE CODE: 0 3; REPORT TYPE: L; REVISION NO.: 0; ACTION TAKEN: Z; EFFECT ON PLANT: Z; SHUTDOWN METHOD: ; HOURS: 0 0 0 0; ATTACHMENT SUBMITTED: Y; NPRD-4 FORM SUB: N; PRIME COMP. SUPPLIER: N; COMPONENT MANUFACTURER: N 4 2 5

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

1 0 A non-licensed operator inadvertently left a valve open while making valve lineup for an authorized gas waste release. The valve was left open because a broken valve stop prevented the valve from being closed. The release was terminated, the valve lineup corrected, and release completed via the normal flow path. Burst rupture disc and broken valve stop were replaced.

FACILITY STATUS: E; % POWER: 0 5 8; OTHER STATUS: N/A; METHOD OF DISCOVERY: A; DISCOVERY DESCRIPTION: Received Vacuum Tank Pressure Alarm

ACTIVITY RELEASED OF RELEASE: G; CONTENT: N; AMOUNT OF ACTIVITY: .017 curies total; LOCATION OF RELEASE: Reactor Building Exhaust Stack

PERSONNEL EXPOSURES: NUMBER: 0 0 0; TYPE: Z; DESCRIPTION: N/A

PERSONNEL INJURIES: NUMBER: 0 0 0; DESCRIPTION: N/A

LOSS OF OR DAMAGE TO FACILITY: TYPE: Z; DESCRIPTION: N/A

PUBLICITY ISSUED: N; DESCRIPTION: N/A

NAME OF PREPARER: J. W. [Signature]

PHONE: (303) 785-2224

8011180667