

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 I L Z I S 1 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 1 4 9

CON'T REPORT SOURCE 60 61 0 5 0 0 0 2 9 5 7 1 0 0 9 8 0 8 1 1 0 7 8 0 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 During normal operation passive failure gas monitor (LRT-DR15) kept
03 tripping off. The monitor was taken O.O.S. and shiftly gas samples
04 were pulled as required by T.S. 3.14.1.C. These samples showed no
05 abnormal activity. There were no safety implications and the health
06 and safety of the general public were not affected.

09 SYSTEM CODE M C 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE C K T B R K 14 COMP. SUBCODE E 15 VALVE SUBCODE Z 16
17 LER/RO REPORT NUMBER 8 0 EVENT YEAR 8 0 SEQUENTIAL REPORT NO. 0 4 6 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0
ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER R 1 0 2 1

CAUSE DESCRIPTION AND CORRECTIVE ACT
10 The limit switch had burned due to loose contacts. A new valve actuator
11 (Raymond Controls P/N MA 8-2) was installed and properly connected. The
12 monitor was returned to service with no further problems. This is the
13 first incident of this occurrence and no further action is necessary.

15 FACILITY STATUS E 28 % POWER 0 9 9 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32
16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
17 PERSONNEL EXPOSURES 0 0 0 37 Z 38 DESCRIPTION NA 39
18 PERSONNEL INJURIES 0 0 0 40 DESCRIPTION NA 41
19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 PUBLICITY ISSUED DESCRIPTION NA 45 8011180 723 NRC USE ONLY (312) 746-2084 X-238
Rock E. Aker

POOR ORIGINAL