REGULATONI DUGALI THE OUT .

Distribution: Docket OELD NRC PDR OI&E (3) ACT 2 9 1980 Local PDR NSIC ORB Reading TERA NRR Reading ACRS (16) -DEisenhut RPurple Docket No. 50-271 TNovak 5 RTedesco WICH S GLainas JRoe Mr. Robert L. Smith JHeltemes, AEOD 5 Licensing Engineer TIppolito 101 Vermont Yankee Nuclear Power SNorris Corporation VRooney 25 Research Drive Westboro, Massachusetts 01581

Dear Mr. Smith:

This letter is in response to your request for an exemption from Appendix J of May 8, 1980. You had requested an exemption from the testing requirements specified in Paragraph III.A.6(b) of Appendix J to 10 CFR 50 which states that if two consecutive Type A tests (integrated leak rate tests of the containment vessel) fail to meet the acceptance criteria, then a Type A test shall be performed at each refueling outage or at intervals of approximately 18 months, whichever occurs first, until two consecutive Type A tests meet the acceptance criteria.

We understand that following the failure of the 1978 Type A test at Vermont Yankee you developed a Corrective Action Plan which focused attention on the cause of previous test failure. The specific exemption requested would exempt you from performing the 1980 Type A test citing the successful completion of the 1979 test and the Corrective Action Plan as a basis.

Based on our evaluation of your request, we have concluded that insufficient justification has been provided for granting the requested exemption and your request is denied. Our conclusion takes into account the considerable reliance we place on Type A tests to provide assurance of containment vessel leak tightness - particularly during the interim period until we have completed our review of your Type B and C test program and resolved all pertinent issues.

This information was previously discussed with your representatives by telephone on September 16, 1980 by Vernon Rooney, Project Manager for Vermont Yankee.

Sincerely,

Original Signed 3%

Thomas A. Ippolito, Chief Operating Reactors Branch No. 2 Division of Licensing

ORB #2 VRooney: kf 10/2430

AD:SA GCLainas 10A1/80

ORB 12 TANDOIMO 10/28/30

8011190701

Mr. Robert L. Smith

. .

- 2 -

October 29, 1980

cc: Mr. W. F. Conway Vice President and Manager of Operations Vermont Yankee Nuclear Power Corporation P. O. Box 157 Vernon, Vermont 05602

Mr. Louis H. Heider, V.P. Vermont Yankee Nuclear Power Corporation 25 Research Drive Westboro, Massachusetts 01581

John A. Ritscher, Esquire Ropes & Gray 226 Franklin Street Boston, Massachusetts 02110

Laurie Burt Assistant Attorney General Environmental Protection Division Attorney General's Office One Ashburton Place, 19th Floor Boston, Massachusetts 02108

Ronald J. Wilson 810 18th Street, N. W. Suite 802 Washington, D. C. 20006

Honorable M. Jerome Diamond Attorney General State of Vermont 109 State Street Pavilion Office Building Montpelier, Vermont 05602

Mr. J. E. Griffin, President Vermont Yankee Nuclear Power Corporation 77 Grove Street Rutland, Vermont 05701

Vermont Yankee Decommissioning Alliance 127 Main Street Brattleboro, Vermont 05301 John R. Stanton, Director Radiation Control Agency Hazen Drive Concord, New Hamoshire 03301

John W. Stevens Conservation Society of Southern Vermont P. O. Box 256 Townshend, Vermont 05353

Dr. Mars Longley, Director Occupational & Radiological Health 10 Baldwin Street Montpelier, Vermont 05602

New England Coalition on Nuclear Pollution Hill and Dale Farm West Hill - Faraway Road Putney, Vermont 05346

Public Service Board State of Vermont 120 State Street Montpelier, Vermont 05602

W. P. Murphy, Plant Superintendent
Vermont Yankee Nuclear Power Corporation
P. O. Box 157
Vermon, Vermont 05354

David White Co-Director Vermont Public Interest Reserach Group, Inc. 26 State Street Montpeiler, Vermont 05602

Vermont Yankee Decommissioning Alliance 5 State Street Box 1117 Montpelier, Vermint 05602

Brooks Memorial Library 224 Main Street Brattleboro, Vermont 05301 Mr. Robert L. Smith

-

.

* ·· ·

- 3 -

cc: Resident Inspector c/o U. S. NRC P. O. Box 17(Vernon, Vermon: 05453