

RICHARD P. CROUSE Vice President Nuclear (419) 259-5221

Docket No. 50-346

1

License No. NPF-3

Serial No. 687

February 9, 1981

Director of Nuclear Reactor Regulation Attention: Mr. Robert W. Reid, Chief Operating Reactors Branch No. 4 Division of Licensing United States Nuclear Regulatory Commission Washington, D.C. 20555

Dear Mr. Reid,

This letter is to document the applicable response to Item II.K.2.15 of NUREG 0737, Clarification of TMI Action Plan Requirements for the Davis-Besse Nuclear Power Station Unit 1 (DB-1). This item deals with the mechanical effects of "slug flow" on steam generator tubes. A generic evaluation was done by Babcock and Wilcox and is attached to this submittal. This evaluation is applicable for DB-1.

Very truly yours,

Allem

RPC:TJM:lab

attachment

cc: DB-1 NRC Resident Inspector

A046

THE TOLEDO EDISON COMPANY EDISON PLAZA 300 MADISON AVENUE

8102170036

Docket No. 50-346 License No. NPF-3 Serial No. 687 February 9, 1981 Item II.K.2.15

Transitions from solid natural circulation to reflux boiling and back to solid natural circulation may cause slug flow in the hot leg piping. By use of analysis and/or experiment address the mechanical effects of the induced slug flow on steam generator tubes.

RESPONSE

The loads imposed on the tubes of the steam generator (SG) during the postulated "slug flow" have been conservatively evaluated and found to be acceptable. Based on very conservative assumptions, the end loading on each tube will be 21.5 lb compared to a theoretical buckling load of about 700 lb.

It was assumed for this analysis that a water level has been established in the hot leg piping and inside the tubes of SG. The transient consists of a "front" of solid water impinging on the primary face of the upper tubesheet. The flow was assumed to be equal to full 100% power flow (about 70,000,000 lb/hr). The load is assumed to be a suddenly - applied load. The upper tubesheet is conservatively assumed to offer no resistance to the load and the lower tubesheet is assumed to be fixed so that the entire load is absorbed by tubes directly under the primary inlet nozzle. The flow is assumed to not follow the diffuser so that the velocity impinging on the tubesheet is the same as the velocity in the 36-inch nozzle. Hot leg temperature is assumed to be $605^{\circ}F$.

The velocity in the 36-inch pipe would be 64.4 ft/sec. By use of the momentum equation, the steady-state force on the upper tubesheet due to the velocity would be 16,080 lb_f. Assuming a suddenly-applied load, the momentary force would be 32,160 lb_f. There are about 1500 tubes in a 36-inch diameter circle. Thus the 32,160 lb_f will result in 21.5 lb_f per tube. Since the cross-sectional area of each tube is 0.070 in, the momentary axial compressive stress in these tubes would be 307 psi.