

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A | L | J | M | F | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CON'T
01 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 0 | 9 | 1 | 0 | 8 | 0 | 8 | 1 | 0 | 1 | 5 | 8 | 0 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 | At 1005 on 9-10-80, while performing surveillance test FNP-1-STP-612.0 (RCP Bus Reactor
03 | Trip Undervoltage Relay Functional Test) the 1A RCP bus train B undervoltage relay was
04 | declared inoperable. The as found trip value of the relay was 2622 volts vs 2640 volts
05 | as required by Tech. Spec. 3.3.1.1. Tech. Spec. 3.3.1.1 action statement requirements
06 | were met. Health/safety of the public were not affected.

07 |
08 |
09 |

09 | SYSTEM CODE | I | A | 11 | CAUSE CODE | A | 12 | CAUSE SUBCODE | C | 13 | COMPONENT CODE | R | E | L | A | Y | X | 14 | COMP SUBCODE | D | 15 | VALVE SUBCODE | Z | 16 |
17 | LER NO REPORT NUMBER | 8 | 0 | SEQUENTIAL REPORT NO. | 0 | 5 | 5 | OCCURRENCE CODE | 0 | 3 | REPORT TYPE | L | REVISION NO. | 0 |
ACTION TAKEN | E | 13 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | N | 23 | NPRD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | A | 25 | COMPONENT MANUFACTURER | G | 0 | 8 | 0 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 | Based on a review of previous surveillance test data, this incident was attributed to
11 | the as left condition of the relay following the last surveillance test. The relay was
12 | adjusted and returned to service at 1025 on 9-10-80 following the successful performance
13 | of the surveillance test. A hold point has been placed in the procedure for verifica-
14 | tion by supervision of the proper setpoint in cases where adjustments are necessary.

15 | FACILITY STATUS | E | 28 | % POWER | 1 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | B | 31 | DISCOVERY DESCRIPTION | Performance of surveillance test. | 32
16 | ACTIVITY CONTENT RELEASED | Z | 33 | Z | 34 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36
17 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39
18 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41
19 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | NA | 43
20 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | NA | 45