

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 NYJAF1 200-0000-0000 341111 45

CON'T 01 L 605000333 71100880 8110780 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
02 During normal operation, RCIC System was made inoperable when required by TS 3.5.E.
03 RCIC was made inoperable to allow repair of steam leaks on manual valves associated
04 with the steam line drains. HPCI was demonstrated operable prior to making RCIC
05 inoperable. No significant hazard existed.

03 SYSTEM CODE CE 11 CAUSE CODE E 12 CAUSE SUBCODE F 13 COMPONENT CODE VALVEX 14 COMP. SUBCODE E 15 VALVE SUBCODE D 16
17 LER NO REPORT NUMBER 80 EVENT YEAR 80 SEQUENTIAL REPORT NO. 079 OCCURRENCE CODE 03 REPORT TYPE L REVISION NO. 0
ACTION TAKEN A 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 ATTACHMENT SUBMITTED N 23 NPRO-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER N 25 COMPONENT MANUFACTURER F153

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27
10 Normal ageing and thermal cycling of valves caused leaks. Replacement of valve
11 body to bonnet gaskets effected repair. RCIC was made fully operable within 24
12 hours. No additional action is required.

15 FACILITY STATUS E 28 % POWER 1000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Observation 32
16 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39
18 PERSONNEL INJURIES NU 000 40 DESCRIPTION NA 41
19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

8011120568